







STAIR FRAMING NOTES:

- A FLIGHT OF STAIRS SHALL NOT HAVE A VERTICAL RISE LARGER THAN 12' BETWEEN FLOOR LEVELS OR LANDINGS.
 STAIR HEADROOM MIN. 6'-8" AT ALL PLACES FROM TREAD NOSING.
 STAIR TREADS MAX. RISE 1 3/4", MIN. RUN 10".
 TREAD VARIATION MAX. 3/8" ON ALL TREADS AND RISERS.
 STAIR WIDTH MIN. 36" WIDE.
 LANDINGS FOR STAIRWAYS MIN. 36" X 36" LANDINGS REQUIRED AT:
 ALL EXT. DOORS (EXCEPT FROM HOUSE INTO GARAGE) AT TOP OF STEPS
 BOTTOM OF ALL INTERIOR STAIRWAYS
 TOP OF INTERIOR STAIRWAYS EXCEPT WHERE DOOR DOES NOT SWING OVER STAIRS.
- OVER STAIRS.
- OVER STAIRS.
 STAIRWAY FIRE PROTECTION 1/2" GYP. BD. REQUIRED ON STAIR SOFFITS \$
 WALLS. NAIL AT MAX. 8" O/C INTO ALL STAIR HORSES.
 HANDRAILS REQUIRED WHEN THERE ARE 4 OR MORE RISERS.
 HANDRAILS SHAPE 1 1/4"-2"DIA, OR EQUIVALENT GRIPPING SURFACE.
 HANDRAIL MOUNTING HEIGHT 34"-38" HIGH, MEASURED VERTICALLY ABOVE THE AD NOCIMIC TO TOP OF PAULING. HANDRAIL MOUNTING HEIGHT - 34"-38" HIGH, MEASURED VERTICALLY ABOVE TREAD NOSING TO TOP OF RAILING.
 HANDRAIL CONTINUITY - CONTINOUS, RETURNED AT ENDS TO WALL, NEWEL POST, OR SAFETY TERMINAL. HANDRAILS SHALL BE CONTINUOUS THE FULL LENGTH OF THE STAIRS FROM A POINT DIRECTLY ABOVE THE TOP RISER TO A POINT DIRECTLY ABOVE THE BOTTOM RISER.
 GUARDRAILS REQUIRED ON OPEN SIDES OF STAIRS, LANDINGS, AND PLATFORMS MORE THAN 30" ABOVE GRADE OR FLOOR BELOW.
 GUARDRAIL HEIGHT - MIN. 36" HIGH TO TOP OF GUARDRAIL.
 BULISTER SPACING - SPACED SO THAT A 4" SPHERE CANNOT PASS

- BALUSTER SPACING SPACED SO THAT A 4" SPHERE CANNOT PASS.
 GUARDRAILS WITH HANDRAILS WHEN COMBINED WITH HANDRAIL ON OPEN SIDE OF STAIRS, GUARDRAIL MAY BE BUILT TO HANDRAIL HEIGHT.

HANDRAIL NOTES:

- HANDRAILS ADJACENT TO A WALL SHALL HAVE A SPACE OF NOT LESS THAN 1 1/2" BETWEEN THE WALL AND THE HANDRAILS. MAX. PROJECTION FROM THE WALL SHALL BE 4 1/2".
- SHALL BE 4 1/2. HANDRAILS WITH A CIRCULAR CROSS SECTION SHALL HAVE AN OUTSIDE DIAMETER OF AT LEAST 1 1/4" AND NOT GREATER THAN 2". IF THE HANDRAIL IS NOT CIRCULAR, IT SHALL HAVE A PERIMETER DIMENSION OF AT LEAST 4" AND NOT GREATER THAN 6 1/4" WITH A MAX. CROSS SECTION OF DIMENSION OF 2 1/4". EDGES SHALL HAVE A MIN. RADIUS OF 0.01". 2.
- HANDRAILS WITH A PERIMETER GREATER THAN 6 1/4" SHALL HAVE A GRASPABLE FINGER RECESS AREA ON BOTH SIDES OF PROFILE. THE FINGER RECESS SHALL BEGIN WITH A DISTANCE OF 3/4" MEASURED VERTICALLY FROM 3. THE TALLEST PORTION OF THE PROFILE. THIS REQUIRED DEPTH SHALL CONTINUE FOR AT LEAST 3/8" TO A LEVEL THAT IS NOT LESS THAN 1 3/4" BELOW THE TALLEST PORTION OF THE PROFILE. THE MIN. WIDTH OF THE HANDRAIL ABOVE THE RECESS SHALL BE 1 1/4" TO A MAX. 2 3/4". EDGES SHALL HAVE A MIN. RADIUS OF 0.01.

