

WASHINGTON STATE ENERGY CODE, APPENDIX CHAPTERS

TABLE OF CONTENTS

Appendix A Default Heat Loss

| | |
|---|-------------|
| Coefficients | AE-3 |
| A101 General | AE-3 |
| A101.1 Scope | AE-3 |
| A101.2 Description | AE-3 |
| A101.3 Air Films | AE-3 |
| A101.4 R-Value of Compressed Insulation | AE-3 |
| A101.5 Building Materials | AE-3 |
| A102 Ceilings | AE-5 |
| A102.1 Default U-Factors for Ceilings | AE-5 |
| A102.2 Component Description | AE-5 |
| A102.2.1 Vented Attic | AE-5 |
| A102.2.2 Vaulted Ceiling | AE-5 |
| A102.2.3 Roof Decks | AE-6 |
| A102.2.4 Metal Truss Framing | AE-6 |
| A102.2.5 Metal Building Roof | AE-7 |
| A102.2.6 Insulation Entirely Above Roof Deck | AE-8 |
| A103 Above Grade Walls | AE-8 |
| A103.1 General | AE-8 |
| A103.2 Framing Description | AE-8 |
| A103.3 Component Description | AE-8 |
| A103.3.1 Single Stud Wall | AE-8 |
| A103.3.2 Strap Wall | AE-15 |
| A103.3.3 Double Stud Wall | AE-15 |
| A103.3.4 Log Wall | AE-15 |
| A103.3.5 Stress Skin Panel | AE-15 |
| A103.3.6 Metal Stud Walls | AE-16 |
| A103.3.7 Concrete and Masonry Walls | AE-16 |
| A104 Below Grade Walls and Slabs | AE-25 |
| A104.1 General | AE-25 |
| A104.2 Component Description | AE-25 |
| A104.3 Insulation Description | AE-26 |
| A105 Floors Over Unconditioned Space | AE-26 |
| A105.1 General | AE-26 |
| A105.2 Crawlspace Description | AE-28 |

| | |
|---|-------|
| A105.3 Construction Description | AE-28 |
| A106 On-Grade Slab Floors | AE-28 |
| A106.1 General | AE-28 |
| A106.2 Component Description | AE-29 |
| A106.3 Insulation Description | AE-29 |
| A107 Default U-Factors for Doors | AE-29 |
| A107.1 Doors Without NFRC Certification | AE-29 |
| A107.1(1) Default U-Factors | AE-30 |
| A107.1(2) Defaults for Revolving Doors | AE-31 |
| A107.1(3) Defaults for Steel Emergency Doors | AE-31 |
| A107.1(4) Defaults for Steel Garage and Hangar Doors | AE-32 |
| A108 Air Infiltration | AE-33 |
| A108.1 General | |

Appendix B Default Internal Load Values

| | |
|--|--------------|
| and Schedules | AE-34 |
| B101 General | AE-34 |
| B102 Default Tables of Internal Loads | AE-34 |
| B103 Default Schedules | AE-35 |
| B103.1 Assembly Occupancy | AE-35 |
| B103.2 Health Occupancy | AE-36 |
| B103.3 Hotel/Motel Occupancy | AE-37 |
| B103.4 Light Manufacturing | AE-38 |
| B103.5 Office Occupancy | AE-39 |
| B103.6 Parking Garage | AE-40 |
| B103.7 Restaurant Occupancy | AE-41 |
| B103.8 Retail Occupancy | AE-42 |
| B103.9 School Occupancy | AE-43 |
| B103.10 Warehouse Occupancy | AE-44 |

Appendix C Exterior Design

| | |
|-------------------------|--------------|
| Conditions | AE-45 |
|-------------------------|--------------|

Second Printing: September 2013

Appendix A

DEFAULT HEAT LOSS COEFFICIENTS

SECTION A101 GENERAL REQUIREMENTS

A101.1 Scope. The following defaults shall apply to Chapter 4 of both the (RE) and (CE) sections of the IECC. This chapter includes tables of seasonal average heat loss coefficients for specified nominal insulation.

A101.2 Description. These coefficients were developed primarily from data and procedures from the ASHRAE Fundamentals Handbook.

Coefficients not contained in this chapter may be computed using the procedures listed in this reference if the assumptions in the following sections are used, along with data from the sources referenced above.

A101.3 Air films. Default R-values used for air films shall be as follows:

| <u>R-Value</u> | <u>Condition</u> |
|----------------|--|
| 0.17 | All exterior surfaces |
| 0.61 | Interior horizontal surfaces, heat flow up |
| 0.92 | Interior horizontal surfaces, heat flow down |
| 0.68 | Interior vertical surfaces |

A101.4 Compression of Insulation: Insulation which is compressed shall be rated in accordance with Table A101.4 or reduction in value may be calculated in accordance with the procedures in the ASHRAE Fundamentals Handbook.

A101.5 Building materials. Default R-values used for building materials shall be as shown in Table A101.5.

TABLE A101.4
R-VALUE OF FIBERGLASS BATTS COMPRESSED WITHIN VARIOUS DEPTH CAVITIES

Insulation R-Values at Standard Thickness

| Rated R-Value | | 82 | 71 | 60 | 49 | 38 | 30 | 22 | 21 | 19 | 15 | 13 | 11 |
|------------------------------|--------------------------------|---|------|------|------|-----|-----|-----|-----|----|-----|-----|-----|
| Standard Thickness, Inches | | 26.0 | 22.5 | 19.0 | 15.5 | 12" | 9.5 | 6.5 | 5.5 | 6 | 3.5 | 3.5 | 3.5 |
| Nominal Lumber Sizes, Inches | Actual Depth of Cavity, Inches | Insulation R-Values When Installed in a Confined Cavity | | | | | | | | | | | |
| Truss | 26.0 | 82 | — | — | — | — | — | — | — | — | — | — | — |
| Truss | 22.5 | — | 71 | — | — | — | — | — | — | — | — | — | — |
| Truss | 19.0 | — | — | 60 | — | — | — | — | — | — | — | — | — |
| Truss | 15.5 | — | — | — | 49 | — | — | — | — | — | — | — | — |
| Truss | 12.0 | — | — | — | — | 38 | — | — | — | — | — | — | — |
| 2x12 | 11.25 | — | — | — | — | 37 | — | — | — | — | — | — | — |
| 2x10 | 9.25 | — | — | — | — | 32 | 30 | — | — | — | — | — | — |
| 2x8 | 7.25 | — | — | — | — | 27 | 26 | 22 | 21 | 19 | — | — | — |
| 2x6 | 5.5 | — | — | — | — | — | 21 | 20 | 21 | 18 | — | — | — |
| 2x4 | 3.5 | — | — | — | — | — | — | 14 | — | 13 | 15 | 13 | 11 |
| | 2.5 | — | — | — | — | — | — | — | — | — | — | 9.8 | — |
| | 1.5 | — | — | — | — | — | — | — | — | — | — | 6.3 | 6.0 |

**TABLE A101.5
DEFAULT R-VALUES FOR BUILDING MATERIALS**

| Material | Nominal Size (in.) | Actual Size (in.) | R-Value (Heat Capacity³) |
|---|---------------------------|--------------------------|--|
| Air cavity (unventilated), between metal studs at 16 inches on center ^a | - | - | 0.79 |
| Air cavity (unventilated), all other depths and framing materials ¹ | - | - | 0.91 |
| Airfilm, exterior surfaces ² | - | - | 0.17 |
| Airfilm, interior horizontal surfaces, heat flow up ² | - | - | 0.61 |
| Airfilm, interior horizontal surfaces, heat flow down ² | - | - | 0.92 |
| Airfilm, interior vertical surfaces ² | - | - | 0.68 |
| Brick at R-0.12/in. (face brick, 75% solid/25% core area, 130 lbs/ft ³) | 4 | 3.5 | 0.32 (5.9) |
| Carpet and rubber pad | - | - | 1.23 |
| Concrete at R-0.0625/in., heavyweight (144 lbs/ft ³) | - | 2 | 0.13 (HC-4.8) |
| | - | 4 | 0.25 (HC-9.6) |
| | - | 6 | 0.38 (HC-14.4) |
| | - | 8 | 0.50 (HC-19.2) |
| | - | 10 | 0.63 (HC-24.0) |
| | - | 12 | 0.75 (HC-28.8) |
| Concrete masonry units, solid grouted, lightweight (95 lbs/ft ³) | 6 | - | 0.80 (HC-11.4) |
| Concrete masonry units, solid grouted, normal weight (135 lbs/ft ³) | 6 | - | 0.51 (HC-13.2) |
| Concrete masonry units, partly grouted, lightweight (95 lbs/ft ³) | 6 | - | 1.33 (HC-6.7) |
| Concrete masonry units, partly grouted, normal weight (135 lbs/ft ³) | 6 | - | 0.82 (HC-9.0) |
| Concrete masonry units, solid grouted, lightweight (95 lbs/ft ³) | 8 | - | 1.05 (HC-15.5) |
| Concrete masonry units, solid grouted, normal weight (135 lbs/ft ³) | 8 | - | 0.69 (HC-17.9) |
| Concrete masonry units, partly grouted, lightweight (95 lbs/ft ³) | 8 | - | 1.44 (HC-9.6) |
| Concrete masonry units, partly grouted, normal weight (135 lbs/ft ³) | 8 | - | 0.98 (HC-12.0) |
| Concrete masonry units, solid grouted, lightweight (95 lbs/ft ³) | 10 | - | 1.30 (HC-19.7) |
| Concrete masonry units, solid grouted, normal weight (135 lbs/ft ³) | 10 | - | 0.87 (HC-22.6) |
| Concrete masonry units, partly grouted, lightweight (95 lbs/ft ³) | 10 | - | 1.61 (HC-11.9) |
| Concrete masonry units, partly grouted, normal weight (135 lbs/ft ³) | 10 | - | 1.11 (HC-14.8) |
| Concrete masonry units, solid grouted, lightweight (95 lbs/ft ³) | 12 | - | 1.53 (HC-23.9) |
| Concrete masonry units, solid grouted, normal weight (135 lbs/ft ³) | 12 | - | 1.06 (HC-27.2) |
| Concrete masonry units, partly grouted, lightweight (95 lbs/ft ³) | 12 | - | 1.75 (HC-14.2) |
| Concrete masonry units, partly grouted, normal weight (135 lbs/ft ³) | 12 | - | 1.23 (HC-17.5) |
| Flooring, wood subfloor | - | 0.75 | 0.94 |
| Gypsum board | - | 0.5 | 0.45 |
| | - | 0.625 | 0.56 |
| Metal deck | - | - | 0 |
| Roofing, built-up | - | 0.375 | 0.33 |
| Sheathing, vegetable fiber board, 0.78 in. | - | 0.78 | 2.06 |
| Soil at R-0.104/in. | - | 12 | 1.25 |
| Steel, mild | - | 1 | 0.0031807 |
| Stucco | - | 0.75 | 0.08 |

- a. There is no credit for cavities that are open to outside air.
- b. Air films do not apply to air cavities within an assembly.
- c. For heat capacity for concrete and concrete masonry materials with densities other than the values listed in Table A101.5, see Tables A3.1B and A3.1C in ASHRAE/IESNA Standard 90.1.

SECTION A102 CEILINGS

A102.1 General. Table A102.1 lists heat loss coefficients for the opaque portion of exterior ceilings below vented attics, vaulted ceilings and roof decks in units of Btu/h × ft² × °F of ceiling.

They are derived from procedures listed in the ASHRAE Fundamentals Handbook. Ceiling U-factors are modified for the buffering effect of the attic, assuming an indoor temperature of 65°F and an outdoor temperature of 45°F.

A102.1.1 Metal framed ceilings. The nominal R-values in Table A103.3.6.2: Effective R-Values for Metal Framing and Cavity Only may be used for purposes of calculating metal framed ceiling section U-factors in lieu of the ASHRAE zone calculation method as provided in Chapter 27 of the ASHRAE Fundamentals Handbook.

Metal building roofs have a different construction and are addressed in Table A102.2.5.

A102.2 Component description. The four types of ceilings are characterized as follows:

A102.2.1 Ceilings below a vented attic. Attic insulation is assumed to be blown-in, loose-fill fiberglass with a K-value of 2.6 h × ft² × °F/Btu per inch. Full bag count for specified R-value is assumed in all cases. Ceiling dimensions for flat ceiling calculations are 45 by 30 feet, with a gabled roof having a 4/12 pitch. The attic is assumed to vent naturally at the rate of 3 air changes per hour through soffit and ridge vents. A void fraction of 0.002 is assumed for all attics with insulation baffles. Standard-framed, un baffled attics assume a void fraction of 0.008.

Attic framing is either standard or advanced. Standard framing assumes tapering of insulation depth around the perimeter with resultant decrease in thermal resistance. An increased R-value is assumed in the center of the ceiling due to the effect of piling leftover insulation. Advanced framing assumes full and even depth of insulation

**TABLE A102.1
DEFAULT U-FACTORS FOR CEILINGS**

| | Standard Frame | Advanced Frame |
|-------------------------------------|---------------------------|-----------------|
| Ceilings Below Vented Attics | | |
| Flat | Baffled | |
| R-19 | 0.049 | 0.047 |
| R-30 | 0.036 | 0.032 |
| R-38 | 0.031 | 0.026 |
| R-49 | 0.027 | 0.020 |
| R-60 | 0.025 | 0.017 |
| Scissors Truss | | |
| R-30 (4/12 roof pitch) | 0.043 | 0.031 |
| R-38 (4/12 roof pitch) | 0.040 | 0.025 |
| R-49 (4/12 roof pitch) | 0.038 | 0.020 |
| R-30 (5/12 roof pitch) | 0.039 | 0.032 |
| R-38 (5/12 roof pitch) | 0.035 | 0.026 |
| R-49 (5/12 roof pitch) | 0.032 | 0.020 |
| Vaulted Ceilings | | |
| | 16" O.C. | 24" O.C. |
| Vented | | |
| R-19 2x10 joist | 0.049 | 0.048 |
| R-30 2x12 joist | 0.034 | 0.033 |
| R-38 2x14 joist | 0.027 | 0.027 |
| Unvented | | |
| R-30 2x10 joist | 0.034 | 0.033 |
| R-38 2x12 joist | 0.029 | 0.027 |
| R-21 + R-21 2x12 joist | 0.026 | 0.025 |
| Roof Deck | | |
| | 4x Beams, 48" O.C. | |
| R-12.5 2" Rigid insulation | 0.064 | |
| R-21.9 3.5" Rigid insulation | 0.040 | |
| R-37.5 6" Rigid insulation | 0.025 | |
| R-50 8" Rigid insulation | 0.019 | |

extending to the outside edge of exterior walls. Advanced framing does not change from the default value. U-factors for flat ceilings below vented attics with standard framing may be modified with the following table:

| Roof Pitch | U-factor for Standard Framing | |
|------------|-------------------------------|-------|
| | R-30 | R-38 |
| 4/12 | 0.036 | 0.031 |
| 5/12 | 0.035 | 0.030 |
| 6/12 | 0.034 | 0.029 |
| 7/12 | 0.034 | 0.029 |
| 8/12 | 0.034 | 0.028 |
| 9/12 | 0.034 | 0.028 |
| 10/12 | 0.033 | 0.028 |
| 11/12 | 0.033 | 0.027 |
| 12/12 | 0.033 | 0.027 |

Vented scissors truss attics assume a ceiling pitch of 2/12 with a roof pitch of either 4/12 or 5/12. Unbaffled standard framed scissors truss attics are assumed to have a void fraction of 0.016.

A102.2.2 Vaulted ceilings. Insulation is assumed to be fiberglass batts installed in roof joist cavities. In the vented case, at least 1.5 inches between the top of the batts and the underside of the roof sheathing is left open for ventilation in each cavity. A ventilation rate of 3.0 air changes per hour is assumed. In the unvented or dense pack case, the ceiling cavity is assumed to be fully packed with insulation, leaving no space for ventilation.

A102.2.3 Roof decks. Rigid insulation is applied to the top of roof decking with no space left for ventilation. Roofing materials are attached directly on top of the insulation. Framing members are often left exposed on the interior side.

A102.2.4 Metal truss framing. Overall system tested values for the roof/ceiling U_o for metal framed truss assemblies from approved laboratories shall be used, when such data is acceptable to the building official.

Alternatively, the U_o for roof/ceiling assemblies using metal truss framing may be obtained from Tables A102.2.4(1) through A102.2.4(5).

**TABLE A102.2.4(1)
STEEL TRUSS^a FRAMED CEILING U_o**

| Cavity R-value | Truss Span (ft) | | | | | | | | | | | | |
|----------------|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | 12 | 14 | 16 | 18 | 20 | 22 | 24 | 26 | 28 | 30 | 32 | 34 | 36 |
| 19 | 0.1075 | 0.0991 | 0.0928 | 0.0878 | 0.0839 | 0.0807 | 0.0780 | 0.0757 | 0.0737 | 0.0720 | 0.0706 | 0.0693 | 0.0681 |
| 30 | 0.0907 | 0.0823 | 0.0760 | 0.0710 | 0.0671 | 0.0638 | 0.0612 | 0.0589 | 0.0569 | 0.0552 | 0.0538 | 0.0525 | 0.0513 |
| 38 | 0.0844 | 0.0759 | 0.0696 | 0.0647 | 0.0607 | 0.0575 | 0.0548 | 0.0525 | 0.0506 | 0.0489 | 0.0474 | 0.0461 | 0.0449 |
| 49 | 0.0789 | 0.0704 | 0.0641 | 0.0592 | 0.0552 | 0.0520 | 0.0493 | 0.0470 | 0.0451 | 0.0434 | 0.0419 | 0.0406 | 0.0395 |

**TABLE A102.2.4(2)
STEEL TRUSS^a FRAMED CEILING U_o WITH R-3 SHEATHING**

| Cavity R-value | Truss Span (ft) | | | | | | | | | | | | |
|----------------|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | 12 | 14 | 16 | 18 | 20 | 22 | 24 | 26 | 28 | 30 | 32 | 34 | 36 |
| 19 | 0.0809 | 0.0763 | 0.0728 | 0.0701 | 0.0679 | 0.0661 | 0.0647 | 0.0634 | 0.0623 | 0.0614 | 0.0606 | 0.0599 | 0.0592 |
| 30 | 0.0641 | 0.0595 | 0.0560 | 0.0533 | 0.0511 | 0.0493 | 0.0478 | 0.0466 | 0.0455 | 0.0446 | 0.0438 | 0.0431 | 0.0424 |
| 38 | 0.0577 | 0.0531 | 0.0496 | 0.0469 | 0.0447 | 0.0430 | 0.0415 | 0.0402 | 0.0392 | 0.0382 | 0.0374 | 0.0367 | 0.0361 |
| 49 | 0.0523 | 0.0476 | 0.0441 | 0.0414 | 0.0393 | 0.0375 | 0.0360 | 0.0348 | 0.0337 | 0.0328 | 0.0319 | 0.0312 | 0.0306 |

**TABLE A102.2.4(3)
STEEL TRUSS^a FRAMED CEILING U_o WITH R-5 SHEATHING**

| Cavity R-value | Truss Span (ft) | | | | | | | | | | | | |
|----------------|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | 12 | 14 | 16 | 18 | 20 | 22 | 24 | 26 | 28 | 30 | 32 | 34 | 36 |
| 19 | 0.0732 | 0.0697 | 0.0670 | 0.0649 | 0.0633 | 0.0619 | 0.0608 | 0.0598 | 0.0590 | 0.0583 | 0.0577 | 0.0571 | 0.0567 |
| 30 | 0.0564 | 0.0529 | 0.0502 | 0.0481 | 0.0465 | 0.0451 | 0.0440 | 0.0430 | 0.0422 | 0.0415 | 0.0409 | 0.0403 | 0.0399 |
| 38 | 0.0501 | 0.0465 | 0.0438 | 0.0418 | 0.0401 | 0.0388 | 0.0376 | 0.0367 | 0.0359 | 0.0351 | 0.0345 | 0.0340 | 0.0335 |
| 49 | 0.0446 | 0.0410 | 0.0384 | 0.0363 | 0.0346 | 0.0333 | 0.0322 | 0.0312 | 0.0304 | 0.0297 | 0.0291 | 0.0285 | 0.0280 |

TABLE A102.2.4(4)
STEEL TRUSS^a FRAMED CEILING U_o WITH R-10 SHEATHING

| Cavity R-value | Truss Span (ft) | | | | | | | | | | | | |
|-------------------|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | 12 | 14 | 16 | 18 | 20 | 22 | 24 | 26 | 28 | 30 | 32 | 34 | 36 |
| 19 | 0.0626 | 0.0606 | 0.0590 | 0.0578 | 0.0569 | 0.0561 | 0.0555 | 0.0549 | 0.0545 | 0.0541 | 0.0537 | 0.0534 | 0.0531 |
| 30 | 0.0458 | 0.0437 | 0.0422 | 0.0410 | 0.0401 | 0.0393 | 0.0387 | 0.0381 | 0.0377 | 0.0373 | 0.0369 | 0.0366 | 0.0363 |
| 38 | 0.0394 | 0.0374 | 0.0359 | 0.0347 | 0.0337 | 0.0330 | 0.0323 | 0.0318 | 0.0313 | 0.0309 | 0.0305 | 0.0302 | 0.0299 |
| 49 | 0.0339 | 0.0319 | 0.0304 | 0.0292 | 0.0283 | 0.0275 | 0.0268 | 0.0263 | 0.0258 | 0.0254 | 0.0251 | 0.0247 | 0.0245 |

TABLE A102.2.4(5)
STEEL TRUSS^a FRAMED CEILING U_o WITH R-15 SHEATHING

| Cavity R-value | Truss Span (ft) | | | | | | | | | | | | |
|-------------------|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | 12 | 14 | 16 | 18 | 20 | 22 | 24 | 26 | 28 | 30 | 32 | 34 | 36 |
| 19 | 0.0561 | 0.0550 | 0.0541 | 0.0535 | 0.0530 | 0.0526 | 0.0522 | 0.0519 | 0.0517 | 0.0515 | 0.0513 | 0.0511 | 0.0509 |
| 30 | 0.0393 | 0.0382 | 0.0373 | 0.0367 | 0.0362 | 0.0358 | 0.0354 | 0.0351 | 0.0349 | 0.0347 | 0.0345 | 0.0343 | 0.0341 |
| 38 | 0.0329 | 0.0318 | 0.0310 | 0.0303 | 0.0298 | 0.0294 | 0.0291 | 0.0288 | 0.0285 | 0.0283 | 0.0281 | 0.0279 | 0.0278 |
| 49 | 0.0274 | 0.0263 | 0.0255 | 0.0249 | 0.0244 | 0.0239 | 0.0236 | 0.0233 | 0.0230 | 0.0228 | 0.0226 | 0.0225 | 0.0223 |

Footnotes for Tables A102.2.4(1) through A102.2.4(5)

- Assembly values based on 24 inch on center truss spacing; 11 Truss member connections penetrating insulation (4 at the eaves, 7 in the interior space); ½ inch drywall ceiling; all truss members are 2x4 "C" channels with a solid web.
- Ceiling sheathing installed between bottom chord and drywall.

A102.2.5 Metal building roof. Table A102.2.5: The base assembly is a roof where the insulation is compressed when installed beneath metal roof panels attached to the steel structure (purlins). Additional assemblies include continuous insulation, uncompressed and uninterrupted by framing.

U-factors for metal building roofs shall be taken from Table A102.2.5, provided the average purlin spacing is at least 52 inches and the R-value of the thermal spacer block is greater than or equal to the thermal spacer block R-value indicated in Table A107.2.5 for the assembly. It is not acceptable to use the U-factors in Table A102.2.6 if additional insulated sheathing is not continuous.

A102.2.5.1 Single layer. The rated R-value of insulation is for insulation installed perpendicular to and draped over purlins and then compressed when the metal roof panels are attached. A minimum R-3 (R-0.5) thermal spacer block between the purlins and the metal roof panels is required, unless compliance is shown by the overall assembly U-factor.

A102.2.5.2 Double layer. The first rated R-value of insulation is for insulation installed perpendicular to and draped over purlins. The second rated R-value of insulation is for unfaced insulation installed above the first layer and parallel to the purlins and then compressed when the metal roof panels are attached. A minimum R-3 (R-0.5) thermal spacer block between the

purlins and the metal roof panels is required, unless compliance is shown by the overall assembly U-factor.

A102.2.5.3 Continuous insulation. For continuous insulation (e.g., insulation boards or blankets), it is assumed that the insulation is installed below the purlins and is uninterrupted by framing members. Insulation exposed to the conditioned space or semi-heated space shall have a facing, and all insulation seams shall be continuously sealed to provide a continuous air barrier.

A102.2.5.4 Liner system (Ls). A continuous membrane is installed below the purlins and uninterrupted by framing members. Uncompressed, unfaced insulation rests on top of the membrane between the purlins. For multilayer installations, the last rated R-value of insulation is for unfaced insulation draped over purlins and then compressed when the metal roof panels are attached. A minimum R-3 (R-0.5) thermal spacer block between the purlins and the metal roof panels is required, unless compliance is shown by the overall assembly U-factor.

A102.2.5.5 Filled cavity. The first rated R-value of insulation is for faced insulation installed parallel to the purlins. The second rated R-value of insulation is for unfaced insulation installed above the first layer, parallel to and between the purlins and compressed when the metal roof panels are attached. The facer of the

first layer of insulation is of sufficient width to be continuously sealed to the top flange of the purlins and to accommodate the full thickness of the second layer of insulation. A supporting structure retains the bottom of the first layer at the prescribed depth required for the full thickness of the second layer of insulation being installed above it. A minimum R-5 (R-0.9) thermal spacer block between the purlins and the metal roof panels is required, unless compliance is shown by the overall assembly U-factor.

A102.2.6 Roofs with insulation entirely above deck (uninterrupted by framing). Table A102.2.6: The base assembly is continuous insulation over a structural deck. Added insulation is continuous and uninterrupted by framing. For the insulation, the first column lists the R-value for continuous insulation with a uniform thickness; the second column lists the comparable area-weighted average R-value for continuous insulation provided that the insulation thickness is never less than R-5 (except at roof drains) and that the slope is no greater than 1/4 inch per foot.

SECTION A103 ABOVE GRADE WALLS

A103.1 General. The tables in this section list heat loss coefficients for the opaque portion of above-grade wood stud frame walls, metal stud frame walls and concrete masonry walls ($\text{Btu/h} \times \text{ft}^2 \times ^\circ\text{F}$). They are derived from procedures listed in the ASHRAE Fundamentals Handbook. For intermediate floor slabs which penetrate the insulated wall, use the concrete wall U-factors in Table A103.3.7.1(1).

Insulation is assumed to uniformly fill the entire cavity and to be installed as per manufacturer's directions. All walls are assumed to be finished on the inside with 1/2 inch gypsum wallboard, and on the outside with either beveled wood siding over 1/2 inch plywood sheathing or with 5/8 inch T1-11 siding. Insulated sheathing (either interior or exterior) is assumed to cover the entire opaque wall surface, except where modified in accordance with footnote h to Table C402.1.1.

Metal building walls have a different construction and are addressed in Table A103.3.6.3.

A103.2 Framing description. For wood stud frame walls, three framing types are considered and defined as follows:

A103.2.1 Standard. Studs framed on 16 inch centers with double top plate and single bottom plate. Corners use three studs and each opening is framed using two studs. Headers consist of double 2x or single 4x material with an air space left between the header and the exterior sheathing. Interior partition wall/exterior wall intersections use two studs in the exterior wall.

Standard framing weighting factors:

| | |
|------------------|------|
| Studs and plates | 0.19 |
| Insulated cavity | 0.77 |
| Headers | 0.04 |

A103.2.2 Intermediate. Studs framed on 16 inch centers with double top plate and single bottom plate. Corners use two studs or other means of fully insulating corners, and each opening is framed by two studs. Headers consist of double 2x material with R-10 insulation. Interior partition wall/exterior wall intersections are fully insulated in the exterior wall.

Intermediate framing weighting factors:

| | |
|------------------|------|
| Studs and plates | 0.18 |
| Insulated cavity | 0.78 |
| Headers | 0.04 |

A103.2.3 Advanced. Studs framed on 24 inch centers with double top plate and single bottom plate. Corners use two studs or other means of fully insulating corners, and one stud is used to support each header. Headers consist of double 2x material with R-10 insulation. Interior partition wall/exterior wall intersections are fully insulated in the exterior wall.

Advanced framing weighting factors:

| | |
|------------------|------|
| Studs and plates | 0.13 |
| Insulated cavity | 0.83 |
| Headers | 0.04 |

A103.3 Component description. Default coefficients for the following types of walls are listed: Single-stud walls, strap walls, double-stud walls, log walls, stress-skin panels, metal stud walls, and metal building walls.

A103.3.1 Single-stud wall. Tables A103.3.1(1) through A103.3.1(8): Assumes either 2 x 4 or 2 x 6 studs framed on 16 or 24 inch centers. Headers are solid for 2 x 4 walls and double 2x for 2 x 6 walls, with either dead-air or rigid-board insulation in the remaining space.

**TABLE A102.2.5
DEFAULT U-FACTORS FOR METAL BUILDING ROOFS**

| Insulation System | Rated R-Value of Insulation | Overall U-Factor for Entire Base Roof Assembly | Overall U-Factor for Assembly of Base Roof Plus Continuous Insulation (uninterrupted by framing) Rated R-Value of Continuous Insulation | | | | | |
|---|-----------------------------|--|--|-------|--------|-------|--------|-------|
| | | | R-6.5 | R-13 | R-19.5 | R-26 | R-32.5 | R-39 |
| Standing Seam Roofs with Thermal Spacer Blocks^{a,b} | | | | | | | | |
| Single Layer | None | 1.280 | 0.137 | 0.073 | 0.049 | 0.037 | 0.030 | 0.025 |
| | R-10 | 0.115 | 0.066 | 0.046 | 0.035 | 0.029 | 0.024 | 0.021 |
| | R-11 | 0.107 | 0.063 | 0.045 | 0.035 | 0.028 | 0.024 | 0.021 |
| | R-13 | 0.101 | 0.061 | 0.044 | 0.034 | 0.028 | 0.024 | 0.020 |
| | R-16 | 0.096 | 0.059 | 0.043 | 0.033 | 0.027 | 0.023 | 0.020 |
| | R-19 | 0.082 | 0.053 | 0.040 | 0.031 | 0.026 | 0.022 | 0.020 |
| Double Layer | R-10 .+ R-10 | 0.088 | 0.056 | 0.041 | 0.032 | 0.027 | 0.023 | 0.020 |
| | R-10 .+ R-11 | 0.086 | 0.055 | 0.041 | 0.032 | 0.027 | 0.023 | 0.020 |
| | R-11 .+ R-11 | 0.085 | 0.055 | 0.040 | 0.032 | 0.026 | 0.023 | 0.020 |
| | R-10 .+ R-13 | 0.084 | 0.054 | 0.040 | 0.032 | 0.026 | 0.023 | 0.020 |
| | R-11 .+ R-13 | 0.082 | 0.053 | 0.040 | 0.032 | 0.026 | 0.022 | 0.020 |
| | R-13 .+ R-13 | 0.075 | 0.050 | 0.038 | 0.030 | 0.025 | 0.022 | 0.019 |
| | R10 .+ R-19 | 0.074 | 0.050 | 0.038 | 0.030 | 0.025 | 0.022 | 0.019 |
| | R-11 .+ R-19 | 0.072 | 0.049 | 0.037 | 0.030 | 0.025 | 0.022 | 0.019 |
| | R-13 .+ R-19 | 0.068 | 0.047 | 0.036 | 0.029 | 0.025 | 0.021 | 0.019 |
| | R-16 .+ R-19 | 0.065 | 0.046 | 0.035 | 0.029 | 0.024 | 0.021 | 0.018 |
| R-19 .+ R-19 | 0.060 | 0.043 | 0.034 | 0.028 | 0.023 | 0.020 | 0.018 | |
| Liner System | R-19 .+ R-11 | 0.035 | | | | | | |
| | R-25 .+ R-11 | 0.031 | | | | | | |
| | R-30 .+ R-11 | 0.029 | | | | | | |
| | R-25 .+ R-11 .+ R-11 | 0.026 | | | | | | |
| Filled Cavity with Thermal Spacer Blocks^c | | | | | | | | |
| | R-10 .+ R-19 | 0.057 | 0.042 | 0.033 | 0.027 | 0.023 | 0.020 | 0.018 |
| Standing Seam Roofs without Thermal Spacer Blocks | | | | | | | | |
| Liner System | R-19 .+ R-11 | 0.040 | | | | | | |
| Thru-Fastened Roofs without Thermal Spacer Blocks | | | | | | | | |
| Single Layer | R-10 | 0.184 | | | | | | |
| | R-11 | 0.182 | | | | | | |
| | R-13 | 0.174 | | | | | | |
| | R-16 | 0.157 | | | | | | |
| | R-19 | 0.151 | | | | | | |
| Liner System | R-19 .+ R-11 | 0.044 | | | | | | |

(Multiple R-values are listed in order from inside to outside)

- A standing seam roof clip that provides a minimum 1.5 in. distance between the top of the purlins and the underside of the metal roof panels is required.
- A minimum R-3 thermal spacer block is required.
- A minimum R-5 thermal spacer block is required.

**TABLE A102.2.6
ASSEMBLY U-FACTORS FOR ROOFS WITH INSULATION ENTIRELY ABOVE DECK
(UNINTERRUPTED BY FRAMING)**

| Rated R-Value of Insulation Alone: Minimum Throughout, Unslowed | Rated R-Value of Insulation Alone: Average (R-5 minimum), Sloped (1/4 inch per foot maximum) | Overall U-Factor for Entire Assembly |
|--|---|---|
| R-0 | Not Allowed | U-1.282 |
| R-1 | Not Allowed | U-0.562 |
| R-2 | Not Allowed | U-0.360 |
| R-3 | Not Allowed | U-0.265 |
| R-4 | Not Allowed | U-0.209 |
| R-5 | Not Allowed | U-0.173 |
| R-6 | R-7 | U-0.147 |
| R-7 | R-8 | U-0.129 |
| R-8 | R-9 | U-0.114 |
| R-9 | R-10 | U-0.102 |
| R-10 | R-12 | U-0.093 |
| R-11 | R-13 | U-0.085 |
| R-12 | R-15 | U-0.078 |
| R-13 | R-16 | U-0.073 |
| R-14 | R-18 | U-0.068 |
| R-15 | R-20 | U-0.063 |
| R-16 | R-22 | U-0.060 |
| R-17 | R-23 | U-0.056 |
| R-18 | R-25 | U-0.053 |
| R-19 | R-27 | U-0.051 |
| R-20 | R-29 | U-0.048 |
| R-21 | R-31 | U-0.046 |
| R-22 | R-33 | U-0.044 |
| R-23 | R-35 | U-0.042 |
| R-24 | R-37 | U-0.040 |
| R-25 | R-39 | U-0.039 |
| R-26 | R-41 | U-0.037 |
| R-27 | R-43 | U-0.036 |
| R-28 | R-46 | U-0.035 |
| R-29 | R-48 | U-0.034 |
| R-30 | R-50 | U-0.032 |
| R-35 | R-61 | U-0.028 |
| R-40 | R-73 | U-0.025 |
| R-45 | R-86 | U-0.022 |
| R-50 | R-99 | U-0.020 |
| R-55 | R-112 | U-0.018 |
| R-60 | R-126 | U-0.016 |

TABLE A103.3.1(1)
2 x 4 Single Wood Stud: R-11 Batt

NOTE:

Nominal Batt R-value:
 R-11 at 3.5 inch thickness

Installed Batt R-value:
 R-11 in 3.5 inch cavity

| R-value of Foam Board | Siding Material/Framing Type | | | |
|--------------------------|------------------------------|-------|-------|-------|
| | Lapped Wood | | T1-11 | |
| | STD | ADV | STD | ADV |
| 0 | 0.088 | 0.084 | 0.094 | 0.090 |
| 1 | 0.080 | 0.077 | 0.085 | 0.082 |
| 2 | 0.074 | 0.071 | 0.078 | 0.075 |
| 3 | 0.069 | 0.066 | 0.072 | 0.070 |
| 4 | 0.064 | 0.062 | 0.067 | 0.065 |
| 5 | 0.060 | 0.058 | 0.063 | 0.061 |
| 6 | 0.056 | 0.055 | 0.059 | 0.057 |
| 7 | 0.053 | 0.052 | 0.055 | 0.054 |
| 8 | 0.051 | 0.049 | 0.052 | 0.051 |
| 9 | 0.048 | 0.047 | 0.050 | 0.049 |
| 10 | 0.046 | 0.045 | 0.047 | 0.046 |
| 11 | 0.044 | 0.043 | 0.045 | 0.044 |
| 12 | 0.042 | 0.041 | 0.043 | 0.042 |

TABLE A103.3.1(2)
2 x 4 Single Wood Stud: R-13 Batt

NOTE:

Nominal Batt R-value:
 R-13 at 3.63 inch thickness

Installed Batt R-value:
 R-12.7 in 3.5 inch cavity

| R-value of Foam Board | Siding Material/Framing Type | | | |
|--------------------------|------------------------------|-------|-------|-------|
| | Lapped Wood | | T1-11 | |
| | STD | ADV | STD | ADV |
| 0 | 0.082 | 0.078 | 0.088 | 0.083 |
| 1 | 0.075 | 0.072 | 0.080 | 0.076 |
| 2 | 0.069 | 0.066 | 0.073 | 0.070 |
| 3 | 0.065 | 0.062 | 0.068 | 0.065 |
| 4 | 0.060 | 0.058 | 0.063 | 0.061 |
| 5 | 0.057 | 0.055 | 0.059 | 0.057 |
| 6 | 0.053 | 0.052 | 0.056 | 0.054 |
| 7 | 0.051 | 0.049 | 0.052 | 0.051 |
| 8 | 0.048 | 0.047 | 0.050 | 0.048 |
| 9 | 0.046 | 0.045 | 0.047 | 0.046 |
| 10 | 0.044 | 0.043 | 0.045 | 0.044 |
| 11 | 0.042 | 0.041 | 0.043 | 0.042 |
| 12 | 0.040 | 0.039 | 0.041 | 0.040 |

TABLE A103.3.1(3)
2 x 4 Single Wood Stud: R-15 Batt

NOTE:
 Nominal Batt R-value:
 R-15 at 3.5 inch thickness

Installed Batt R-value:
 R-15 in 3.5 inch cavity

| R-value of Foam Board | Siding Material/Framing Type | | | |
|--------------------------|------------------------------|-------|-------|-------|
| | Lapped Wood | | T1-11 | |
| | STD | ADV | STD | ADV |
| 0 | 0.076 | 0.071 | 0.081 | 0.075 |
| 1 | 0.069 | 0.065 | 0.073 | 0.069 |
| 2 | 0.064 | 0.061 | 0.068 | 0.069 |
| 3 | 0.060 | 0.057 | 0.063 | 0.059 |
| 4 | 0.056 | 0.053 | 0.059 | 0.056 |
| 5 | 0.053 | 0.051 | 0.055 | 0.052 |
| 6 | 0.050 | 0.048 | 0.052 | 0.050 |
| 7 | 0.047 | 0.046 | 0.049 | 0.047 |
| 8 | 0.045 | 0.044 | 0.047 | 0.045 |
| 9 | 0.043 | 0.042 | 0.044 | 0.043 |
| 10 | 0.041 | 0.040 | 0.042 | 0.041 |
| 11 | 0.039 | 0.038 | 0.041 | 0.039 |
| 12 | 0.038 | 0.037 | 0.039 | 0.038 |

TABLE A103.3.1(4)
2 x 6 Single Wood Stud: R-19 Batt

NOTE:
 Nominal Batt R-value:
 R-19 at 6 inch thickness

Installed Batt R-value:
 R-18 in 5.5 inch cavity

| R-value of Foam Board | Siding Material/Framing Type | | | | | |
|--------------------------|------------------------------|-------|-------|-------|-------|-------|
| | Lapped Wood | | | T1-11 | | |
| | STD | INT | ADV | STD | INT | ADV |
| 0 | 0.062 | 0.058 | 0.055 | 0.065 | 0.061 | 0.058 |
| 1 | 0.058 | 0.055 | 0.052 | 0.060 | 0.057 | 0.055 |
| 2 | 0.054 | 0.052 | 0.050 | 0.056 | 0.054 | 0.051 |
| 3 | 0.051 | 0.049 | 0.047 | 0.053 | 0.051 | 0.049 |
| 4 | 0.048 | 0.046 | 0.045 | 0.050 | 0.048 | 0.046 |
| 5 | 0.046 | 0.044 | 0.043 | 0.048 | 0.046 | 0.044 |
| 6 | 0.044 | 0.042 | 0.041 | 0.045 | 0.044 | 0.042 |
| 7 | 0.042 | 0.040 | 0.039 | 0.043 | 0.042 | 0.040 |
| 8 | 0.040 | 0.039 | 0.038 | 0.041 | 0.040 | 0.039 |
| 9 | 0.038 | 0.037 | 0.035 | 0.039 | 0.038 | 0.037 |
| 10 | 0.037 | 0.036 | 0.035 | 0.038 | 0.037 | 0.036 |
| 11 | 0.036 | 0.035 | 0.034 | 0.036 | 0.035 | 0.035 |
| 12 | 0.034 | 0.033 | 0.033 | 0.035 | 0.034 | 0.033 |

TABLE A103.3.1(5)
2 x 6 Single Wood Stud: R-21 Batt

NOTE:

Nominal Batt R-value:
R-21 at 5.5 inch thickness

Installed Batt R-value:
R-21 in 5.5 inch cavity

| R-value of Foam Board | Siding Material/Framing Type | | | | | |
|--------------------------|------------------------------|-------|-------|-------|-------|-------|
| | Lapped Wood | | | T1-11 | | |
| | STD | INT | ADV | STD | INT | ADV |
| 0 | 0.057 | 0.054 | 0.051 | 0.060 | 0.056 | 0.053 |
| 1 | 0.054 | 0.051 | 0.048 | 0.056 | 0.053 | 0.050 |
| 2 | 0.050 | 0.048 | 0.045 | 0.052 | 0.050 | 0.047 |
| 3 | 0.048 | 0.045 | 0.043 | 0.049 | 0.047 | 0.045 |
| 4 | 0.045 | 0.043 | 0.041 | 0.047 | 0.045 | 0.043 |
| 5 | 0.043 | 0.041 | 0.040 | 0.044 | 0.042 | 0.041 |
| 6 | 0.041 | 0.039 | 0.038 | 0.042 | 0.041 | 0.039 |
| 7 | 0.039 | 0.038 | 0.036 | 0.040 | 0.039 | 0.037 |
| 8 | 0.038 | 0.036 | 0.035 | 0.039 | 0.037 | 0.036 |
| 9 | 0.036 | 0.035 | 0.034 | 0.037 | 0.036 | 0.035 |
| 10 | 0.035 | 0.034 | 0.033 | 0.036 | 0.035 | 0.033 |
| 11 | 0.033 | 0.033 | 0.032 | 0.034 | 0.033 | 0.032 |
| 12 | 0.032 | 0.031 | 0.031 | 0.033 | 0.032 | 0.031 |

TABLE A103.3.1(6)
2 x 6 Single Wood Stud: R-22 Batt

NOTE:

Nominal Batt R-value:
R-22 at 6.75 inch thickness

Installed Batt R-value:
R-20 in 5.5 inch cavity

| R-value of Foam Board | Siding Material/Framing Type | | | | | |
|--------------------------|------------------------------|-------|-------|-------|-------|-------|
| | Lapped Wood | | | T1-11 | | |
| | STD | INT | ADV | STD | INT | ADV |
| 0 | 0.059 | 0.055 | 0.052 | 0.062 | 0.058 | 0.054 |
| 1 | 0.055 | 0.052 | 0.049 | 0.057 | 0.054 | 0.051 |
| 2 | 0.052 | 0.049 | 0.047 | 0.054 | 0.051 | 0.048 |
| 3 | 0.049 | 0.046 | 0.044 | 0.050 | 0.048 | 0.046 |
| 4 | 0.046 | 0.044 | 0.042 | 0.048 | 0.046 | 0.044 |
| 5 | 0.044 | 0.042 | 0.041 | 0.045 | 0.043 | 0.042 |
| 6 | 0.042 | 0.040 | 0.039 | 0.043 | 0.042 | 0.040 |
| 7 | 0.040 | 0.039 | 0.037 | 0.041 | 0.040 | 0.038 |
| 8 | 0.038 | 0.037 | 0.036 | 0.039 | 0.038 | 0.037 |
| 9 | 0.037 | 0.036 | 0.035 | 0.038 | 0.037 | 0.035 |
| 10 | 0.035 | 0.034 | 0.033 | 0.036 | 0.035 | 0.034 |
| 11 | 0.034 | 0.033 | 0.032 | 0.035 | 0.034 | 0.033 |
| 12 | 0.033 | 0.032 | 0.031 | 0.034 | 0.033 | 0.032 |

TABLE A103.3.1(7)
2 x 6 Single Wood Stud: Two R-11 Batts

NOTE:
 Nominal Batt R-value:
 R-22 at 7 inch thickness

Installed Batt R-value:
 R-18.9 in 5.5 inch cavity

| R-value of Foam Board | Siding Material/Framing Type | | | | | |
|--------------------------|------------------------------|-------|-------|-------|-------|-------|
| | Lapped Wood | | | T1-11 | | |
| | STD | INT | ADV | STD | INT | ADV |
| 0 | 0.060 | 0.057 | 0.054 | 0.063 | 0.059 | 0.056 |
| 1 | 0.056 | 0.053 | 0.051 | 0.059 | 0.056 | 0.053 |
| 2 | 0.053 | 0.050 | 0.048 | 0.055 | 0.052 | 0.050 |
| 3 | 0.050 | 0.048 | 0.046 | 0.052 | 0.049 | 0.047 |
| 4 | 0.047 | 0.045 | 0.044 | 0.049 | 0.047 | 0.045 |
| 5 | 0.045 | 0.043 | 0.042 | 0.046 | 0.045 | 0.043 |
| 6 | 0.043 | 0.041 | 0.040 | 0.044 | 0.043 | 0.041 |
| 7 | 0.041 | 0.040 | 0.038 | 0.042 | 0.041 | 0.039 |
| 8 | 0.039 | 0.038 | 0.037 | 0.040 | 0.039 | 0.038 |
| 9 | 0.038 | 0.037 | 0.036 | 0.039 | 0.038 | 0.036 |
| 10 | 0.036 | 0.035 | 0.034 | 0.037 | 0.036 | 0.035 |
| 11 | 0.035 | 0.034 | 0.033 | 0.036 | 0.035 | 0.034 |
| 12 | 0.034 | 0.033 | 0.032 | 0.034 | 0.034 | 0.033 |

TABLE A103.3.1(8)
2 x 8 Single Stud: R-25 Batt

NOTE:
 Nominal Batt R-value:
 R-25 at 8 inch thickness

Installed Batt R-value:
 R-23.6 in 7.25 inch cavity

| R-value of Foam Board | Siding Material/Framing Type | | | | | |
|--------------------------|------------------------------|-------|-------|-------|-------|-------|
| | Lapped Wood | | | T1-11 | | |
| | STD | INT | ADV | STD | INT | ADV |
| 0 | 0.051 | 0.047 | 0.045 | 0.053 | 0.049 | 0.046 |
| 1 | 0.048 | 0.045 | 0.043 | 0.049 | 0.046 | 0.044 |
| 2 | 0.045 | 0.043 | 0.041 | 0.047 | 0.044 | 0.042 |
| 3 | 0.043 | 0.041 | 0.039 | 0.044 | 0.042 | 0.040 |
| 4 | 0.041 | 0.039 | 0.037 | 0.042 | 0.040 | 0.038 |
| 5 | 0.039 | 0.037 | 0.036 | 0.040 | 0.038 | 0.037 |
| 6 | 0.037 | 0.036 | 0.035 | 0.038 | 0.037 | 0.036 |
| 7 | 0.036 | 0.035 | 0.033 | 0.037 | 0.035 | 0.034 |
| 8 | 0.035 | 0.033 | 0.032 | 0.035 | 0.034 | 0.033 |
| 9 | 0.033 | 0.032 | 0.031 | 0.034 | 0.033 | 0.032 |
| 10 | 0.032 | 0.031 | 0.030 | 0.033 | 0.032 | 0.031 |
| 11 | 0.031 | 0.030 | 0.029 | 0.032 | 0.031 | 0.030 |
| 12 | 0.030 | 0.029 | 0.028 | 0.031 | 0.030 | 0.029 |

A103.3.2 Strap wall. Table A103.3.2: Assumes 2 x 6 studs framed on 16 or 24 inch centers. 2 x 3 or 2 x 4 strapping is run horizontally along the interior surface of the wall to provide additional space for insulation.

A103.3.3 Double stud wall. Tables A103.3.3(1) and A103.3.3(2): Assumes an exterior structural wall and a separate interior, nonstructural wall.

Insulation is placed in both wall cavities and in the space between the two walls. Stud spacing is assumed to be on 24 inch centers for both walls.

A103.3.4 Log wall. See Table A103.3.4.

A103.3.5 Stress-skin panel. See Table A103.3.5.

**TABLE A103.3.2
2 X 6: STRAP WALL**

| | Siding Material/Frame Type | | | |
|-------------------|----------------------------|-------|-------|-------|
| | Lapped Wood | | T1-11 | |
| | STD | ADV | STD | ADV |
| R-19 + R-11 Batts | 0.036 | 0.035 | 0.038 | 0.036 |
| R-19 + R-8 Batts | 0.041 | 0.039 | 0.042 | 0.040 |

**TABLE A103.3.3(1)
2 X 6 + 2 X 4: DOUBLE WOOD STUD**

| Batt Configuration | | | Siding Material/Frame Type | | | |
|--------------------|--------|----------|----------------------------|-------|-------|-------|
| | | | Lapped Wood | | T1-11 | |
| Exterior | Middle | Interior | STD | ADV | STD | ADV |
| R-19 | -- | R-11 | 0.040 | 0.037 | 0.041 | 0.038 |
| R-19 | -- | R-19 | 0.034 | 0.031 | 0.035 | 0.032 |
| R-19 | R-8 | R-11 | 0.029 | 0.028 | 0.031 | 0.029 |
| R-19 | R-11 | R-11 | 0.027 | 0.026 | 0.028 | 0.027 |
| R-19 | R-11 | R-19 | 0.024 | 0.023 | 0.025 | 0.023 |
| R-19 | R-19 | R-19 | 0.021 | 0.020 | 0.021 | 0.020 |

**TABLE A103.3.3(2)
2 X 4 + 2 X 4: DOUBLE WOOD STUD**

| Batt Configuration | | | Siding Material/Frame Type | | | |
|--------------------|--------|----------|----------------------------|-------|-------|-------|
| | | | Lapped Wood | | T1-11 | |
| Exterior | Middle | Interior | STD | ADV | STD | ADV |
| R-11 | -- | R-11 | 0.050 | 0.046 | 0.052 | 0.048 |
| R-19 | -- | R-11 | 0.039 | 0.037 | 0.043 | 0.039 |
| R-11 | R-8 | R-11 | 0.037 | 0.035 | 0.036 | 0.036 |
| R-11 | R-11 | R-11 | 0.032 | 0.031 | 0.033 | 0.032 |
| R-13 | R-13 | R-13 | 0.029 | 0.028 | 0.029 | 0.028 |
| R-11 | R-19 | R-11 | 0.026 | 0.026 | 0.027 | 0.026 |

**TABLE A103.3.4
LOG WALLS**

| Average Log Diameter, Inches | U-factor |
|------------------------------|----------|
| 6 | 0.148 |
| 8 | 0.111 |
| 10 | 0.089 |
| 12 | 0.074 |
| 14 | 0.063 |
| 16 | 0.056 |

NOTE:

R-value of wood:
R-1.25 per inch
thickness

Average wall
thickness
90% average log
diameter

**TABLE A103.3.5
STRESS SKIN PANEL**

| Panel Thickness, Inches | U-factor |
|-------------------------|----------|
| 3 1/2 | 0.071 |
| 5 1/2 | 0.048 |
| 7 1/4 | 0.037 |
| 9 1/4 | 0.030 |
| 11 1/4 | 0.025 |

NOTE:

R-value of expanded
polystyrene: R-3.85
per inch

Framing: 6%

Spline: 8%

No thermal bridging between interior and exterior splines

A103.3.6 Metal stud walls. The nominal R-values in Tables A103.3.6.1 through A103.3.6.3 may be used for purposes of calculating metal stud wall section U-factors in lieu of the ASHRAE zone calculation method as provided in Chapter 27 of the ASHRAE Fundamentals Handbook.

A103.3.6.1 Metal stud wall, overall assembly

U-factors. Tables A103.3.6.1(1) and A103.3.6.1(2): Assumes metal studs spaced on 16 or 24 inch centers with insulation installed to fill wall cavities. Continuous rigid board insulation is applied without creating uninsulated voids in the wall assembly.

A103.3.6.2 Metal stud wall, effective R-values for metal framing and cavity only.

Table A103.3.6.2: These values may be used for the metal-framing/cavity layers in walls with metal studs spaced on 16- or 24-inch centers with insulation installed to fill wall cavities in lieu of using the zone method provided in Chapter 25 of the ASHRAE Fundamentals Handbook.

A103.3.6.3 Metal building wall.

Table A103.3.6.3: A wall whose structure consists of metal spanning panels supported by steel structural members (does not include spandrel glass or metal panels in curtain wall systems). The first nominal R-value is for insulation compressed between metal wall panels and the steel structure. For double-layer installations, the second rated R-value of insulation is for insulation installed from the inside, covering the girts. For continuous insulation (e.g., insulation boards) it is assumed that the insulation boards are installed on the inside of the girts and

uninterrupted by the framing members. Insulation exposed to the conditioned space or semi-heated space shall have a facing, and all insulation seams shall be continuously sealed to provide a continuous air barrier.

A103.3.7 Concrete and masonry walls.

A103.3.7.1 Concrete masonry walls. The nominal R-values in Tables A103.3.7.1(1) and A103.3.7.1(2) may be used for purposes of calculating concrete masonry wall section U-factors in lieu of the ASHRAE isothermal planes calculation method as provided in Chapter 27 of the ASHRAE Fundamentals Handbook

A103.3.7.2 Peripheral edges of intermediate concrete floors. See Table A103.3.7.2.

TABLE A103.3.6.1(1)
OVERALL ASSEMBLY U-FACTORS
FOR METAL STUD WALLS WITH CONTINUOUS INSULATION

| Metal Framing | R-Value of Continuous Foam Board Insulation | Cavity Insulation | | | | | |
|---------------|---|-------------------|-------|-------|-------|-------|-------|
| | | R-0 | R-11 | R-13 | R-15 | R-19 | R-21 |
| 16" o.c. | R-0 (none) | 0.352 | 0.132 | 0.124 | 0.118 | 0.109 | 0.106 |
| | R-1 | 0.260 | 0.117 | 0.111 | 0.106 | 0.099 | 0.096 |
| | R-2 | 0.207 | 0.105 | 0.100 | 0.096 | 0.090 | 0.087 |
| | R-3 | 0.171 | 0.095 | 0.091 | 0.087 | 0.082 | 0.080 |
| | R-4 | 0.146 | 0.087 | 0.083 | 0.080 | 0.076 | 0.074 |
| | R-5 | 0.128 | 0.080 | 0.077 | 0.074 | 0.071 | 0.069 |
| | R-6 | 0.113 | 0.074 | 0.071 | 0.069 | 0.066 | 0.065 |
| | R-7 | 0.102 | 0.069 | 0.066 | 0.065 | 0.062 | 0.061 |
| | R-8 | 0.092 | 0.064 | 0.062 | 0.061 | 0.058 | 0.057 |
| | R-9 | 0.084 | 0.060 | 0.059 | 0.057 | 0.055 | 0.054 |
| | R-10 | 0.078 | 0.057 | 0.055 | 0.054 | 0.052 | 0.051 |
| | R-11 | 0.072 | 0.054 | 0.052 | 0.051 | 0.050 | 0.049 |
| | R-12 | 0.067 | 0.051 | 0.050 | 0.049 | 0.047 | 0.047 |
| | R-13 | 0.063 | 0.049 | 0.048 | 0.047 | 0.045 | 0.045 |
| | R-14 | 0.059 | 0.046 | 0.045 | 0.045 | 0.043 | 0.043 |
| | R-15 | 0.056 | 0.044 | 0.043 | 0.043 | 0.041 | 0.041 |
| | R-20 | 0.044 | 0.036 | 0.036 | 0.035 | 0.034 | 0.034 |
| 24" o.c. | R-0 (none) | 0.338 | 0.116 | 0.108 | 0.102 | 0.094 | 0.090 |
| | R-1 | 0.253 | 0.104 | 0.098 | 0.092 | 0.086 | 0.083 |
| | R-2 | 0.202 | 0.094 | 0.089 | 0.084 | 0.079 | 0.077 |
| | R-3 | 0.168 | 0.086 | 0.082 | 0.078 | 0.073 | 0.071 |
| | R-4 | 0.144 | 0.079 | 0.075 | 0.072 | 0.068 | 0.066 |
| | R-5 | 0.126 | 0.073 | 0.070 | 0.067 | 0.064 | 0.062 |
| | R-6 | 0.112 | 0.068 | 0.066 | 0.063 | 0.060 | 0.059 |
| | R-7 | 0.100 | 0.064 | 0.062 | 0.059 | 0.057 | 0.055 |
| | R-8 | 0.091 | 0.060 | 0.058 | 0.056 | 0.054 | 0.052 |
| | R-9 | 0.084 | 0.057 | 0.055 | 0.053 | 0.051 | 0.050 |
| | R-10 | 0.077 | 0.054 | 0.052 | 0.050 | 0.048 | 0.048 |
| | R-11 | 0.072 | 0.051 | 0.049 | 0.048 | 0.046 | 0.045 |
| | R-12 | 0.067 | 0.048 | 0.047 | 0.046 | 0.044 | 0.043 |
| | R-13 | 0.063 | 0.046 | 0.045 | 0.044 | 0.042 | 0.042 |
| | R-14 | 0.059 | 0.044 | 0.043 | 0.042 | 0.041 | 0.040 |
| R-15 | 0.056 | 0.042 | 0.041 | 0.040 | 0.039 | 0.038 | |
| R-20 | 0.044 | 0.035 | 0.034 | 0.034 | 0.033 | 0.032 | |

Continuous foam board insulation: Continuous insulation assumes no thermal bridging of insulation by framing or z-furring through applied foam board. Zone calculation method as provided in the ASHRAE Fundamentals Handbook must be used for thermally bridged foam board insulation. Values for attachment of insulation with z-furring are given in Table A103.3.6.1(2).

TABLE A105.3.6.1(2)
OVERALL ASSEMBLY U-FACTORS FOR METAL STUD WALLS
WITH INSULATION SUPPORTED BY Z-FURRING

| Metal Framing | R-value of Foam Board Insulation | Z-furring Attachment | Cavity Insulation | | | | | |
|---------------|----------------------------------|----------------------|-------------------|-------|-------|-------|-------|-------|
| | | | R-0 | R-11 | R-13 | R-15 | R-19 | R-21 |
| 16" o.c. | R-0 (none) | Horizontal | 0.352 | 0.132 | 0.124 | 0.118 | 0.109 | 0.106 |
| | R-5 | Horizontal | 0.155 | 0.089 | 0.086 | 0.083 | 0.078 | 0.077 |
| | R-7.5 | Horizontal | 0.128 | 0.080 | 0.077 | 0.074 | 0.071 | 0.069 |
| | R-10 | Horizontal | 0.110 | 0.072 | 0.070 | 0.068 | 0.065 | 0.064 |
| | R-12.5 | Horizontal | 0.099 | 0.068 | 0.065 | 0.064 | 0.061 | 0.060 |
| | R-15 | Horizontal | 0.091 | 0.064 | 0.062 | 0.060 | 0.058 | 0.057 |
| | R-17.5 | Horizontal | 0.084 | 0.060 | 0.058 | 0.057 | 0.055 | 0.054 |
| | R-20 | Horizontal | 0.078 | 0.057 | 0.056 | 0.054 | 0.052 | 0.052 |
| | R-22.5 | Horizontal | 0.074 | 0.055 | 0.054 | 0.052 | 0.051 | 0.050 |
| | R-25 | Horizontal | 0.071 | 0.053 | 0.052 | 0.051 | 0.049 | 0.048 |
| | R-0 (none) | Vertical | 0.352 | 0.132 | 0.124 | 0.118 | 0.109 | 0.106 |
| | R-5 | Vertical | 0.165 | 0.093 | 0.089 | 0.086 | 0.081 | 0.079 |
| | R-7.5 | Vertical | 0.142 | 0.085 | 0.081 | 0.079 | 0.075 | 0.073 |
| | R-10 | Vertical | 0.126 | 0.079 | 0.076 | 0.074 | 0.070 | 0.069 |
| | R-12.5 | Vertical | 0.115 | 0.074 | 0.072 | 0.070 | 0.066 | 0.065 |
| | R-15 | Vertical | 0.107 | 0.071 | 0.069 | 0.067 | 0.064 | 0.063 |
| | R-17.5 | Vertical | 0.100 | 0.068 | 0.065 | 0.064 | 0.061 | 0.060 |
| | R-20 | Vertical | 0.094 | 0.065 | 0.063 | 0.061 | 0.059 | 0.058 |
| R-22.5 | Vertical | 0.090 | 0.063 | 0.061 | 0.060 | 0.057 | 0.056 | |
| R-25 | Vertical | 0.086 | 0.061 | 0.059 | 0.058 | 0.056 | 0.055 | |
| 24" o.c. | R-0 (none) | Horizontal | 0.338 | 0.116 | 0.108 | 0.102 | 0.094 | 0.09 |
| | R-5 | Horizontal | 0.152 | 0.082 | 0.078 | 0.074 | 0.070 | 0.068 |
| | R-7.5 | Horizontal | 0.126 | 0.074 | 0.070 | 0.068 | 0.064 | 0.062 |
| | R-10 | Horizontal | 0.109 | 0.067 | 0.065 | 0.062 | 0.059 | 0.058 |
| | R-12.5 | Horizontal | 0.098 | 0.063 | 0.061 | 0.059 | 0.056 | 0.055 |
| | R-15 | Horizontal | 0.090 | 0.060 | 0.058 | 0.056 | 0.053 | 0.052 |
| | R-17.5 | Horizontal | 0.083 | 0.057 | 0.055 | 0.053 | 0.051 | 0.050 |
| | R-20 | Horizontal | 0.078 | 0.054 | 0.052 | 0.051 | 0.049 | 0.048 |
| | R-22.5 | Horizontal | 0.074 | 0.052 | 0.050 | 0.049 | 0.047 | 0.046 |
| | R-25 | Horizontal | 0.070 | 0.050 | 0.049 | 0.047 | 0.046 | 0.045 |
| | R-0 (none) | Vertical | 0.338 | 0.116 | 0.108 | 0.102 | 0.094 | 0.09 |
| | R-5 | Vertical | 0.162 | 0.084 | 0.080 | 0.077 | 0.072 | 0.070 |
| | R-7.5 | Vertical | 0.140 | 0.078 | 0.074 | 0.071 | 0.067 | 0.065 |
| | R-10 | Vertical | 0.124 | 0.073 | 0.070 | 0.067 | 0.063 | 0.062 |
| | R-12.5 | Vertical | 0.113 | 0.069 | 0.066 | 0.064 | 0.061 | 0.059 |
| | R-15 | Vertical | 0.106 | 0.066 | 0.063 | 0.061 | 0.058 | 0.057 |
| | R-17.5 | Vertical | 0.098 | 0.063 | 0.061 | 0.059 | 0.056 | 0.055 |
| | R-20 | Vertical | 0.093 | 0.061 | 0.059 | 0.057 | 0.054 | 0.053 |
| R-22.5 | Vertical | 0.089 | 0.059 | 0.057 | 0.055 | 0.053 | 0.051 | |
| R-25 | Vertical | 0.085 | 0.057 | 0.055 | 0.054 | 0.051 | 0.050 | |

Values in Table A105.3.6.1(2) may not be interpolated between. The value of the foam board insulation must meet or exceed the value listed in the table in order to use the value shown.

**TABLE A103.3.6.2
EFFECTIVE R-VALUES FOR METAL FRAMING AND CAVITY ONLY**

| | Cavity | | Insulation | | |
|-------------------|-----------------------|----------------------------|-----------------|-------------------|----------|
| | Nominal Depth, Inches | Actual Depth, Inches | Nominal R-Value | Effective R-Value | |
| | | | | 16" O.C. | 24" O.C. |
| Air Cavity | Any | Any | R-0.91 (air) | 0.79 | 0.91 |
| Wall | 4 | 3-1/2 | R-11 | 5.5 | 6.6 |
| | 4 | 3-1/2 | R-13 | 6.0 | 7.2 |
| | 4 | 3-1/2 | R-15 | 6.4 | 7.8 |
| | 6 | 5-1/2 | R-19 | 7.1 | 8.6 |
| | 6 | 5-1/2 | R-21 | 7.4 | 9.0 |
| | 8 | 7-1/4 | R-25 | 7.8 | 9.6 |
| Roof | | Insulation is uncompressed | R-11 | 5.5 | 6.1 |
| | | | R-19 | 7.0 | 9.1 |
| | | | R-30 | 9.3 | 11.4 |

**TABLE A103.3.6.3
DEFAULT METAL BUILDING WALL U-FACTORS**

| Insulation System | Rated R-Value of Insulation | Overall U-Factor for Entire Base Wall Assembly | Overall U-Factor for Assembly of Base Wall Plus Continuous Insulation (Uninterrupted by Framing) | | | | | |
|--------------------------------------|-----------------------------|--|--|-------|--------|-------|--------|-------|
| | | | R-6.5 | R-13 | R-19.5 | R-26 | R-32.5 | R-39 |
| Single Layer of Mineral Fiber | | | | | | | | |
| | None | 1.180 | 0.136 | 0.072 | 0.049 | 0.037 | 0.030 | 0.025 |
| | R-10 | 0.186 | 0.084 | 0.054 | 0.040 | 0.032 | 0.026 | 0.023 |
| | R-11 | 0.185 | 0.084 | 0.054 | 0.040 | 0.032 | 0.026 | 0.023 |
| | R-13 | 0.162 | 0.079 | 0.052 | 0.039 | 0.031 | 0.026 | 0.022 |
| | R-16 | 0.155 | 0.077 | 0.051 | 0.039 | 0.031 | 0.026 | 0.022 |
| | R-19 | 0.147 | 0.075 | 0.050 | 0.038 | 0.030 | 0.025 | 0.022 |

**TABLE A103.3.7.1(1)
DEFAULT U-FACTORS FOR CONCRETE AND MASONRY WALLS**

8" Concrete Masonry

| WALL DESCRIPTION | CORE TREATMENT | | | |
|---|------------------------------------|----------------------|-------------|-------------|
| | Partial Grout with UngROUTED Cores | | | Solid Grout |
| | Empty | Loose-fill insulated | | |
| | | Perlite | Vermiculite | |
| Exposed Block, Both Sides | 0.40 | 0.23 | 0.24 | 0.43 |
| R-5 Interior Insulation, Wood Furring | 0.14 | 0.11 | 0.12 | 0.15 |
| R-6 Interior Insulation, Wood Furring | 0.14 | 0.11 | 0.11 | 0.14 |
| R-10.5 Interior Insulation, Wood Furring | 0.11 | 0.09 | 0.09 | 0.11 |
| R-8 Interior Insulation, Metal Clips | 0.11 | 0.09 | 0.09 | 0.11 |
| R-6 Exterior Insulation | 0.12 | 0.10 | 0.10 | 0.12 |
| R-10 Exterior Insulation | 0.08 | 0.07 | 0.07 | 0.08 |
| R-9.5 Rigid Polystyrene Integral Insulation, Two Webbed Block | 0.11 | 0.09 | 0.09 | 0.12 |

**TABLE A103.3.7.1(1) – continued
DEFAULT U-FACTORS FOR CONCRETE AND MASONRY WALLS**

12" Concrete Masonry

| WALL DESCRIPTION | CORE TREATMENT | | | |
|---|------------------------------------|----------------------|------|-------------|
| | Partial Grout with UngROUTED Cores | | | Solid Grout |
| | Empty | Loose-fill insulated | | |
| Perlite | | Vermiculite | | |
| Exposed Block, Both Sides | 0.35 | 0.17 | 0.18 | 0.33 |
| R-5 Interior Insulation, Wood Furring | 0.14 | 0.10 | 0.10 | 0.13 |
| R-6 Interior Insulation, Wood Furring | 0.13 | 0.09 | 0.10 | 0.13 |
| R-10.5 Interior Insulation, Wood Furring | 0.11 | 0.08 | 0.08 | 0.10 |
| R-8 Interior Insulation, Metal Clips | 0.10 | 0.08 | 0.08 | 0.09 |
| R-6 Exterior Insulation | 0.11 | 0.09 | 0.09 | 0.11 |
| R-10 Exterior Insulation | 0.08 | 0.06 | 0.06 | 0.08 |
| R-9.5 Rigid Polystyrene Integral Insulation, Two Webbed Block | 0.11 | 0.08 | 0.09 | 0.12 |

8" Clay Brick

| WALL DESCRIPTION | CORE TREATMENT | | | |
|--|------------------------------------|----------------------|------|-------------|
| | Partial Grout with UngROUTED Cores | | | Solid Grout |
| | Empty | Loose-fill insulated | | |
| Perlite | | Vermiculite | | |
| Exposed Block, Both Sides | 0.50 | 0.31 | 0.32 | 0.56 |
| R-5 Interior Insulation, Wood Furring | 0.15 | 0.13 | 0.13 | 0.16 |
| R-6 Interior Insulation, Wood Furring | 0.15 | 0.12 | 0.12 | 0.15 |
| R-10.5 Interior Insulation, Wood Furring | 0.12 | 0.10 | 0.10 | 0.12 |
| R-8 Interior Insulation, Metal Clips | 0.11 | 0.10 | 0.10 | 0.11 |
| R-6 Exterior Insulation | 0.12 | 0.11 | 0.11 | 0.13 |
| R-10 Exterior Insulation | 0.08 | 0.08 | 0.08 | 0.09 |

6" Concrete Poured or Precast

| WALL DESCRIPTION | CORE TREATMENT | | | |
|--|------------------------------------|----------------------|----|-------------|
| | Partial Grout with UngROUTED Cores | | | Solid Grout |
| | Empty | Loose-fill insulated | | |
| Perlite | | Vermiculite | | |
| Exposed Concrete, Both Sides | NA | NA | NA | 0.61 |
| R-5 Interior Insulation, Wood Furring | NA | NA | NA | 0.16 |
| R-6 Interior Insulation, Wood Furring | NA | NA | NA | 0.15 |
| R-10.5 Interior Insulation, Wood Furring | NA | NA | NA | 0.12 |
| R-8 Interior Insulation, Metal Clips | NA | NA | NA | 0.12 |
| R-6 Exterior Insulation | NA | NA | NA | 0.13 |
| R-10 Exterior Insulation | NA | NA | NA | 0.09 |

1. Grouted cores at 40" x 48" on center vertically and horizontally in partial grouted walls.
2. Interior insulation values include 1/2" gypsum board on the inner surface.
3. Furring and stud spacing is 16" on center. Insulation is assumed to fill furring space and is not compressed.
4. Intermediate values may be interpolated using this table. Values not contained in this table may be computed using the procedures listed in the ASHRAE Fundamentals Handbook.
5. Concrete Masonry Unit (CMU) assembly U-values are based on local test data for Washington state CMU block material using the ASTM C-236-87 steady state thermal conductance test. Tests included an 8"x8"x16" CMU with all cells filled with vermiculite (1995) and 8"x8"x16" CMU with all cells filled with polymaster foam in place insulation (1996). Refer to ASHRAE Standard 90.1 for additional nationally recognized data on the thermal performance of CMU block walls.

TABLE A103.3.7.1(2)
DEFAULT U-FACTORS FOR CONCRETE AND MASONRY WALLS

| Framing Type and Depth | Rated R-Value of Insulation Alone | Assembly U-Factors for Solid Concrete Walls | Assembly U-Factors for Concrete Block Walls: Solid Grouted | Assembly U-Factors for Concrete Block Walls: Partially Grouted (cores uninsulated except where specified) |
|--|---|--|---|--|
| Base Wall only | | | | |
| No Framing | R-0 | U-0.740 | U-0.580 | U-0.480 |
| | UngROUTED Cores Filled with Loose-Fill Insulation | N.A. | N.A. | U-0.350 |
| Continuous Wood Framing | | | | |
| 0.75 in. | R-3.0 | U-0.247 | U-0.226 | U-0.210 |
| 1.5 in. | R-6.0 | U-0.160 | U-0.151 | U-0.143 |
| 2.0 in. | R-10.0 | U-0.116 | U-0.111 | U-0.107 |
| 3.5 in. | R-11.0 | U-0.094 | U-0.091 | U-0.088 |
| 3.5 in. | R-13.0 | U-0.085 | U-0.083 | U-0.080 |
| 3.5 in. | R-15.0 | U-0.079 | U-0.077 | U-0.075 |
| 5.5 in. | R-19.0 | U-0.060 | U-0.059 | U-0.058 |
| 5.5 in. | R-21.0 | U-0.057 | U-0.055 | U-0.054 |
| Continuous Metal Framing at 24 in. on center horizontally | | | | |
| 1.0 in. | R-0.0 | U-0.414 | U-0.359 | U-0.318 |
| 1.0 in. | R-3.8 | U-0.325 | U-0.290 | U-0.263 |
| 1.0 in. | R-5.0 | U-0.314 | U-0.281 | U-0.255 |
| 1.0 in. | R-6.5 | U-0.305 | U-0.274 | U-0.249 |
| 1.5 in. | R-11.0 | U-0.267 | U-0.243 | U-0.223 |
| 2.0 in. | R-7.6 | U-0.230 | U-0.212 | U-0.197 |
| 2.0 in. | R-10.0 | U-0.219 | U-0.202 | U-0.188 |
| 2.0 in. | R-13.0 | U-0.210 | U-0.195 | U-0.182 |
| 3.0 in. | R-11.4 | U-0.178 | U-0.167 | U-0.157 |
| 3.0 in. | R-15.0 | U-0.168 | U-0.158 | U-0.149 |
| 3.0 in. | R-19.0 | U-0.161 | U-0.152 | U-0.144 |
| 3.5 in. | R-11.0 | U-0.168 | U-0.158 | U-0.149 |
| 3.5 in. | R-13.0 | U-0.161 | U-0.152 | U-0.144 |
| 3.5 in. | R-15.0 | U-0.155 | U-0.147 | U-0.140 |
| 4.5 in. | R-17.1 | U-0.133 | U-0.126 | U-0.121 |
| 4.5 in. | R-22.5 | U-0.124 | U-0.119 | U-0.114 |
| 4.5 in. | R-25.2 | U-0.122 | U-0.116 | U-0.112 |
| 5.0 in. | R-19.0 | U-0.122 | U-0.117 | U-0.112 |
| 5.0 in. | R-25.0 | U-0.115 | U-0.110 | U-0.106 |
| 5.0 in. | R-28.0 | U-0.112 | U-0.107 | U-0.103 |
| 5.0 in. | R-32.0 | U-0.109 | U-0.105 | U-0.101 |
| 5.5 in. | R-19.0 | U-0.118 | U-0.113 | U-0.109 |
| 5.5 in. | R-20.9 | U-0.114 | U-0.109 | U-0.105 |
| 5.5 in. | R-21.0 | U-0.113 | U-0.109 | U-0.105 |
| 5.5 in. | R-27.5 | U-0.106 | U-0.102 | U-0.099 |
| 5.5 in. | R-30.8 | U-0.104 | U-0.100 | U-0.096 |

TABLE A103.3.7.1(2) – continued
DEFAULT U-FACTORS FOR CONCRETE AND MASONRY WALLS

| Framing Type and Depth | Rated R-Value of Insulation Alone | Assembly U-Factors for Solid Concrete Walls | Assembly U-Factors for Concrete Block Walls: Solid Grouted | Assembly U-Factors for Concrete Block Walls: Partially Grouted (cores uninsulated except where specified) |
|---|--|--|---|--|
| 6.0 in. | R-22.8 | U-0.106 | U-0.102 | U-0.098 |
| 6.0 in. | R-30.0 | U-0.099 | U-0.095 | U-0.092 |
| 6.0 in. | R-33.6 | U-0.096 | U-0.093 | U-0.090 |
| 6.5 in. | R-24.7 | U-0.099 | U-0.096 | U-0.092 |
| 7.0 in. | R-26.6 | U-0.093 | U-0.090 | U-0.087 |
| 7.5 in. | R-28.5 | U-0.088 | U-0.085 | U-0.083 |
| 8.0 in. | R-30.4 | U-0.083 | U-0.081 | U-0.079 |
| 1 in Metal Clips at 24 in. on center horizontally and 16 in. vertically (also, where allowed by Section 1332, for assemblies with a ratio of metal penetration area/ mass wall area of <0.0004 or <0.04% of the mass wall area) ⁵ | | | | |
| 1.0 in. | R-3.8 | U-0.210 | U-0.195 | U-0.182 |
| 1.0 in. | R-5.0 | U-0.184 | U-0.172 | U-0.162 |
| 1.0 in. | R-5.6 | U-0.174 | U-0.163 | U-0.154 |
| 1.5 in. | R-5.7 | U-0.160 | U-0.151 | U-0.143 |
| 1.5 in. | R-7.5 | U-0.138 | U-0.131 | U-0.125 |
| 1.5 in. | R-8.4 | U-0.129 | U-0.123 | U-0.118 |
| 2.0 in. | R-7.6 | U-0.129 | U-0.123 | U-0.118 |
| 2.0 in. | R-10.0 | U-0.110 | U-0.106 | U-0.102 |
| 2.0 in. | R-11.2 | U-0.103 | U-0.099 | U-0.096 |
| 2.5 in. | R-9.5 | U-0.109 | U-0.104 | U-0.101 |
| 2.5 in. | R-12.5 | U-0.092 | U-0.089 | U-0.086 |
| 2.5 in. | R-14.0 | U-0.086 | U-0.083 | U-0.080 |
| 3.0 in. | R-11.4 | U-0.094 | U-0.090 | U-0.088 |
| 3.0 in. | R-15.0 | U-0.078 | U-0.076 | U-0.074 |
| 3.0 in. | R-16.8 | U-0.073 | U-0.071 | U-0.069 |
| 3.5 in. | R-13.3 | U-0.082 | U-0.080 | U-0.077 |
| 3.5 in. | R-17.5 | U-0.069 | U-0.067 | U-0.065 |
| 3.5 in. | R-19.6 | U-0.064 | U-0.062 | U-0.061 |
| 4.0 in. | R-15.2 | U-0.073 | U-0.071 | U-0.070 |
| 4.0 in. | R-20.0 | U-0.061 | U-0.060 | U-0.058 |
| 4.0 in. | R-22.4 | U-0.057 | U-0.056 | U-0.054 |
| 5.0 in. | R-28.0 | U-0.046 | U-0.046 | U-0.045 |
| 6.0 in. | R-33.6 | U-0.039 | U-0.039 | U-0.038 |
| 7.0 in. | R-39.2 | U-0.034 | U-0.034 | U-0.033 |
| 8.0 in. | R-44.8 | U-0.030 | U-0.030 | U-0.029 |
| 9.0 in. | R-50.4 | U-0.027 | U-0.027 | U-0.026 |
| 10.0 in. | R-56.0 | U-0.024 | U-0.024 | U-0.024 |
| 11.0 in. | R-61.6 | U-0.022 | U-0.022 | U-0.022 |

TABLE A103.3.7.1(2) – continued
DEFAULT U-FACTORS FOR CONCRETE AND MASONRY WALLS

| Framing Type and Depth | Rated R-Value of Insulation Alone | Assembly U-Factors for Solid Concrete Walls | Assembly U-Factors for Concrete Block Walls: Solid Grouted | Assembly U-Factors for Concrete Block Walls: Partially Grouted (cores uninsulated except where specified) |
|---|--|--|---|--|
| Continuous Insulation Uninterrupted by Framing | | | | |
| No Framing | R-1.0 | U-0.425 | U-0.367 | U-0.324 |
| | R-2.0 | U-0.298 | U-0.269 | U-0.245 |
| | R-3.0 | U-0.230 | U-0.212 | U-0.197 |
| | R-4.0 | U-0.187 | U-0.175 | U-0.164 |
| | R-5.0 | U-0.157 | U-0.149 | U-0.141 |
| No Framing | R-6.0 | U-0.136 | U-0.129 | U-0.124 |
| | R-7.0 | U-0.120 | U-0.115 | U-0.110 |
| | R-8.0 | U-0.107 | U-0.103 | U-0.099 |
| | R-9.0 | U-0.097 | U-0.093 | U-0.090 |
| | R-10.0 | U-0.088 | U-0.085 | U-0.083 |
| No Framing | R-11.0 | U-0.081 | U-0.079 | U-0.076 |
| | R-12.0 | U-0.075 | U-0.073 | U-0.071 |
| | R-13.0 | U-0.070 | U-0.068 | U-0.066 |
| | R-14.0 | U-0.065 | U-0.064 | U-0.062 |
| | R-15.0 | U-0.061 | U-0.060 | U-0.059 |
| No Framing | R-16.0 | U-0.058 | U-0.056 | U-0.055 |
| | R-17.0 | U-0.054 | U-0.053 | U-0.052 |
| | R-18.0 | U-0.052 | U-0.051 | U-0.050 |
| | R-19.0 | U-0.049 | U-0.048 | U-0.047 |
| | R-20.0 | U-0.047 | U-0.046 | U-0.045 |
| No Framing | R-21.0 | U-0.045 | U-0.044 | U-0.043 |
| | R-22.0 | U-0.043 | U-0.042 | U-0.042 |
| | R-3.0 | U-0.041 | U-0.040 | U-0.040 |
| | R-24.0 | U-0.039 | U-0.039 | U-0.038 |
| | R-25.0 | U-0.038 | U-0.037 | U-0.037 |
| No Framing | R-30.0 | U-0.032 | U-0.032 | U-0.031 |
| | R-35.0 | U-0.028 | U-0.027 | U-0.027 |
| | R-40.0 | U-0.024 | U-0.024 | U-0.024 |
| | R-45.0 | U-0.022 | U-0.021 | U-0.021 |
| | R-50.0 | U-0.019 | U-0.019 | U-0.019 |
| | R-55.0 | U-0.018 | U-0.018 | U-0.018 |
| | R-60.0 | U-0.016 | U-0.016 | U-0.016 |
| Brick cavity wall with continuous insulation | | | | |
| No Framing | R-0.0 | U-0.337 | U-0.299 | U-0.270 |
| No Framing | R-3.8 | U-0.148 | U-0.140 | U-0.133 |
| No Framing | R-5.0 | U-0.125 | U-0.120 | U-0.115 |
| No Framing | R-6.5 | U-0.106 | U-0.102 | U-0.098 |
| No Framing | R-7.6 | U-0.095 | U-0.091 | U-0.088 |
| No Framing | R-10.0 | U-0.077 | U-0.075 | U-0.073 |
| No Framing | R-10.5 | U-0.079 | U-0.077 | U-0.075 |
| No Framing | R-11.4 | U-0.070 | U-0.068 | U-0.066 |

TABLE A103.3.7.1(2) – continued
DEFAULT U-FACTORS FOR CONCRETE AND MASONRY WALLS

| Framing Type and Depth | Rated R-Value of Insulation Alone | Assembly U-Factors for Solid Concrete Walls | Assembly U-Factors for Concrete Block Walls: Solid Grouted | Assembly U-Factors for Concrete Block Walls: Partially Grouted (cores uninsulated except where specified) |
|--|-----------------------------------|---|--|---|
| No Framing | R-15.0 | U-0.056 | U-0.055 | U-0.053 |
| No Framing | R-16.5 | U-0.054 | U-0.053 | U-0.052 |
| No Framing | R-19.0 | U-0.046 | U-0.045 | U-0.044 |
| No Framing | R-22.5 | U-0.041 | U-0.040 | U-0.039 |
| No Framing | R-28.5 | U-0.033 | U-0.032 | U-0.032 |
| Continuous Insulation Uninterrupted by Framing with Stucco and Continuous Metal Framing at 24 in. on center horizontally | | | | |
| 1.0 in. | R-0.0 + R-19 c.i. | U-0.047 | U-0.046 | U-0.045 |
| 1.0 in. | R-3.8 + R-19 c.i. | U-0.045 | U-0.044 | U-0.044 |
| 1.0 in. | R-5.0 + R-19 c.i. | U-0.045 | U-0.044 | U-0.043 |
| 1.0 in. | R-6.5 + R-19 c.i. | U-0.045 | U-0.044 | U-0.043 |
| 1.5 in. | R-11.0 + R-19 c.i. | U-0.044 | U-0.043 | U-0.043 |
| 2.0 in. | R-7.6 + R-19 c.i. | U-0.043 | U-0.042 | U-0.041 |
| 2.0 in. | R-10.0 + R-19 c.i. | U-0.042 | U-0.041 | U-0.041 |
| 2.0 in. | R-13.0 + R-19 c.i. | U-0.042 | U-0.041 | U-0.041 |
| 3.0 in. | R-11.4 + R-19 c.i. | U-0.041 | U-0.040 | U-0.039 |
| 3.0 in. | R-15.0 + R-19 c.i. | U-0.040 | U-0.039 | U-0.039 |
| 3.0 in. | R-19.0 + R-19 c.i. | U-0.040 | U-0.039 | U-0.038 |
| 3.5 in. | R-11.0 + R-19 c.i. | U-0.040 | U-0.039 | U-0.039 |
| 3.5 in. | R-13.0 + R-19 c.i. | U-0.040 | U-0.039 | U-0.038 |
| 5.0 in. | R-19.0 + R-19 c.i. | U-0.037 | U-0.036 | U-0.036 |
| 5.0 in. | R-25.0 + R-19 c.i. | U-0.036 | U-0.035 | U-0.035 |
| 5.0 in. | R-32.5 + R-19 c.i. | U-0.035 | U-0.035 | U-0.034 |
| 5.5 in. | R-19.0 + R-19 c.i. | U-0.036 | U-0.036 | U-0.035 |
| 5.5 in. | R-21.0 + R-19 c.i. | U-0.035 | U-0.035 | U-0.035 |

Notes for Default Table A103.3.7.1(2):

- a. It is acceptable to use the U-factors in Table A103.3.7.1(2) for all concrete and masonry walls, provided that the grouting is equal to or less than that specified.
 - -For ungrouted walls, use the partially grouted column.
 - -For metal studs and z-furring, use the continuous-metal-framing category.
 - -For discontinuous metal clips 1 inch square or smaller, use the metal-clip category.
 - -For insulation that is attached without any framing members (e.g. glued), use the continuous-insulation uninterrupted-by-framing category. Continuous insulation may be installed on the interior or exterior of masonry walls, or between stand-alone walls in multilayer masonry walls, or on the interior or exterior of the concrete.
- b. For Table A103.3.7.1(2), the U-factor includes R-0.17 for exterior air film and R-0.68 for interior air film-vertical surfaces. For insulated walls, the U-factor also includes R-0.45 for 0.5 in. gypsum board. U-factors are provided for the following configurations:
 1. Concrete wall: 8-in. normal weight concrete wall with a density of 145 lb/ft³.
 2. Solid grouted concrete block wall: 8-in. medium weight ASTM C90 concrete block with a density of 115 lb/ft³ and solid grouted cores.
 3. Partially grouted concrete block wall: 8-in. medium weight ASTM C90 concrete block with a density of 115 lb/ft³ having reinforcing steel every 32 in. vertically and every 48 in. horizontally, with cores grouted in those areas only. Other cores are filled with insulating material only if there is no other insulation.
- c. For walls with insulation contained in a framing layer, the U-factors in Table A103.3.7.1(2) assume contact (and thermal bridging) between the mass wall and other framing. For wall assemblies with multiple layers where the wood or metal framing layer does not contact the concrete or masonry layer (i.e., walls with an airspace between the stud wall layer and the mass wall layer), it is acceptable to use the appropriate wood or metal frame wall default U-factors in Tables A103.3.1 or A103.3.6.1. Note: It is acceptable to use this approach where the insulation extends beyond the framing and is in contact with the mass wall layer (e.g. a nominal four-inch metal stud containing insulation that is nominally six inches thick and therefore extends two inches beyond the back of the metal stud).
- d. Except for wall assemblies qualifying for note 3, if not taken from Table A103.3.7.1(2), mass wall U-factors shall be determined in accordance with ASHRAE 90.1, Appendix A, Section A3.1 and Tables A3.1A to A3.1D, or Section A9.4.

**TABLE A103.3.7.2
DEFAULT U-FACTORS FOR PERIPHERAL EDGES OF INTERMEDIATE CONCRETE FLOORS**

| Slab Edge Treatment | Average Thickness of Wall Above and Below | | | |
|--------------------------|---|----------|-----------|-----------|
| | 6 inches | 8 inches | 10 inches | 12 inches |
| Exposed Concrete | 0.816 | 0.741 | 0.678 | 0.625 |
| R-5 Exterior Insulation | 0.161 | 0.157 | 0.154 | 0.152 |
| R-6 Exterior Insulation | 0.138 | 0.136 | 0.134 | 0.132 |
| R-7 Exterior Insulation | 0.122 | 0.120 | 0.118 | 0.116 |
| R-8 Exterior Insulation | 0.108 | 0.107 | 0.106 | 0.104 |
| R-9 Exterior Insulation | 0.098 | 0.097 | 0.095 | 0.094 |
| R-10 Exterior Insulation | 0.089 | 0.088 | 0.087 | 0.086 |
| R-11 Exterior Insulation | 0.082 | 0.081 | 0.080 | 0.079 |
| R-12 Exterior Insulation | 0.076 | 0.075 | 0.074 | 0.074 |
| R-13 Exterior Insulation | 0.070 | 0.070 | 0.069 | 0.068 |
| R-14 Exterior Insulation | 0.066 | 0.065 | 0.065 | 0.064 |
| R-15 Exterior Insulation | 0.062 | 0.061 | 0.061 | 0.060 |

Notes for Table A103.3.7.2:

- a. Exterior insulation values listed above are continuous R-values on the exterior side of the concrete floor.
- b. For conditions with an exterior wall above the peripheral edge of intermediate concrete floor but with no wall below the intermediate concrete floor this table may be used as long as the code minimum insulation is applied to the floor slab below the concrete floor.
- c. Typical conditions where conditioned space building envelope wall thermal insulation values are broken concrete floors include, but are not limited to, the following examples:
 1. Elevator hoistway shafts that serve the conditioned building and pass through unconditioned floors such as parking garage levels;
 2. Stairwell enclosures that serve the conditioned building and pass through unconditioned floors such as parking garage levels;
 3. Walls between interior and exterior building envelope that separate the interior conditioned space from an exterior courtyard or roofdeck;
 4. Walls between interior and exterior building envelope that separate the interior conditioned space from an exterior unconditioned space on parking garage levels.

**SECTION A104
BELOW-GRADE WALLS AND SLABS**

A104.1 General. Table A104.1 lists heat loss coefficients for below-grade walls and floors.

Coefficients for below-grade walls are given as U-factors ($\text{Btu/h} \times \text{ft}^2 \times ^\circ\text{F}$ of wall area). Coefficients for below-grade slabs are listed as F-factors ($\text{Btu/h} \times \text{ft} \times ^\circ\text{F}$ per lineal foot of slab perimeter).

Below-grade wall U-factors are only valid when used with the accompanying below-grade slab F-factor, and vice versa.

A104.2 Component description. All below-grade walls are assumed to be 8 inch concrete. The wall is assumed to extend from the slab upward to the top of the mud sill for the distance specified in Table A104.1, with 6 inches of concrete wall extending above grade.

Interior insulation is assumed to be fiberglass batts placed in the cavity formed by 2 x 4 framing on 24 inch centers with 1/2 inch gypsum board as the interior finish material. Exterior insulation is assumed to be applied directly to the exterior of the below-grade wall from the top of the wall to the footing. The exterior case does not assume any interior framing or sheetrock.

In all cases, the entire wall surface is assumed to be insulated to the indicated nominal level with the appropriate framing and insulation application. Coefficients are listed for wall depths of 2, 3-1/2 and 7 feet below grade. Basements shallower than two feet should use on-grade slab coefficients.

Heat-loss calculations for wall areas above-grade should use above-grade wall U-factors, beginning at the mudsill.

**TABLE A104.1
DEFAULT WALL U-FACTORS AND SLAB F-FACTORS FOR BASEMENTS**

| | Below Grade Wall U-factor | Below Grade Slab F-factor |
|-----------------------------------|------------------------------|------------------------------|
| 2 Foot Depth Below Grade | | |
| Uninsulated | 0.350 | 0.59 |
| R-11 Interior | 0.066 | 0.68 |
| R-11 Interior w/TB | 0.070 | 0.60 |
| R-19 Interior | 0.043 | 0.69 |
| R-19 Interior w/TB | 0.045 | 0.61 |
| R-10 Exterior | 0.070 | 0.60 |
| R-12 Exterior | 0.061 | 0.60 |
| 3.5 Foot Depth Below Grade | | |
| Uninsulated | 0.278 | 0.53 |
| R-11 Interior | 0.062 | 0.63 |
| R-11 Interior w/TB | 0.064 | 0.57 |
| R-19 Interior | 0.041 | 0.64 |
| R-19 Interior w/TB | 0.042 | 0.57 |
| R-10 Exterior | 0.064 | 0.57 |
| R-12 Exterior | 0.057 | 0.57 |
| 7 Foot Depth Below Grade | | |
| Uninsulated | 0.193 | 0.46 |
| R-11 Interior | 0.054 | 0.56 |
| R-11 Interior w/TB | 0.056 | 0.42 |
| R-19 Interior | 0.037 | 0.57 |
| R-19 Interior w/TB | 0.038 | 0.43 |
| R-10 Exterior | 0.056 | 0.42 |
| R-12 Exterior | 0.050 | 0.42 |

TB = Thermal Break

A104.3 Insulation description. Coefficients are listed for the following four configurations:

1. **Uninsulated:** No insulation or interior finish.
2. **Interior insulation:** Interior 2 x 4 insulated wall without a thermal break between concrete wall and slab.
3. **Interior insulation with thermal break:** Interior 2 x 4 insulated wall with R-5 rigid board providing a thermal break between the concrete wall and the slab.
4. **Exterior insulation:** Insulation applied directly to the exterior surface of the concrete wall.

**SECTION A105
FLOORS OVER UNCONDITIONED SPACE**

A105.1 General. Tables A105.1(1), A105.1(2) and A105.1(3) list heat loss coefficients for floors over unconditioned spaces in units of Btu/h × ft² × °F.

They are derived from procedures listed in the ASHRAE Fundamentals Handbook, assuming an average outdoor temperature of 45°F, an average indoor temperature of 65°F and a crawlspace area of 1350 ft² and 100 feet of perimeter. The crawlspace is assumed to be 2.5 feet high, with 24 inches below grade and 6 inches above grade.

**TABLE A105.1(1)
DEFAULT U-FACTORS FOR FLOORS OVER VENTED CRAWLSPACE
OR UNHEATED BASEMENT**

| Nominal R-Value | | U-Factor | |
|-----------------|-----------|-------------|--------|
| Floor | Perimeter | Post & Beam | Joists |
| 0 | 0 | 0.112 | 0.134 |
| | 11 | 0.100 | 0.116 |
| | 19 | 0.098 | 0.114 |
| | 30 | 0.093 | 0.107 |
| 11 | 0 | 0.052 | 0.056 |
| | 11 | 0.048 | 0.052 |
| 19 | 0 | 0.038 | 0.041 |
| | 11 | 0.036 | 0.038 |
| 22 | 0 | 0.034 | 0.037 |
| | 11 | 0.033 | 0.035 |
| 25 | 0 | 0.032 | 0.034 |
| | 11 | 0.031 | 0.033 |
| 30 | 0 | 0.028 | 0.029 |
| | 11 | 0.027 | 0.028 |
| 38 | 0 | 0.024 | 0.025 |
| | 11 | 0.024 | 0.024 |

**TABLE A105.1(2)
DEFAULT U-FACTORS FOR FLOORS OVER HEATED PLENUM CRAWLSPACES**

| Nominal R-Value Perimeter | U-Factor |
|------------------------------|----------|
| 11 | 0.085 |
| 19 | 0.075 |
| 30 | 0.069 |

Note: Crawlspace used as heated plenums have approximately 30% higher heat loss rate than unvented crawlspaces with the same assumed ACH. Default U-factors in Table A105.1(2) reflect this higher rate of heat loss.

**TABLE A105.1(3)
DEFAULT U-FACTORS FOR EXPOSED FLOORS**

| Nominal R-Value | U-Factor | | |
|-----------------|----------|------------|-------------|
| | Concrete | Wood Joist | Metal Joist |
| R-11 | 0.077 | 0.088 | 0.14 |
| R-15 | 0.059 | 0.076 | 0.12 |
| R-19 | 0.048 | 0.062 | 0.11 |
| R-21 | 0.043 | 0.057 | 0.11 |
| R-25 | 0.037 | 0.051 | 0.10 |
| R-30 | 0.031 | 0.040 | 0.09 |
| R-38 | 0.025 | 0.034 | 0.08 |

A105.2 Crawlspace description. Four configurations are considered: Naturally ventilated crawlspace, mechanically vented crawlspace, heated plenum crawlspace and exposed floor.

A105.2.1 Naturally ventilated crawlspaces.

Assumed to have 3.0 air changes per hour, with at least 1.0 ft² of net-free ventilation in the foundation for every 300 ft² of crawlspace floor area. The crawlspace is not actively heated. Floors over unheated areas, such as garages, may only use those values which have R-0 perimeter insulation.

A105.2.2 Mechanically ventilated crawlspaces.

Assume to have 1.5 air changes per hour, with less than 1.0 ft² of net-free ventilation in the foundation for every 300 ft² of crawlspace floor area. The crawlspace is not actively heated. Floors over unheated basements may only use those values which have R-0 perimeter insulation.

A105.2.3 Heated plenum crawlspaces. Assumed to have 0.25 air changes per hour, with no foundation vents. Heated supply air from central furnace is blown into a crawlspace and allowed to enter the living space unducted via holes cut into the floor.

A105.2.4 Exposed floors. Assumes no buffer space, and a covering of 1/2 inch T1-11 on the exterior of

the cavity exposed to the outside air or rigid insulation below a concrete floor, such as over parking garages.

A105.3 Construction description. Floors are assumed to be either joisted floors framed on 16 inch centers, or post and beam on 4 foot by 8 foot squares. Insulation is assumed to be installed under the subflooring between the joists or beams with no space between the insulation and the subfloor. Insulation is assumed to be uncompressed. Exposed floors also include concrete with continuous rigid insulation assumed.

Perimeter insulation is assumed to extend from the top of the rim joist to the crawlspace floor and then inward along the ground (on top of the ground cover) for at least 24 inches.

Floor coverings are assumed to be light carpet with rubber pad.

**SECTION A106
ON-GRADE SLAB FLOORS**

A106.1 General. Table A106.1 lists heat loss coefficients for heated on-grade slab floors, in units of Btu/h × °F per lineal foot of perimeter.

**TABLE A106.1
DEFAULT F-FACTORS FOR ON-GRADE SLABS**

| Insulation type | R-0 | R-5 | R-10 | R-15 |
|---|------|------|------|------|
| Unheated Slab | | | | |
| Uninsulated slab | 0.73 | -- | -- | -- |
| 2 ft Horizontal (No thermal break) | -- | 0.70 | 0.70 | 0.69 |
| 4 ft Horizontal (No thermal break) | -- | 0.67 | 0.64 | 0.63 |
| 2 ft Vertical | -- | 0.58 | 0.54 | 0.52 |
| 4 ft Vertical | -- | 0.54 | 0.48 | 0.45 |
| Fully insulated slab | -- | -- | 0.36 | -- |
| Heated Slab | | | | |
| Uninsulated slab | 0.84 | -- | -- | -- |
| Fully insulated slab | -- | 0.74 | 0.55 | 0.44 |
| R-5 Center (With perimeter insulation) | -- | -- | 0.66 | 0.62 |
| R-10 Center (With perimeter insulation) | -- | -- | -- | 0.51 |
| 3 ft Vertical | -- | -- | 0.78 | -- |

A106.2 Component description. All on-grade slab floors are assumed to be 6 inch concrete poured directly onto the earth. The bottom of the slab is assumed to be at grade line. Monolithic and floating slabs are not differentiated.

Soil is assumed to have a conductivity of 0.75 Btu/h × ft² × °F. Slabs 2 feet or more below grade should use basement coefficients.

A106.3 Insulation description. Coefficients are provided for the following three configurations:

1. **Two foot (or four foot) vertical:** Insulation is applied directly to the slab exterior, extending downward from the top of the slab to a depth of 2 feet (or 4 feet) below grade.
2. **Two foot (or four foot) horizontal:** Insulation is applied directly to the underside of the slab, and run horizontally from the perimeter inward for 2 feet (or 4 feet). The slab edge is exposed in this configuration.

Note: A horizontal installation with a thermal break of at least R-5 at the slab edge should use the vertical-case F-factors.

3. **Fully insulated slab:** Insulation extends from the top of the slab, along the entire perimeter, and completely covers the area under the slab. Thicker perimeter insulation covers the slab edge and extends 2 feet under the slab.

SECTION A107 DEFAULT U-FACTORS FOR DOORS

A107.1 Doors without NFRC certification. Doors that do not have NFRC certification shall be assigned the appropriate U-factor from Tables A107.1(1) through A107.1(4).

**TABLE A107.1(1)
DEFAULT U-FACTORS FOR DOORS**

| Door Type | No Glazed Fenestration | Single Glazing | Double Glazing with ¼ in. Airspace | Double Glazing with ½ in. Airspace | Double Glazing with e=0.10, ½ in. Argon |
|---|--|----------------|------------------------------------|------------------------------------|---|
| SWINGING DOORS (Rough opening – 38 in. x 82 in.) | | | | | |
| Slab Doors | | | | | |
| Wood slab in wood frame ^a | 0.46 | | | | |
| 6% glazed fenestration (22 in. x 8 in. lite) | – | 0.48 | 0.47 | 0.46 | 0.44 |
| 25% glazed fenestration (22 in.x36 in. lite) | – | 0.58 | 0.48 | 0.46 | 0.42 |
| 45% glazed fenestration (22 in.x64 in. lite) | – | 0.69 | 0.49 | 0.46 | 0.39 |
| More than 50% glazed fenestration | Use Table C303.1.3(1)/R303.1.3(1) as appropriate | | | | |
| Insulated steel slab with wood edge in wood frame ^a | 0.16 | | | | |
| 6% glazed fenestration (22 in. x 8 in. lite) | – | 0.21 | 0.20 | 0.19 | 0.18 |
| 25% glazed fenestration (22 in.x36 in. lite) | – | 0.39 | 0.28 | 0.26 | 0.23 |
| 45% glazed fenestration (22 in.x64 in. lite) | – | 0.58 | 0.38 | 0.35 | 0.26 |
| More than 50% g glazed fenestration | Use Table C303.1.3(1)/R303.1.3(1) as appropriate | | | | |
| Foam insulated steel slab with metal edge in steel frame ^b | 0.37 | | | | |
| 6% glazed fenestration (22 in. x 8 in. lite) | – | 0.44 | 0.42 | 0.41 | 0.39 |
| 25% glazed fenestration (22 in.x36 in. lite) | – | 0.55 | 0.50 | 0.48 | 0.44 |
| 45% glazed fenestration (22 in.x64 in. lite) | – | 0.71 | 0.59 | 0.56 | 0.48 |
| More than 50% glazed fenestration | Use Table C303.1.3(1)/R303.1.3(1) as appropriate | | | | |
| Cardboard honeycomb slab with metal edge in steel frame ^b | 0.61 | | | | |
| Style and Rail Doors | | | | | |
| Sliding glass doors/French doors | Use Table C303.1.3(1)/R303.1.3(1) as appropriate | | | | |
| Site-Assembled Style and Rail Doors | | | | | |
| Aluminum in aluminum frame | – | 1.32 | 0.99 | 0.93 | 0.79 |
| Aluminum in aluminum frame with thermal break | – | 1.13 | 0.80 | 0.74 | 0.63 |

- a. Thermally broken sill (add 0.03 for non-thermally broken sill)
- b. Non-thermally broken sill
- c. Nominal U-factors are through the center of the insulated panel before consideration of thermal bridges around the edges of the door section and due to the frame.

**TABLE A107.1(2)
DEFAULT U-FACTORS FOR REVOLVING DOORS**

| Revolving Doors | |
|-----------------|----------|
| Size (W x H) | U-Factor |
| 3-wing | |
| 8 ft x 7 ft | 0.79 |
| 10 ft x 8 ft | 0.80 |
| 4-wing | |
| 7 ft x 6.5 ft | 0.63 |
| 7 ft x 7.5 ft | 0.64 |
| Open | |
| 82 in x 84 in | 1.32 |

**TABLE A107.1(3)
DEFAULT U-FACTORS FOR STEEL EMERGENCY DOORS**

| Double-Skin Steel Emergency Exit Doors | | |
|--|------------------|------------------|
| Core Insulation | 3 ft x 6 ft 8 in | 6 ft x 6 ft 8 in |
| 1-3/8 in. thickness | | |
| Honeycomb kraft paper | 0.57 | 0.52 |
| Mineral wool, steel ribs | 0.44 | 0.36 |
| Polyurethane foam | 0.34 | 0.28 |
| 1-3/4 in. thickness | | |
| Honeycomb kraft paper | 0.57 | 0.54 |
| Mineral wool, steel ribs | 0.41 | 0.33 |
| Polyurethane foam | 0.31 | 0.26 |
| 1-3/8 in. thickness | | |
| Honeycomb kraft paper | 0.60 | 0.55 |
| Mineral wool, steel ribs | 0.47 | 0.39 |
| Polyurethane foam | 0.37 | 0.31 |
| 1-3/4 in. thickness | | |
| Honeycomb kraft paper | 0.60 | 0.57 |
| Mineral wool, steel ribs | 0.44 | 0.37 |
| Polyurethane foam | 0.34 | 0.30 |

**TABLE A107.1(4)
DEFAULT U-FACTORS FOR STEEL GARAGE AND HANGAR DOORS**

| Double-Skin Steel Garage and Aircraft Hangar Doors | | | | | |
|---|--------------------------------------|-----------------------|--------------------------------------|------------------------------------|-------------------------------------|
| Insulation^e | One-piece tilt-up^a | | Sectional tilt-up^b | Aircraft hangar | |
| | 8 ft. x 7 ft. | 16 ft. x 7 ft. | 9 ft. x 7 ft. | 72 ft. x 12 ft.^c | 240 ft. x 50 ft.^d |
| 1-3/8 in. thickness | | | | | |
| EPS, steel ribs | 0.36 | 0.33 | 0.34-0.39 | | |
| XPS, steel ribs | 0.33 | 0.31 | 0.31-0.36 | | |
| 2 in. thickness | | | | | |
| EPS, steel ribs | 0.31 | 0.28 | 0.29-0.33 | | |
| XPS, steel ribs | 0.29 | 0.26 | 0.27-0.31 | | |
| 3 in. thickness | | | | | |
| EPS, steel ribs | 0.26 | 0.23 | 0.25-0.28 | | |
| XPS, steel ribs | 0.24 | 0.21 | 0.24-0.27 | | |
| 4 in. thickness | | | | | |
| EPS, steel ribs | 0.23 | 0.20 | 0.23-0.25 | | |
| XPS, steel ribs | 0.21 | 0.19 | 0.21-0.24 | | |
| 6 in. thickness | | | | | |
| EPS, steel ribs | 0.20 | 0.16 | 0.20-0.21 | | |
| XPS, steel ribs | 0.19 | 0.15 | 0.19-0.21 | | |
| 4 in. thickness | | | | | |
| Non-insulated | | | | 1.10 | 1.23 |
| Expanded polystyrene | | | | 0.25 | 0.16 |
| Mineral wool, steel ribs | | | | 0.25 | 0.16 |
| Extruded polystyrene | | | | 0.23 | 0.15 |
| 6 in. thickness | | | | | |
| Non-insulated | | | | 1.10 | 1.23 |
| Expanded polystyrene | | | | 0.21 | 0.13 |
| Mineral wool, steel ribs | | | | 0.23 | 0.13 |
| Extruded polystyrene | | | | 0.20 | 0.12 |
| Uninsulated | | | | | |
| All products | 1.15 | | | | |

- a. Values are for thermally broken or thermally unbroken doors.
- b. Lower values are for thermally broken doors; upper values are for doors with no thermal break.
- c. Typical size for a small private airplane (single-engine or twin).
- d. Typical hangar door for a midsize commercial jet airliner.
- e. EPS is extruded polystyrene, XPS is expanded polystyrene.

**SECTION A108
AIR INFILTRATION**

A108.1 General. Tables A108.1(1) and A108.1(2) list effective air change rates and heat capacities for heat loss due to infiltration for Single-Family Residential.

The estimated seasonal average infiltration rate in air changes per hour (ACH) is given for standard air-leakage control (see Section R402.4 for air leakage requirements for Single-Family Residential). The effective air change rate shall be used in calculations for compliance under either the Component Performance or Systems Analysis approaches.

Heat loss due to infiltration shall be computed using the following equation:

$$Q_{\text{infil}} = \text{ACH}_{\text{eff}} * \text{HCP}$$

Where:

Q_{infil} = Heat loss due to air infiltration.

ACH_{eff} = The effective air infiltration rate in Table A108.1(1)

HCP = The Heat Capacity Density Product for the appropriate elevation or climate zone as given below.

**TABLE A108.1(1)
ASSUMED EFFECTIVE AIR CHANGES
PER HOUR**

| Air-Leakage Control Package | Air Changes per Hour | |
|-----------------------------|----------------------|-----------|
| | Natural | Effective |
| Standard | 0.35 | 0.35 |

**TABLE A108.1(2)
DEFAULT HEAT CAPACITY/DENSITY
PRODUCT FOR AIR**

| Zone | Average Elevation | Heat Capacity/Density |
|------|-------------------|-----------------------|
| 1 | Mean Sea Level | 0.0180 Btu/h•°F |
| 2 | 2000 | 0.0168 Btu/h•°F |
| 3 | 3000 | 0.0162 Btu/h•°F |

Appendix B

DEFAULT INTERNAL LOAD VALUES AND SCHEDULES

SECTION B101 GENERAL

B101.1 Scope. The following default internal load values and schedules shall apply to Section C407.

SECTION B102 DEFAULT TABLES OF INTERNAL LOADS

B102 Default tables of internal loads. Default occupancy densities, receptacle power densities and service hot water consumption are included in Table B102.

**TABLE B102
ACCEPTABLE OCCUPANCY DENSITIES, RECEPTACLE POWER DENSITIES
AND SERVICE HOT WATER CONSUMPTION^a**

| Building Type | Occupancy Density ^b ft ² /Person (Btu/h· ft ²) | Receptacle Power Density ^c , Watts/ ft ² (Btu/h· ft ²) | Service Hot Water Quantities ^d Btu/h per person |
|----------------------|---|--|--|
| Assembly | 50 (4.60) | 0.25 (0.85) | 215 |
| Health/Institutional | 200 (1.15) | 1.00 (3.41) | 135 |
| Hotel/Motel | 250 (0.92) | 0.25 (0.85) | 1,110 |
| Light Manufacturing | 750 (0.31) | 0.20 (0.68) | 225 |
| Office | 275 (0.84) | 0.75 (2.56) | 175 |
| Parking Garage | NA | NA | NA |
| Restaurant | 100 (2.30) | 0.10 (0.34) | 390 |
| Retail | 300 (0.77) | 0.25 (0.85) | 135 |
| School | 75 (3.07) | 0.50 (1.71) | 215 |
| Warehouse | 15,000 (0.02) | 0.10 (0.34) | 225 |

- a. The occupancy densities, receptacle power densities, and service hot water consumption values are from ASHRAE Standard 90.1-1989 and addenda.
- b. Values are in square feet of conditioned floor area per person. Heat generation in Btu per person per hour is 230 sensible and 190 latent. Figures in parenthesis are equivalent Btu per hour per square foot.
- c. Values are in Watts per square foot of conditioned floor area. Figures in parenthesis are equivalent Btu per hour per square foot. These values are the minimum acceptable. If other process loads are not input (such as for computers, cooking, refrigeration, etc.), it is recommended that receptacle power densities be increased until total process energy consumption is equivalent to 25% of the total.
- d. Values are in Btu per person per hour.

**SECTION B103
DEFAULT SCHEDULES**

B103 Default schedules. Default schedules for occupancy, lighting, receptacles, HVAC, service hot water, and elevators are included in Tables B103(1) through B103(10).

**TABLE B103(1)
ASSEMBLY OCCUPANCY^a**

| Hour of Day (Time) | Schedule for Occupancy Percent of Maximum Load | | | Schedule for Lighting Receptacle Percent of Maximum Load | | | Schedule for HVAC System | | | Schedule for Service Hot Water Percent of Maximum Load | | | Schedule for Elevator Percent of Maximum Load | | |
|-----------------------|---|-------------|-----|---|-------------|-----|-----------------------------|------------|------|---|-----------|-----|--|---------|-----|
| | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun |
| 1 (12-1 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 0 | 0 | 0 | 0 | 0 | 0 |
| 2 (1-2 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 0 | 0 | 0 | 0 | 0 | 0 |
| 3 (2-3 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 0 | 0 | 0 | 0 | 0 | 0 |
| 4 (3-4 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 0 | 0 | 0 | 0 | 0 | 0 |
| 5 (4-5 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 0 | 0 | 0 | 0 | 0 | 0 |
| 6 (5-6 am) | 0 | 0 | 0 | 5 | 5 | 5 | On | Off | Off | 0 | 0 | 0 | 0 | 0 | 0 |
| 7 (6-7 am) | 0 | 0 | 0 | 40 | 5 | 5 | On | On | On | 0 | 0 | 0 | 0 | 0 | 0 |
| 8 (7-8 am) | 0 | 0 | 0 | 40 | 30 | 30 | On | On | On | 0 | 0 | 0 | 0 | 0 | 0 |
| 9 (8-9 am) | 20 | 20 | 10 | 40 | 30 | 30 | On | On | On | 0 | 0 | 0 | 0 | 0 | 0 |
| 10 (9-10 am) | 20 | 20 | 10 | 75 | 50 | 30 | On | On | On | 5 | 5 | 5 | 0 | 0 | 0 |
| 11 (10-11 am) | 20 | 20 | 10 | 75 | 50 | 30 | On | On | On | 5 | 5 | 5 | 0 | 0 | 0 |
| 12 (11-12 pm) | 80 | 60 | 10 | 75 | 50 | 30 | On | On | On | 35 | 20 | 10 | 0 | 0 | 0 |
| 13 (12-1 pm) | 80 | 60 | 10 | 75 | 50 | 65 | On | On | On | 5 | 0 | 0 | 0 | 0 | 0 |
| 14 (1-2 pm) | 80 | 60 | 70 | 75 | 50 | 65 | On | On | On | 5 | 0 | 0 | 0 | 0 | 0 |
| 15 (2-3 pm) | 80 | 60 | 70 | 75 | 50 | 65 | On | On | On | 5 | 0 | 0 | 0 | 0 | 0 |
| 16 (3-4 pm) | 80 | 60 | 70 | 75 | 50 | 65 | On | On | On | 5 | 0 | 0 | 0 | 0 | 0 |
| 17 (4-5 pm) | 80 | 60 | 70 | 75 | 50 | 65 | On | On | On | 5 | 0 | 0 | 0 | 0 | 0 |
| 18 (5-6 pm) | 80 | 60 | 70 | 75 | 50 | 65 | On | On | On | 0 | 0 | 0 | 0 | 0 | 0 |
| 19 (6-7 pm) | 20 | 60 | 70 | 75 | 50 | 65 | On | On | On | 0 | 0 | 0 | 0 | 0 | 0 |
| 20 (7-8 pm) | 20 | 60 | 70 | 75 | 50 | 65 | On | On | On | 0 | 65 | 65 | 0 | 0 | 0 |
| 21 (8-9 pm) | 20 | 60 | 70 | 75 | 50 | 65 | On | On | On | 0 | 30 | 30 | 0 | 0 | 0 |
| 22 (9-10 pm) | 20 | 80 | 70 | 75 | 50 | 65 | On | On | On | 0 | 0 | 0 | 0 | 0 | 0 |
| 23 (10-11 pm) | 10 | 10 | 20 | 25 | 50 | 5 | On | On | On | 0 | 0 | 0 | 0 | 0 | 0 |
| 24 (11-12 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 0 | 0 | 0 | 0 | 0 | 0 |
| Total/Day | 710 | 750 | 700 | 1155 | 800 | 845 | 1800 | 1700 | 1700 | 70 | 125 | 115 | 0 | 0 | 0 |
| Total/Week | | 50.50 hours | | | 74.20 hours | | | 124 hours | | | 5.9 hours | | | 0 hours | |
| Total/Year | | 2633 hours | | | 3869 hours | | | 6465 hours | | | 308 hours | | | 0 hours | |

Wk = Weekday

- a. Schedules for occupancy, lighting, receptacle, HVAC system, and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. **These values may be used only if actual schedules are not known.**

**TABLE B103(2)
HEALTH OCCUPANCY^a**

| Hour of Day (Time) | Schedule for Occupancy Percent of Maximum Load | | | Schedule for Lighting Receptacle Percent of Maximum Load | | | Schedule for HVAC System | | | Schedule for Service Hot Water Percent of Maximum Load | | | Schedule for Elevator Percent of Maximum Load | | |
|-----------------------|---|-----|-------------|---|-----|-------------|-----------------------------|------|------------|---|-----|-------------|--|-----|-------------|
| | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun |
| 1 (12-1 am) | 0 | 0 | 0 | 10 | 10 | 5 | On | On | On | 1 | 1 | 1 | 0 | 0 | 0 |
| 2 (1-2 am) | 0 | 0 | 0 | 10 | 10 | 5 | On | On | On | 1 | 1 | 1 | 0 | 0 | 0 |
| 3 (2-3 am) | 0 | 0 | 0 | 10 | 10 | 5 | On | On | On | 1 | 1 | 1 | 0 | 0 | 0 |
| 4 (3-4 am) | 0 | 0 | 0 | 10 | 10 | 5 | On | On | On | 1 | 1 | 1 | 0 | 0 | 0 |
| 5 (4-5 am) | 0 | 0 | 0 | 10 | 10 | 5 | On | On | On | 1 | 1 | 1 | 0 | 0 | 0 |
| 6 (5-6 am) | 0 | 0 | 0 | 10 | 10 | 5 | On | On | On | 1 | 1 | 1 | 0 | 0 | 0 |
| 7 (6-7 am) | 0 | 0 | 0 | 10 | 10 | 5 | On | On | On | 1 | 1 | 1 | 0 | 0 | 0 |
| 8 (7-8 am) | 10 | 10 | 0 | 50 | 20 | 5 | On | On | On | 17 | 1 | 1 | 2 | 2 | 0 |
| 9 (8-9 am) | 50 | 30 | 5 | 90 | 40 | 10 | On | On | On | 58 | 20 | 1 | 75 | 46 | 2 |
| 10 (9-10 am) | 80 | 40 | 5 | 90 | 40 | 10 | On | On | On | 66 | 28 | 1 | 100 | 70 | 2 |
| 11 (10-11 am) | 80 | 40 | 5 | 90 | 40 | 10 | On | On | On | 78 | 30 | 1 | 100 | 70 | 2 |
| 12 (11-12 pm) | 80 | 40 | 5 | 90 | 40 | 10 | On | On | On | 82 | 30 | 1 | 100 | 70 | 2 |
| 13 (12-1 pm) | 80 | 40 | 5 | 90 | 40 | 10 | On | On | On | 71 | 24 | 1 | 75 | 51 | 2 |
| 14 (1-2 pm) | 80 | 40 | 5 | 90 | 40 | 10 | On | On | On | 82 | 24 | 1 | 100 | 51 | 2 |
| 15 (2-3 pm) | 80 | 40 | 5 | 90 | 40 | 10 | On | On | On | 78 | 23 | 1 | 100 | 51 | 2 |
| 16 (3-4 pm) | 80 | 40 | 5 | 90 | 40 | 10 | On | On | On | 74 | 23 | 1 | 100 | 51 | 2 |
| 17 (4-5 pm) | 80 | 40 | 0 | 30 | 40 | 5 | On | On | On | 63 | 23 | 1 | 100 | 51 | 0 |
| 18 (5-6 pm) | 50 | 10 | 0 | 30 | 40 | 5 | On | On | On | 41 | 10 | 1 | 100 | 25 | 0 |
| 19 (6-7 pm) | 30 | 10 | 0 | 30 | 10 | 5 | On | On | On | 18 | 1 | 1 | 52 | 2 | 0 |
| 20 (7-8 pm) | 30 | 0 | 0 | 30 | 10 | 5 | On | On | On | 18 | 1 | 1 | 52 | 0 | 0 |
| 21 (8-9 pm) | 20 | 0 | 0 | 30 | 10 | 5 | On | On | On | 18 | 1 | 1 | 52 | 0 | 0 |
| 22 (9-10 pm) | 20 | 0 | 0 | 30 | 10 | 5 | On | On | On | 10 | 1 | 1 | 28 | 0 | 0 |
| 23 (10-11 pm) | 0 | 0 | 0 | 30 | 10 | 5 | On | On | On | 1 | 1 | 1 | 0 | 0 | 0 |
| 24 (11-12 am) | 0 | 0 | 0 | 10 | 10 | 5 | On | On | On | 1 | 1 | 1 | 0 | 0 | 0 |
| Total/Day | 850 | 380 | 40 | 1060 | 550 | 160 | 2400 | 2400 | 2400 | 783 | 249 | 24 | 1136 | 540 | 16 |
| Total/Week | | | 46.70 hours | | | 60.10 hours | | | 168 hours | | | 41.88 hours | | | 62.36 hours |
| Total/Year | | | 2435 hours | | | 3134 hours | | | 8760 hours | | | 2148 hours | | | 3251 hours |

Wk = Weekday

- a. Schedules for occupancy, lighting, receptacle, HVAC system, and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. **These values may be used only if actual schedules are not known.**

**TABLE B103(3)
HOTEL/MOTEL OCCUPANCY^a**

| Hour of Day (Time) | Schedule for Occupancy Percent of Maximum Load | | | Schedule for Lighting Receptacle Percent of Maximum Load | | | Schedule for HVAC System | | | Schedule for Service Hot Water Percent of Maximum Load | | | Schedule for Elevator Percent of Maximum Load | | |
|-----------------------|---|------|-------------|---|-----|-------------|-----------------------------|------|-------------|---|-----|-------------|--|------|-------------|
| | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun |
| 1 (12-1 am) | 90 | 90 | 70 | 20 | 20 | 30 | On | On | On | 20 | 20 | 25 | 40 | 44 | 55 |
| 2 (1-2 am) | 90 | 90 | 70 | 15 | 20 | 30 | On | On | On | 15 | 15 | 20 | 33 | 35 | 55 |
| 3 (2-3 am) | 90 | 90 | 70 | 10 | 10 | 20 | On | On | On | 15 | 15 | 20 | 33 | 35 | 43 |
| 4 (3-4 am) | 90 | 90 | 70 | 10 | 10 | 20 | On | On | On | 15 | 15 | 20 | 33 | 35 | 43 |
| 5 (4-5 am) | 90 | 90 | 70 | 10 | 10 | 20 | On | On | On | 20 | 20 | 20 | 33 | 35 | 43 |
| 6 (5-6 am) | 90 | 90 | 70 | 20 | 10 | 20 | On | On | On | 25 | 25 | 30 | 33 | 35 | 43 |
| 7 (6-7 am) | 70 | 70 | 70 | 40 | 30 | 30 | On | On | On | 50 | 40 | 50 | 42 | 40 | 52 |
| 8 (7-8 am) | 40 | 50 | 70 | 50 | 30 | 40 | On | On | On | 60 | 50 | 50 | 42 | 32 | 52 |
| 9 (8-9 am) | 40 | 50 | 50 | 40 | 40 | 40 | On | On | On | 55 | 50 | 50 | 52 | 45 | 65 |
| 10 (9-10 am) | 20 | 30 | 50 | 40 | 40 | 30 | On | On | On | 45 | 50 | 55 | 52 | 45 | 65 |
| 11 (10-11 am) | 20 | 30 | 50 | 25 | 30 | 30 | On | On | On | 40 | 45 | 50 | 40 | 42 | 53 |
| 12 (11-12 pm) | 20 | 30 | 30 | 25 | 25 | 30 | On | On | On | 45 | 50 | 50 | 51 | 60 | 60 |
| 13 (12-1 pm) | 20 | 30 | 30 | 25 | 25 | 30 | On | On | On | 40 | 50 | 40 | 51 | 65 | 53 |
| 14 (1-2 pm) | 20 | 30 | 20 | 25 | 25 | 20 | On | On | On | 35 | 45 | 40 | 51 | 65 | 51 |
| 15 (2-3 pm) | 20 | 30 | 20 | 25 | 25 | 20 | On | On | On | 30 | 40 | 30 | 51 | 65 | 50 |
| 16 (3-4 pm) | 30 | 30 | 20 | 25 | 25 | 20 | On | On | On | 30 | 40 | 30 | 51 | 65 | 44 |
| 17 (4-5 pm) | 50 | 30 | 30 | 25 | 25 | 20 | On | On | On | 30 | 35 | 30 | 63 | 65 | 64 |
| 18 (5-6 pm) | 50 | 50 | 40 | 25 | 25 | 20 | On | On | On | 40 | 40 | 40 | 80 | 75 | 62 |
| 19 (6-7 pm) | 50 | 60 | 40 | 60 | 60 | 50 | On | On | On | 55 | 55 | 50 | 86 | 80 | 65 |
| 20 (7-8 pm) | 70 | 60 | 60 | 80 | 70 | 70 | On | On | On | 60 | 55 | 50 | 70 | 80 | 63 |
| 21 (8-9 pm) | 70 | 60 | 60 | 90 | 70 | 80 | On | On | On | 50 | 50 | 40 | 70 | 75 | 63 |
| 22 (9-10 pm) | 80 | 70 | 80 | 80 | 70 | 60 | On | On | On | 55 | 55 | 50 | 70 | 75 | 63 |
| 23 (10-11 pm) | 90 | 70 | 80 | 60 | 60 | 50 | On | On | On | 45 | 40 | 40 | 45 | 55 | 40 |
| 24 (11-12 am) | 90 | 70 | 80 | 30 | 30 | 30 | On | On | On | 25 | 30 | 20 | 45 | 55 | 40 |
| Total/Day | 1390 | 1390 | 1300 | 855 | 785 | 810 | 2400 | 2400 | 2400 | 915 | 930 | 900 | 1217 | 1303 | 1287 |
| Total/Week | | | 96.40 hours | | | 58.70 hours | | | 168.0 hours | | | 64.05 hours | | | 86.75 hours |
| Total/Year | | | 5026 hours | | | 3061 hours | | | 8760 hours | | | 3340 hours | | | 4523 hours |

Wk = Weekday

- a. Schedules for occupancy, lighting, receptacle, HVAC system, and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. **These values may be used only if actual schedules are not known.**

**TABLE B103(4)
LIGHT MANUFACTURING OCCUPANCY^a**

| Hour of Day (Time) | Schedule for Occupancy Percent of Maximum Load | | | Schedule for Lighting Receptacle Percent of Maximum Load | | | Schedule for HVAC System | | | Schedule for Service Hot Water Percent of Maximum Load | | | Schedule for Elevator Percent of Maximum Load | | |
|-----------------------|---|-----|-------------|---|-----|-------------|-----------------------------|------|-------------|---|-----|-------------|--|-----|-------------|
| | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun |
| 1 (12-1 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 5 | 4 | 0 | 0 | 0 |
| 2 (1-2 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 5 | 4 | 0 | 0 | 0 |
| 3 (2-3 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 5 | 4 | 0 | 0 | 0 |
| 4 (3-4 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 5 | 4 | 0 | 0 | 0 |
| 5 (4-5 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 5 | 4 | 0 | 0 | 0 |
| 6 (5-6 am) | 0 | 0 | 0 | 10 | 5 | 5 | Off | Off | Off | 8 | 8 | 7 | 0 | 0 | 0 |
| 7 (6-7 am) | 10 | 10 | 5 | 10 | 10 | 5 | On | On | Off | 7 | 7 | 4 | 0 | 0 | 0 |
| 8 (7-8 am) | 20 | 10 | 5 | 30 | 10 | 5 | On | On | Off | 19 | 11 | 4 | 35 | 16 | 0 |
| 9 (8-9 am) | 95 | 30 | 5 | 90 | 30 | 5 | On | On | Off | 35 | 15 | 4 | 69 | 14 | 0 |
| 10 (9-10 am) | 95 | 30 | 5 | 90 | 30 | 5 | On | On | Off | 38 | 21 | 4 | 43 | 21 | 0 |
| 11 (10-11 am) | 95 | 30 | 5 | 90 | 30 | 5 | On | On | Off | 39 | 19 | 4 | 37 | 18 | 0 |
| 12 (11-12 pm) | 95 | 30 | 5 | 90 | 30 | 5 | On | On | Off | 47 | 23 | 6 | 43 | 25 | 0 |
| 13 (12-1 pm) | 50 | 10 | 5 | 80 | 15 | 5 | On | On | Off | 57 | 20 | 6 | 58 | 21 | 0 |
| 14 (1-2 pm) | 95 | 10 | 5 | 90 | 15 | 5 | On | On | Off | 54 | 19 | 9 | 48 | 13 | 0 |
| 15 (2-3 pm) | 95 | 10 | 5 | 90 | 15 | 5 | On | On | Off | 34 | 15 | 6 | 37 | 8 | 0 |
| 16 (3-4 pm) | 95 | 10 | 5 | 90 | 15 | 5 | On | On | Off | 33 | 12 | 4 | 37 | 4 | 0 |
| 17 (4-5 pm) | 95 | 10 | 5 | 90 | 15 | 5 | On | On | Off | 44 | 14 | 4 | 46 | 5 | 0 |
| 18 (5-6 pm) | 30 | 5 | 5 | 50 | 5 | 5 | On | On | Off | 26 | 7 | 4 | 62 | 6 | 0 |
| 19 (6-7 pm) | 10 | 5 | 0 | 30 | 5 | 5 | On | Off | Off | 21 | 7 | 4 | 20 | 0 | 0 |
| 20 (7-8 pm) | 10 | 0 | 0 | 30 | 5 | 5 | On | Off | Off | 15 | 7 | 4 | 12 | 0 | 0 |
| 21 (8-9 pm) | 10 | 0 | 0 | 20 | 5 | 5 | On | Off | Off | 17 | 7 | 4 | 4 | 0 | 0 |
| 22 (9-10 pm) | 10 | 0 | 0 | 20 | 5 | 5 | On | Off | Off | 8 | 9 | 7 | 4 | 0 | 0 |
| 23 (10-11 pm) | 5 | 0 | 0 | 10 | 5 | 5 | Off | Off | Off | 5 | 5 | 4 | 0 | 0 | 0 |
| 24 (11-12 am) | 5 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 5 | 4 | 0 | 0 | 0 |
| Total/Day | 920 | 200 | 60 | 1040 | 280 | 120 | 1600 | 1200 | 0 | 537 | 256 | 113 | 555 | 151 | 0 |
| Total/Week | | | 48.60 hours | | | 56.00 hours | | | 92.00 hours | | | 30.54 hours | | | 29.26 hours |
| Total/Year | | | 2534 hours | | | 2920 hours | | | 4797 hours | | | 1592 hours | | | 1526 hours |

Wk = Weekday

- a. Schedules for occupancy, lighting, receptacle, HVAC system, and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. **These values may be used only if actual schedules are not known.**

**TABLE B103(5)
OFFICE OCCUPANCY^a**

| Hour of Day (Time) | Schedule for Occupancy Percent of Maximum Load | | | Schedule for Lighting Receptacle Percent of Maximum Load | | | Schedule for HVAC System | | | Schedule for Service Hot Water Percent of Maximum Load | | | Schedule for Elevator Percent of Maximum Load | | |
|-----------------------|---|-----|-------------|---|-----|-------------|-----------------------------|------|-------------|---|-----|-------------|--|-----|-------------|
| | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun |
| 1 (12-1 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 5 | 4 | 0 | 0 | 0 |
| 2 (1-2 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 5 | 4 | 0 | 0 | 0 |
| 3 (2-3 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 5 | 4 | 0 | 0 | 0 |
| 4 (3-4 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 5 | 4 | 0 | 0 | 0 |
| 5 (4-5 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 5 | 4 | 0 | 0 | 0 |
| 6 (5-6 am) | 0 | 0 | 0 | 10 | 5 | 5 | Off | Off | Off | 8 | 8 | 7 | 0 | 0 | 0 |
| 7 (6-7 am) | 10 | 10 | 5 | 10 | 10 | 5 | On | On | Off | 7 | 7 | 4 | 0 | 0 | 0 |
| 8 (7-8 am) | 20 | 10 | 5 | 30 | 10 | 5 | On | On | Off | 19 | 11 | 4 | 35 | 16 | 0 |
| 9 (8-9 am) | 95 | 30 | 5 | 90 | 30 | 5 | On | On | Off | 35 | 15 | 4 | 69 | 14 | 0 |
| 10 (9-10 am) | 95 | 30 | 5 | 90 | 30 | 5 | On | On | Off | 38 | 21 | 4 | 43 | 21 | 0 |
| 11 (10-11 am) | 95 | 30 | 5 | 90 | 30 | 5 | On | On | Off | 39 | 19 | 4 | 37 | 18 | 0 |
| 12 (11-12 pm) | 95 | 30 | 5 | 90 | 30 | 5 | On | On | Off | 47 | 23 | 6 | 43 | 25 | 0 |
| 13 (12-1 pm) | 50 | 10 | 5 | 80 | 15 | 5 | On | On | Off | 57 | 20 | 6 | 58 | 21 | 0 |
| 14 (1-2 pm) | 95 | 10 | 5 | 90 | 15 | 5 | On | On | Off | 54 | 19 | 9 | 48 | 13 | 0 |
| 15 (2-3 pm) | 95 | 10 | 5 | 90 | 15 | 5 | On | On | Off | 34 | 15 | 6 | 37 | 8 | 0 |
| 16 (3-4 pm) | 95 | 10 | 5 | 90 | 15 | 5 | On | On | Off | 33 | 12 | 4 | 37 | 4 | 0 |
| 17 (4-5 pm) | 95 | 10 | 5 | 90 | 15 | 5 | On | On | Off | 44 | 14 | 4 | 46 | 5 | 0 |
| 18 (5-6 pm) | 30 | 5 | 5 | 50 | 5 | 5 | On | On | Off | 26 | 7 | 4 | 62 | 6 | 0 |
| 19 (6-7 pm) | 10 | 5 | 0 | 30 | 5 | 5 | On | Off | Off | 21 | 7 | 4 | 20 | 0 | 0 |
| 20 (7-8 pm) | 10 | 0 | 0 | 30 | 5 | 5 | On | Off | Off | 15 | 7 | 4 | 12 | 0 | 0 |
| 21 (8-9 pm) | 10 | 0 | 0 | 20 | 5 | 5 | On | Off | Off | 17 | 7 | 4 | 4 | 0 | 0 |
| 22 (9-10 pm) | 10 | 0 | 0 | 20 | 5 | 5 | On | Off | Off | 8 | 9 | 7 | 4 | 0 | 0 |
| 23 (10-11 pm) | 5 | 0 | 0 | 10 | 5 | 5 | Off | Off | Off | 5 | 5 | 4 | 0 | 0 | 0 |
| 24 (11-12 am) | 5 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 5 | 4 | 0 | 0 | 0 |
| Total/Day | 920 | 200 | 60 | 1040 | 280 | 120 | 1600 | 1200 | 0 | 537 | 256 | 113 | 555 | 151 | 0 |
| Total/Week | | | 48.60 hours | | | 56.00 hours | | | 92.00 hours | | | 30.54 hours | | | 29.26 hours |
| Total/Year | | | 2534 hours | | | 2920 hours | | | 4797 hours | | | 1592 hours | | | 1526 hours |

Wk = Weekday

- a. Schedules for occupancy, lighting, receptacle, HVAC system, and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. **These values may be used only if actual schedules are not known.**

**TABLE B103(6)
PARKING GARAGE OCCUPANCY^a**

| Hour of Day (Time) | Schedule for Occupancy Percent of Maximum Load | | | Schedule for Lighting Receptacle Percent of Maximum Load | | | Schedule for HVAC System | | | Schedule for Service Hot Water Percent of Maximum Load | | | Schedule for Elevator Percent of Maximum Load | | |
|-----------------------|---|-----|-----|---|------|------|-----------------------------|-----|-----|---|-----|-----|--|-----|-----|
| | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun |
| 1 (12-1 am) | | | | 100 | 100 | 100 | | | | | | | | | |
| 2 (1-2 am) | | | | 100 | 100 | 100 | | | | | | | | | |
| 3 (2-3 am) | | | | 100 | 100 | 100 | | | | | | | | | |
| 4 (3-4 am) | | | | 100 | 100 | 100 | | | | | | | | | |
| 5 (4-5 am) | | | | 100 | 100 | 100 | | | | | | | | | |
| 6 (5-6 am) | | | | 100 | 100 | 100 | | | | | | | | | |
| 7 (6-7 am) | | | | 100 | 100 | 100 | | | | | | | | | |
| 8 (7-8 am) | | | | 100 | 100 | 100 | | | | | | | | | |
| 9 (8-9 am) | | | | 100 | 100 | 100 | | | | | | | | | |
| 10 (9-10 am) | | | | 100 | 100 | 100 | | | | | | | | | |
| 11 (10-11 am) | | | | 100 | 100 | 100 | | | | | | | | | |
| 12 (11-12 pm) | | NA | | 100 | 100 | 100 | | | | | NA | | | | |
| 13 (12-1 pm) | | | | 100 | 100 | 100 | | | | | | | | | |
| 14 (1-2 pm) | | | | 100 | 100 | 100 | | | | | | | | | |
| 15 (2-3 pm) | | | | 100 | 100 | 100 | | | | | | | | | |
| 16 (3-4 pm) | | | | 100 | 100 | 100 | | | | | | | | | |
| 17 (4-5 pm) | | | | 100 | 100 | 100 | | | | | | | | | |
| 18 (5-6 pm) | | | | 100 | 100 | 100 | | | | | | | | | |
| 19 (6-7 pm) | | | | 100 | 100 | 100 | | | | | | | | | |
| 20 (7-8 pm) | | | | 100 | 100 | 100 | | | | | | | | | |
| 21 (8-9 pm) | | | | 100 | 100 | 100 | | | | | | | | | |
| 22 (9-10 pm) | | | | 100 | 100 | 100 | | | | | | | | | |
| 23 (10-11 pm) | | | | 100 | 100 | 100 | | | | | | | | | |
| 24 (11-12 am) | | | | 100 | 100 | 100 | | | | | | | | | |
| Total/Day | | | | 2400 | 2400 | 2400 | | | | | | | | | |
| Total/Week | | | | | | | | | | | | | | | |
| Total/Year | | | | | | | | | | | | | | | |

Wk = Weekday

- a. Schedules for occupancy, lighting, receptacle, HVAC system, and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. **These values may be used only if actual schedules are not known.**

**TABLE B103(7)
RESTAURANT OCCUPANCY^a**

| Hour of Day (Time) | Schedule for Occupancy Percent of Maximum Load | | | Schedule for Lighting Receptacle Percent of Maximum Load | | | Schedule for HVAC System | | | Schedule for Service Hot Water Percent of Maximum Load | | | Schedule for Elevator Percent of Maximum Load | | |
|-----------------------|---|-----|-------------|---|------|-------------|-----------------------------|------|------------|---|-----|-------------|--|-----|---------|
| | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun |
| 1 (12-1 am) | 15 | 30 | 20 | 15 | 20 | 20 | On | On | On | 20 | 20 | 25 | 0 | 0 | 0 |
| 2 (1-2 am) | 15 | 25 | 20 | 15 | 15 | 15 | On | On | On | 15 | 15 | 20 | 0 | 0 | 0 |
| 3 (2-3 am) | 5 | 5 | 5 | 15 | 15 | 15 | On | On | On | 15 | 15 | 20 | 0 | 0 | 0 |
| 4 (3-4 am) | 0 | 0 | 0 | 15 | 15 | 15 | Off | Off | Off | 0 | 0 | 0 | 0 | 0 | 0 |
| 5 (4-5 am) | 0 | 0 | 0 | 15 | 15 | 15 | Off | Off | Off | 0 | 0 | 0 | 0 | 0 | 0 |
| 6 (5-6 am) | 0 | 0 | 0 | 20 | 15 | 15 | Off | Off | Off | 0 | 0 | 0 | 0 | 0 | 0 |
| 7 (6-7 am) | 0 | 0 | 0 | 40 | 30 | 30 | Off | Off | Off | 0 | 0 | 0 | 0 | 0 | 0 |
| 8 (7-8 am) | 5 | 0 | 0 | 40 | 30 | 30 | On | Off | Off | 60 | 0 | 0 | 0 | 0 | 0 |
| 9 (8-9 am) | 5 | 0 | 0 | 60 | 60 | 50 | On | Off | Off | 55 | 0 | 0 | 0 | 0 | 0 |
| 10 (9-10 am) | 5 | 5 | 0 | 60 | 60 | 50 | On | On | Off | 45 | 50 | 0 | 0 | 0 | 0 |
| 11 (10-11 am) | 20 | 20 | 10 | 90 | 80 | 70 | On | On | On | 40 | 45 | 50 | 0 | 0 | 0 |
| 12 (11-12 pm) | 50 | 45 | 20 | 90 | 80 | 70 | On | On | On | 45 | 50 | 50 | 0 | 0 | 0 |
| 13 (12-1 pm) | 80 | 50 | 25 | 90 | 80 | 70 | On | On | On | 40 | 50 | 40 | 0 | 0 | 0 |
| 14 (1-2 pm) | 70 | 50 | 25 | 90 | 80 | 70 | On | On | On | 35 | 45 | 40 | 0 | 0 | 0 |
| 15 (2-3 pm) | 40 | 35 | 15 | 90 | 80 | 70 | On | On | On | 30 | 40 | 30 | 0 | 0 | 0 |
| 16 (3-4 pm) | 20 | 30 | 20 | 90 | 80 | 70 | On | On | On | 30 | 40 | 30 | 0 | 0 | 0 |
| 17 (4-5 pm) | 25 | 30 | 25 | 90 | 80 | 60 | On | On | On | 30 | 35 | 30 | 0 | 0 | 0 |
| 18 (5-6 pm) | 50 | 30 | 35 | 90 | 90 | 60 | On | On | On | 40 | 40 | 40 | 0 | 0 | 0 |
| 19 (6-7 pm) | 80 | 70 | 55 | 90 | 90 | 60 | On | On | On | 55 | 55 | 50 | 0 | 0 | 0 |
| 20 (7-8 pm) | 80 | 90 | 65 | 90 | 90 | 60 | On | On | On | 60 | 55 | 50 | 0 | 0 | 0 |
| 21 (8-9 pm) | 80 | 70 | 70 | 90 | 90 | 60 | On | On | On | 50 | 50 | 40 | 0 | 0 | 0 |
| 22 (9-10 pm) | 50 | 65 | 35 | 90 | 90 | 60 | On | On | On | 55 | 55 | 50 | 0 | 0 | 0 |
| 23 (10-11 pm) | 35 | 55 | 20 | 50 | 50 | 50 | On | On | On | 45 | 40 | 40 | 0 | 0 | 0 |
| 24 (11-12 am) | 20 | 35 | 20 | 30 | 30 | 30 | On | On | On | 25 | 30 | 20 | 0 | 0 | 0 |
| Total/Day | 750 | 740 | 485 | 1455 | 1365 | 1115 | 2000 | 1800 | 1700 | 790 | 730 | 625 | 0 | 0 | 0 |
| Total/Week | | | 49.75 hours | | | 97.55 hours | | | 135 hours | | | 53.05 hours | | | 0 hours |
| Total/Year | | | 2594 hours | | | 5086 hours | | | 7039 hours | | | 2766 hours | | | 0 hours |

Wk = Weekday

- a. Schedules for occupancy, lighting, receptacle, HVAC system, and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. **These values may be used only if actual schedules are not known.**

**TABLE B103(8)
RETAIL OCCUPANCY^a**

| Hour of Day (Time) | Schedule for Occupancy Percent of Maximum Load | | | Schedule for Lighting Receptacle Percent of Maximum Load | | | Schedule for HVAC System | | | Schedule for Service Hot Water Percent of Maximum Load | | | Schedule for Elevator Percent of Maximum Load | | |
|-----------------------|---|-------------|-----|---|-------------|-----|-----------------------------|------------|-----|---|-------------|-----|--|-------------|-----|
| | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun |
| 1 (12-1 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 4 | 11 | 7 | 0 | 0 | 0 |
| 2 (1-2 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 10 | 7 | 0 | 0 | 0 |
| 3 (2-3 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 8 | 7 | 0 | 0 | 0 |
| 4 (3-4 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 4 | 6 | 6 | 0 | 0 | 0 |
| 5 (4-5 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 4 | 6 | 6 | 0 | 0 | 0 |
| 6 (5-6 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 4 | 6 | 6 | 0 | 0 | 0 |
| 7 (6-7 am) | 0 | 0 | 0 | 5 | 5 | 5 | On | On | Off | 4 | 7 | 7 | 0 | 0 | 0 |
| 8 (7-8 am) | 10 | 10 | 0 | 20 | 10 | 5 | On | On | Off | 15 | 20 | 10 | 12 | 9 | 0 |
| 9 (8-9 am) | 20 | 20 | 0 | 50 | 30 | 10 | On | On | On | 23 | 24 | 12 | 22 | 21 | 0 |
| 10 (9-10 am) | 50 | 50 | 10 | 90 | 60 | 10 | On | On | On | 32 | 27 | 14 | 64 | 56 | 11 |
| 11 (10-11 am) | 50 | 60 | 20 | 90 | 90 | 40 | On | On | On | 41 | 42 | 29 | 74 | 66 | 13 |
| 12 (11-12 pm) | 70 | 80 | 20 | 90 | 90 | 40 | On | On | On | 57 | 54 | 31 | 68 | 68 | 35 |
| 13 (12-1 pm) | 70 | 80 | 40 | 90 | 90 | 60 | On | On | On | 62 | 59 | 36 | 68 | 68 | 37 |
| 14 (1-2 pm) | 70 | 80 | 40 | 90 | 90 | 60 | On | On | On | 61 | 60 | 36 | 71 | 69 | 37 |
| 15 (2-3 pm) | 70 | 80 | 40 | 90 | 90 | 60 | On | On | On | 50 | 49 | 34 | 72 | 70 | 39 |
| 16 (3-4 pm) | 80 | 80 | 40 | 90 | 90 | 60 | On | On | On | 45 | 48 | 35 | 72 | 69 | 41 |
| 17 (4-5 pm) | 70 | 80 | 40 | 90 | 90 | 60 | On | On | On | 46 | 47 | 37 | 73 | 66 | 38 |
| 18 (5-6 pm) | 50 | 60 | 20 | 90 | 90 | 40 | On | On | Off | 47 | 46 | 34 | 68 | 58 | 34 |
| 19 (6-7 pm) | 50 | 20 | 10 | 60 | 50 | 20 | On | On | Off | 42 | 44 | 25 | 68 | 47 | 3 |
| 20 (7-8 pm) | 30 | 20 | 0 | 60 | 30 | 5 | On | On | Off | 34 | 36 | 27 | 58 | 43 | 0 |
| 21 (8-9 pm) | 30 | 20 | 0 | 50 | 30 | 5 | On | On | Off | 33 | 29 | 21 | 54 | 43 | 0 |
| 22 (9-10 pm) | 0 | 10 | 0 | 20 | 10 | 5 | Off | On | Off | 23 | 22 | 16 | 0 | 8 | 0 |
| 23 (10-11 pm) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 13 | 16 | 10 | 0 | 0 | 0 |
| 24 (11-12 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 8 | 13 | 6 | 0 | 0 | 0 |
| Total/Day | 720 | 750 | 280 | 1115 | 985 | 525 | 1500 | 1600 | 900 | 662 | 690 | 459 | 844 | 761 | 288 |
| Total/Week | | 46.30 hours | | | 70.85 hours | | | 100 hours | | | 44.59 hours | | | 52.69 hours | |
| Total/Year | | 2414 hours | | | 3694 hours | | | 5214 hours | | | 2325 hours | | | 2747 hours | |

Wk = Weekday

- a. Schedules for occupancy, lighting, receptacle, HVAC system, and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. **These values may be used only if actual schedules are not known.**

**TABLE B103(9)
SCHOOL OCCUPANCY^a**

| Hour of Day (Time) | Schedule for Occupancy Percent of Maximum Load | | | Schedule for Lighting Receptacle Percent of Maximum Load | | | Schedule for HVAC System | | | Schedule for Service Hot Water Percent of Maximum Load | | | Schedule for Elevator Percent of Maximum Load | | |
|-----------------------|---|-----|-------------|---|-----|-------------|-----------------------------|-----|-------------|---|-----|-------------|--|-----|-------------|
| | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun |
| 1 (12-1 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 3 | 3 | 0 | 0 | 0 |
| 2 (1-2 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 3 | 3 | 0 | 0 | 0 |
| 3 (2-3 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 3 | 3 | 0 | 0 | 0 |
| 4 (3-4 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 3 | 3 | 0 | 0 | 0 |
| 5 (4-5 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 3 | 3 | 0 | 0 | 0 |
| 6 (5-6 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 3 | 3 | 0 | 0 | 0 |
| 7 (6-7 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 3 | 3 | 0 | 0 | 0 |
| 8 (7-8 am) | 5 | 0 | 0 | 30 | 5 | 5 | On | Off | Off | 10 | 3 | 3 | 0 | 0 | 0 |
| 9 (8-9 am) | 75 | 10 | 0 | 85 | 15 | 5 | On | On | Off | 34 | 3 | 5 | 30 | 0 | 0 |
| 10 (9-10 am) | 90 | 10 | 0 | 95 | 15 | 5 | On | On | Off | 60 | 5 | 5 | 30 | 0 | 0 |
| 11 (10-11 am) | 90 | 10 | 0 | 95 | 15 | 5 | On | On | Off | 63 | 5 | 5 | 30 | 0 | 0 |
| 12 (11-12 pm) | 80 | 10 | 0 | 95 | 15 | 5 | On | On | Off | 72 | 5 | 5 | 30 | 0 | 0 |
| 13 (12-1 pm) | 80 | 10 | 0 | 80 | 15 | 5 | On | On | Off | 79 | 5 | 5 | 30 | 0 | 0 |
| 14 (1-2 pm) | 80 | 0 | 0 | 80 | 5 | 5 | On | Off | Off | 83 | 3 | 5 | 30 | 0 | 0 |
| 15 (2-3 pm) | 80 | 0 | 0 | 80 | 5 | 5 | On | Off | Off | 61 | 3 | 3 | 30 | 0 | 0 |
| 16 (3-4 pm) | 45 | 0 | 0 | 70 | 5 | 5 | On | Off | Off | 65 | 3 | 3 | 15 | 0 | 0 |
| 17 (4-5 pm) | 15 | 0 | 0 | 50 | 5 | 5 | On | Off | Off | 10 | 3 | 3 | 0 | 0 | 0 |
| 18 (5-6 pm) | 5 | 0 | 0 | 50 | 5 | 5 | On | Off | Off | 10 | 3 | 3 | 0 | 0 | 0 |
| 19 (6-7 pm) | 15 | 0 | 0 | 35 | 5 | 5 | On | Off | Off | 19 | 3 | 3 | 0 | 0 | 0 |
| 20 (7-8 pm) | 20 | 0 | 0 | 35 | 5 | 5 | On | Off | Off | 25 | 3 | 3 | 0 | 0 | 0 |
| 21 (8-9 pm) | 20 | 0 | 0 | 35 | 5 | 5 | On | Off | Off | 22 | 3 | 3 | 0 | 0 | 0 |
| 22 (9-10 pm) | 10 | 0 | 0 | 30 | 5 | 5 | On | Off | Off | 22 | 3 | 3 | 0 | 0 | 0 |
| 23 (10-11 pm) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 12 | 3 | 3 | 0 | 0 | 0 |
| 24 (11-12 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 9 | 3 | 3 | 0 | 0 | 0 |
| Total/Day | 710 | 50 | 0 | 990 | 170 | 120 | 1500 | 500 | 0 | 691 | 80 | 84 | 285 | 0 | 0 |
| Total/Week | | | 36.00 hours | | | 52.40 hours | | | 80.00 hours | | | 36.19 hours | | | 14.25 hours |
| Total/Year | | | 1877 hours | | | 2732 hours | | | 4171 hours | | | 1887 hours | | | 743 hours |

Wk = Weekday

- a. Schedules for occupancy, lighting, receptacle, HVAC system, and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. **These values may be used only if actual schedules are not known.**

**TABLE B103(10)
WAREHOUSE OCCUPANCY^a**

| Hour of Day (Time) | Schedule for Occupancy Percent of Maximum Load | | | Schedule for Lighting Receptacle Percent of Maximum Load | | | Schedule for HVAC System | | | Schedule for Service Hot Water Percent of Maximum Load | | | Schedule for Elevator Percent of Maximum Load | | |
|-----------------------|---|-----|-------------|---|-----|-------------|-----------------------------|-----|-------------|---|-----|-------------|--|-----|------------|
| | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun |
| 1 (12-1 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 2 | 2 | 2 | 0 | 0 | 0 |
| 2 (1-2 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 2 | 2 | 2 | 0 | 0 | 0 |
| 3 (2-3 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 2 | 2 | 2 | 0 | 0 | 0 |
| 4 (3-4 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 2 | 2 | 2 | 0 | 0 | 0 |
| 5 (4-5 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 2 | 2 | 0 | 0 | 0 |
| 6 (5-6 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 7 | 2 | 2 | 0 | 0 | 0 |
| 7 (6-7 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 7 | 2 | 2 | 0 | 0 | 0 |
| 8 (7-8 am) | 15 | 0 | 0 | 40 | 5 | 5 | On | Off | Off | 10 | 2 | 2 | 0 | 0 | 0 |
| 9 (8-9 am) | 70 | 20 | 0 | 70 | 8 | 5 | On | On | Off | 30 | 6 | 2 | 0 | 0 | 0 |
| 10 (9-10 am) | 90 | 20 | 0 | 90 | 24 | 5 | On | On | Off | 36 | 12 | 2 | 0 | 0 | 0 |
| 11 (10-11 am) | 90 | 20 | 0 | 90 | 24 | 5 | On | On | Off | 36 | 12 | 2 | 30 | 0 | 0 |
| 12 (11-12 pm) | 90 | 20 | 0 | 90 | 24 | 5 | On | On | Off | 46 | 17 | 2 | 0 | 0 | 0 |
| 13 (12-1 pm) | 50 | 10 | 0 | 80 | 5 | 5 | On | On | Off | 57 | 4 | 4 | 0 | 0 | 0 |
| 14 (1-2 pm) | 85 | 10 | 0 | 90 | 5 | 5 | On | On | Off | 43 | 4 | 4 | 0 | 0 | 0 |
| 15 (2-3 pm) | 85 | 10 | 0 | 90 | 5 | 5 | On | On | Off | 38 | 2 | 2 | 0 | 0 | 0 |
| 16 (3-4 pm) | 85 | 10 | 0 | 90 | 5 | 5 | On | On | Off | 40 | 2 | 2 | 40 | 0 | 0 |
| 17 (4-5 pm) | 20 | 0 | 0 | 90 | 5 | 5 | On | Off | Off | 30 | 2 | 2 | 0 | 0 | 0 |
| 18 (5-6 pm) | 0 | 0 | 0 | 30 | 5 | 5 | Off | Off | Off | 18 | 2 | 2 | 0 | 0 | 0 |
| 19 (6-7 pm) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 3 | 2 | 2 | 0 | 0 | 0 |
| 20 (7-8 pm) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 3 | 2 | 2 | 0 | 0 | 0 |
| 21 (8-9 pm) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 3 | 2 | 2 | 0 | 0 | 0 |
| 22 (9-10 pm) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 3 | 2 | 2 | 0 | 0 | 0 |
| 23 (10-11 pm) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 3 | 2 | 2 | 0 | 0 | 0 |
| 24 (11-12 am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 3 | 2 | 2 | 0 | 0 | 0 |
| Total/Day | 680 | 120 | 0 | 915 | 180 | 120 | 1000 | 800 | 0 | 429 | 91 | 52 | 70 | 0 | 0 |
| Total/Week | | | 35.20 hours | | | 48.75 hours | | | 58.00 hours | | | 22.88 hours | | | 3.50 hours |
| Total/Year | | | 1835 hours | | | 2542 hours | | | 3024 hours | | | 1193 hours | | | 182 hours |

Wk = Weekday

- a. Schedules for occupancy, lighting, receptacle, HVAC system, and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. **These values may be used only if actual schedules are not known.**

APPENDIX C

EXTERIOR DESIGN CONDITIONS

As required by Sections C302.2 and R302.2, the heating or cooling outdoor design temperatures shall be selected from Table C-1.

TABLE C-1
OUTDOOR DESIGN TEMPERATURES

| Location | Outdoor Design Temp Heating (°F) | Outdoor Design Temp Cooling (°F) |
|----------------------|----------------------------------|----------------------------------|
| Aberdeen 20NNE | 25 | 83 |
| Anacortes | 24 | 72 |
| Anatone | -4 | 89 |
| Auburn | 25 | 84 |
| Battleground | 19 | 91 |
| Bellevue | 24 | 83 |
| Bellingham 2N | 19 | 78 |
| Blain | 17 | 73 |
| Bremerton | 29 | 83 |
| Burlington | 19 | 77 |
| Chehalis | 21 | 87 |
| Chelan | 10 | 89 |
| Cheney | 4 | 94 |
| Chesaw | -11 | 81 |
| Clarkston | 10 | 94 |
| Cle Elum | 1 | 91 |
| Colfax 1NW | 2 | 94 |
| Colville AP | -2 | 92 |
| Concrete | 19 | 83 |
| Connell 4NNW | 6 | 100 |
| Cougar 5E | 25 | 93 |
| Dallesport AP | 14 | 99 |
| Darrington RS | 13 | 85 |
| Davenport | 5 | 92 |
| Edmonds | 24 | 82 |
| Ellensburg AP | 2 | 90 |
| Elma | 24 | 88 |
| Ephrata AP | 7 | 97 |
| Everett Paine AFB | 21 | 79 |
| Forks 1E | 23 | 81 |
| Glacier RS | 13 | 82 |
| Glenoma (Kosmos) | 18 | 89 |
| Goldendale | 7 | 94 |
| Grays River Hatchery | 24 | 86 |

| Location | Outdoor Design Temp Heating (°F) | Outdoor Design Temp Cooling (°F) |
|--------------------|----------------------------------|----------------------------------|
| Greenwater | 1.4 | 84 |
| Grotto | 21 | 84 |
| Hoquiam AP | 26 | 79 |
| Inchelium 2NW | 0 | 92 |
| John Day Dam | 19 | 100 |
| Long Beach 3NNE | 25 | 77 |
| Longview | 24 | 87 |
| Lower Granite Dam | 14 | 98 |
| Lower Monument Dam | 18 | 103 |
| Marysville | 23 | 79 |
| Metaline Falls | -1 | 89 |
| Methow 2W | 1 | 89 |
| Nespelem 2S | -4 | 93 |
| Newhalem | 19 | 89 |
| Newport | -5 | 92 |
| Northport | 2 | 92 |
| Oak Harbor | 16 | 74 |
| Odessa | 7 | 100 |
| Olga 2SE | 24 | 71 |
| Olympia AP | 17 | 85 |
| Omak 2NW | 3 | 90 |
| Oroville | 5 | 93 |
| Othello | 9 | 98 |
| Packwood | 16 | 90 |
| Plain | -3 | 89 |
| Pleasant View | 16 | 98 |
| Pomeroy | 3 | 95 |
| Port Angeles | 28 | 75 |
| Port Townsend | 25 | 76 |
| Prosser | 12 | 97 |
| Puyallup | 19 | 86 |
| Quilcene 2SW | 23 | 83 |
| Quinalt RS | 25 | 84 |

| Location | Outdoor Design Temp Heating (°F) | Outdoor Design Temp Cooling (°F) |
|--------------------|----------------------------------|----------------------------------|
| Rainier, Longmire | 15 | 85 |
| Paradise RS | 8 | 71 |
| Raymond | 28 | 81 |
| Redmond | 17 | 83 |
| Republic | -9 | 87 |
| Richland | 11 | 101 |
| Ritzville | 6 | 99 |
| Satus Pass | 10 | 90 |
| Seattle: SeaTac AP | 24 | 83 |
| Sedro Woolley 1E | 19 | 78 |
| Sequim | 23 | 78 |
| Shelton | 23 | 85 |
| Smyrna | 8 | 102 |
| Snohomish | 21 | 81 |
| Snoqualmie Pass | 6 | 80 |
| Spokane AP | 4 | 92 |
| Spokane CO | 10 | 96 |
| Stampede Pass | 7 | 76 |
| Stehekin 3 NW | 12 | 85 |
| Stevens Pass | 6 | 77 |
| Tacoma CO | 29 | 82 |
| Tatoosh Island | 31 | 63 |
| Toledo AP | 17 | 84 |
| Vancouver | 22 | 88 |
| Vashon Island | 28 | 78 |
| Walla Walla AP | 6 | 96 |
| Waterville | 1 | 88 |
| Wellpinit | 1 | 93 |
| Wenatchee CO | 10 | 92 |
| Whidbey Island | 11 | 71 |
| Willapa Harbor | 26 | 81 |
| Wilson Creek | 3 | 96 |
| Winthrop 1WSW | -12 | 91 |
| Yakima AP | 11 | 94 |

ABBREVIATIONS:
Typical: "4(miles)NE"

AFB Air Force Base

AP Airport

CO City Office

RS Ranger Station