



Wind Load Report - WIND LOADING ANALYSIS

1. Site & Building Data

Roof Type: Gable
 Wind Speed (ult): 99 mph
 Exposure Category: C
 Enclosure Class: Enclosed
 Building Width (W): 50 ft.
 Building Length (L): 70 ft.
 Eave Height (h_e): 20 ft.
 Foundation Height (h_f): 0.5 ft.
 Roof Pitch: 4 /12
 Eave Overhang (OH_e): 1 ft.
 Gable Overhang (OH_g): 1 ft.

2. Parameters & Coefficients

Topographic Factor (K_{zt}): 1.0
 Directionality Factor (K_d): .85
 Roof Angle (θ): 18.43 deg.
 Mean Roof Height (h): 24.17 ft.
 Ridge Height (h_r): 28.33 ft.
 Pos. Internal Pressure (+GC_{pi}): +0.18
 Neg. Internal Pressure (-GC_{pi}): -0.18
 Velocity Pressure Exp. Coeff. (K_h): 0.94 @ z=h
 Velocity Pressure (q_h): 20.02 psf
 End Zone Width (a): 3.00 ft.
 Zone 2/2E Dist.: 25.00 ft.

3. Design Assumptions and Notes


Code Standard: ASCE 7-10
 Geometry: Regular-Shaped Bldg.
 Height Class: Low-Rise Building
 Notes:

4. Design Loads

Top Chord Dead Load: 7 psf
 Bottom Chord Dead Load: 10 psf
 Truss/Rafter Spacing: 24 in. o/c

4. Design Wind Pressures: MWFRS Envelope Procedure

Load Case A: Transverse Direction			
Surface	GC _{pf}	Design Pressure (psf)	
		(w/ +GC _{pi})	(w/ -GC _{pi})
1	0.52	6.73	13.94
2	-0.69	-17.41	-10.21
3	-0.47	-12.98	-5.78
4	-0.42	-11.92	-4.71
1E	0.78	12.01	19.22
2E	-1.07	-25.02	-17.81
3E	-0.67	-17.08	-9.87
4E	-0.62	-15.97	-8.77
2OH	-0.69	-13.81	
2EOH	-1.07	-21.42	
3OH	-0.47	-9.38	
3EOH	-0.67	-13.48	
2OH+W	-0.69/-0.7	-27.28	
2EOH+W	-1.07/-0.7	-34.88	



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
- b) External Pressure Coefficients linearly interpolated from Fig. 28.4-1 ASCE 7-10.
- c) Design building for all wind directions, 4 load patterns per load case.
- d) Total horizontal shear shall not be less than that by neglecting roof wind forces.
- e) Min. wind load for enclosed or partially enclosed bldg.: 16 psf wall, 8 psf roof.
- f) Design pressures are for strength design, multiply by 0.6 for ASD.

Subject Wind Loads	Customer PAUL SCHIEMAN	Location 13621 SUMMITVIEW EXT	Job No. 13621
Engr. MALIK REHMAN	REHMAN CONSULTING ENGINEERS		Rev. -
Date 8/12/2024	7936 EL RENO AVE, ELVERTA, CA 95626 ph. 9164064264 www.website.com		Page 1



This report may not be copied, reproduced or distributed without the written consent of Company Name

Load Case B: Longitudinal Direction


Surface	GCpf	Design Pressure (psf)	
		(w/ +GCpi)	(w/ -GCpi)
1	-0.45	-12.61	-5.40
2	-0.69	-17.41	-10.21
3	-0.37	-11.01	-3.80
4	-0.45	-12.61	-5.40
5	0.40	4.40	11.61
6	-0.29	-9.41	-2.20
1E	-0.48	-13.21	-6.00
2E	-1.07	-25.02	-17.81
3E	-0.53	-14.21	-7.01
4E	-0.48	-13.21	-6.00
5E	0.61	8.61	15.81
6E	-0.43	-12.21	-5.00
2OH	-0.69	-13.81	
2EOH	-1.07	-21.42	
3OH	-0.37	-7.41	
3EOH	-0.53	-10.61	
2EOH+W	-1.07/-0.7	-35.43	
3EOH+W	-0.53/-0.7	-24.62	



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
- b) External Pressure Coefficients linearly interpolated from Fig. 28.4-1 ASCE 7-10.
- c) Design building for all wind directions, 4 load patterns per load case.
- d) Total horizontal shear shall not be less than that by neglecting roof wind forces.
- e) Min. wind load for enclosed or partially enclosed bldg.: 16 psf wall, 8 psf roof.
- f) Design pressures are for strength design, multiply by 0.6 for ASD.

Torsional Load Cases

Surface	Load Case	GCpf	Design Pressure (psf)	
			(w/ +GCpi)	(w/ -GCpi)
1T	A	-	1.68	3.49
2T	A	-	-4.35	-2.55
3T	A	-	-3.25	-1.44
4T	A	-	-2.98	-1.18
5T	B	-	1.10	2.90
6T	B	-	-2.35	-0.55



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
- b) Pressures designated with a "T" are 25% of full design wind pressures.
- c) Torsional loading shall apply to all 8 load patterns using the figures shown.
- d) Design pressures are for strength design, multiply by 0.6 for ASD.
- e) Torsional Design Exceptions: One story bldg. with $h \leq 30$ ft.
Two stories or less framed with light frame construction,
Two stories or less with flexible diaphragms.


Subject Wind Loads	Customer PAUL SCHIEMAN	Location 13621 SUMMITVIEW EXT	Job No. 13621
Engr. MALIK REHMAN	REHMAN CONSULTING ENGINEERS		Rev. -
Date 8/12/2024	7936 EL RENO AVE, ELVERTA, CA 95626 ph. 9164064264 www.website.com		Page 2



This report may not be copied, reproduced or distributed without the written consent of Company Name

5. Wind Load Calculations

1.) Lateral Loads - Transverse Direction:



- a) (-) signs signify wind lateral forces acting opposite to the direction of the arrows shown.
 b) Strength design values multiplied by 0.6 to obtain ASD values.

Wind Base Shear (ASD)						
Load Case A: Transverse Direction						
Load Case	Walls (lbs)	Roof (lbs)	Roof Overhangs (lbs)	Total Lateral Load (lbs)	R ₁ (lbs)	R ₂ (lbs)
Positive Internal Pressure	7966	-1657	-324	5984	3083	2902
Negative Internal Pressure	7966	-1657	-324	5984	3083	2902
Roof Pressure = 0	7966	0	0	7966	4133	3833
Min. Pressures (8 psf, 16 psf)	6552	2800	195	9547	4774	4774


- a) Bottom half of wall neglected in tributary area calculations.
 b) Strength design values multiplied by 0.6 to obtain ASD values.

Subject Wind Loads	Customer PAUL SCHIEMAN	Location 13621 SUMMITVIEW EXT	Job No. 13621
Engr. MALIK REHMAN	REHMAN CONSULTING ENGINEERS		Rev. -
Date 8/12/2024	7936 EL RENO AVE, ELVERTA, CA 95626 ph. 9164064264 www.website.com		Page 3



This report may not be copied, reproduced or distributed without the written consent of Company Name

2.) Lateral Loads - Longitudinal Direction:




- a) (-) signs signify wind lateral forces acting opposite to the direction of the arrows shown.
- b) Strength design values multiplied by 0.6 to obtain ASD values.
- c) Where the length of building (L) exceeds 4X the mean roof height (h), wind drag forces should additionally be considered.

Wind Base Shear (ASD)						
Load Case B: Longitudinal Direction						
Load Case	Walls (lbs)	Gable Ends (lbs)	Roof (lbs)	Total Lateral Load (lbs)	R _A (lbs)	R _B (lbs)
Positive Internal Pressure	4163	1733	0	5895	3008	2887
Negative Internal Pressure	4163	1733	0	5895	3008	2887
Roof Pressure = 0	4163	1733	0	5895	3008	2887
Min. Pressures (8 psf, 16 psf)	4680	2000	0	6680	3340	3340

- a) Bottom half of wall neglected in tributary area calculations.
- b) Strength design values multiplied by 0.6 to obtain ASD values.

Subject Wind Loads	Customer PAUL SCHIEMAN	Location 13621 SUMMITVIEW EXT	Job No. 13621
Engr. MALIK REHMAN	REHMAN CONSULTING ENGINEERS 7936 EL RENO AVE, ELVERTA, CA 95626 ph. 9164064264 www.website.com		Rev. -
Date 8/12/2024			
This report may not be copied, reproduced or distributed without the written consent of Company Name			
Copyright © 2024			

3.) Roof Truss Reactions:




- a) Strength design values multiplied by 0.6 to obtain ASD values.
- b) Windward loads may be positive or negative depending on pitch of roof.

Roof Truss/Rafter Reactions (ASD)					
w/ Positive Internal Pressure					
Load Case	Horizontal Load (lbs)	Gross Uplift (lbs)	Net Uplift (lbs)	U ₁ (lbs)	U ₂ (lbs)
Transverse Int. Zone	51	956	-105	-8	-96
Transverse End Zone	88	1321	261	203	58
Longitudinal Int. Zone	67	878	-182	-39	-143
Longitudinal End Zone	112	1215	155	165	-10

- a) Gross Uplift calculations do not include any counteracting roof dead loads.
- b) Net Uplift calculations include counteracting roof dead loads multiplied by 0.6 per load case (7) ASCE 7-10.
- c) Strength design values multiplied by 0.6 to obtain ASD values for wind loads.
- d) Loads based on truss spacing calculated at 24" o/c.
- e) Negative values for horizontal load indicate load acting in windward direction (transverse load cases).
- f) Negative values for uplift indicate net downward force (zero uplift).

*Disclaimer: The calculations produced herein are for initial design and estimating purposes only. The calculations and drawings presented do not constitute a fully engineered design. All of the potential load cases required to fully design an actual structure may not be provided by this calculator. For the design of an actual structure, a registered and licensed professional should be consulted as per IRC 2012 Sec. R802.10.2 and designed according to the minimum requirements of ASCE 7-10. The wind load calculations provided by this online tool are for educational and illustrative purposes only. Medeek Design assumes no liability or loss for any designs presented and does not guarantee fitness for use.

Subject Wind Loads	Customer PAUL SCHIEMAN	Location 13621 SUMMITVIEW EXT	Job No. 13621
Engr. MALIK REHMAN	REHMAN CONSULTING ENGINEERS 7936 EL RENO AVE, ELVERTA, CA 95626 ph. 9164064264 www.website.com		Rev. -
Date 8/12/2024			
			This report may not be copied, reproduced or distributed without the written consent of Company Name Copyright © 2024