



Wind Load Report - Wind Shear Load

1. Site & Building Data

Roof Type: Gable
Wind Speed (ult): 110 mph
Exposure Category: C
Enclosure Class: Enclosed
Building Width (W): 44 ft.
Building Length (L): 66 ft.
Eave Height (h_e): 16 ft.
Foundation Height (h_f): 0 ft.
Roof Pitch: 4 /12
Eave Overhang (OH_e): 1 ft.
Gable Overhang (OH_g): 1 ft.

2. Parameters & Coefficients

Topographic Factor (K_{zt}): 1.0
Directionality Factor (K_d): .85
Roof Angle (θ): 18.43 deg.
Mean Roof Height (h): 19.67 ft.
Ridge Height (h_r): 23.33 ft.
Pos. Internal Pressure (+GCpi): +0.18
Neg. Internal Pressure (-GCpi): -0.18
Velocity Pressure Exp. Coeff. (K_h): 0.90 @ $z=h$
Velocity Pressure (q_h): 23.66 psf
End Zone Width (a): 3.00 ft.
Zone 2/2E Dist.: 22.00 ft.

3. Design Assumptions and Notes

Code Standard: ASCE 7-10
Geometry: Regular-Shaped Bldg.
Height Class: Low-Rise Building
Notes:

4. Design Loads

Top Chord Dead Load: 7 psf
Bottom Chord Dead Load: 10 psf
Truss/Rafter Spacing: 48 in. o/c

4. Design Wind Pressures: MWFRS Envelope Procedure

Load Case A: Transverse Direction			
Surface	GCpf	Design Pressure (psf)	
		(w/ +GCpi)	(w/ -GCpi)
1	0.52	7.96	16.48
2	-0.69	-20.59	-12.07
3	-0.47	-15.35	-6.83
4	-0.42	-14.09	-5.57
1E	0.78	14.20	22.72
2E	-1.07	-29.58	-21.06
3E	-0.67	-20.19	-11.67
4E	-0.62	-18.88	-10.37
2OH	-0.69	-16.33	
2EOH	-1.07	-25.32	
3OH	-0.47	-11.09	
3EOH	-0.67	-15.93	
2OH+W	-0.69/-0.7	-32.19	
2EOH+W	-1.07/-0.7	-41.18	




- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
b) External Pressure Coefficients linearly interpolated from Fig. 28.4-1 ASCE 7-10.
c) Design building for all wind directions, 4 load patterns per load case.
d) Total horizontal shear shall not be less than that by neglecting roof wind forces.
e) Min. wind load for enclosed or partially enclosed bldg.: 16 psf wall, 8 psf roof.
f) Design pressures are for strength design, multiply by 0.6 for ASD.

Subject	Customer	Location	Job No.
Wind Loads	Brian Machado	Malbone Rd Freetown, Ma	2025D181
Engr.	ENGINEERING COMPANY INC. Street Address City, CA 99999 ph. (800) 000-0000 www.website.com		Rev.
Engineer Name			-
Date	6/2/2025	 This report may not be copied, reproduced or distributed without the written consent of Engineering Company Inc. Copyright © 2025	Page
			1

Load Case B: Longitudinal Direction


Surface	GCpf	Design Pressure (psf)	
		(w/ +GCpi)	(w/ -GCpi)
1	-0.45	-14.91	-6.39
2	-0.69	-20.59	-12.07
3	-0.37	-13.01	-4.50
4	-0.45	-14.91	-6.39
5	0.40	5.21	13.72
6	-0.29	-11.12	-2.60
1E	-0.48	-15.62	-7.10
2E	-1.07	-29.58	-21.06
3E	-0.53	-16.80	-8.28
4E	-0.48	-15.62	-7.10
5E	0.61	10.17	18.69
6E	-0.43	-14.43	-5.92
2OH	-0.69	-16.33	
2EOH	-1.07	-25.32	
3OH	-0.37	-8.76	
3EOH	-0.53	-12.54	
2EOH+W	-1.07/-0.7	-41.88	
3EOH+W	-0.53/-0.7	-29.10	



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
b) External Pressure Coefficients linearly interpolated from Fig. 28.4-1 ASCE 7-10.
c) Design building for all wind directions, 4 load patterns per load case.
d) Total horizontal shear shall not be less than that by neglecting roof wind forces.
e) Min. wind load for enclosed or partially enclosed bldg.: 16 psf wall, 8 psf roof.
f) Design pressures are for strength design, multiply by 0.6 for ASD.

Torsional Load Cases

Surface	Load Case	GCpf	Design Pressure (psf)	
			(w/ +GCpi)	(w/ -GCpi)
1T	A	-	1.99	4.12
2T	A	-	-5.15	-3.02
3T	A	-	-3.84	-1.71
4T	A	-	-3.52	-1.39
5T	B	-	1.30	3.43
6T	B	-	-2.78	-0.65



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
b) Pressures designated with a "T" are 25% of full design wind pressures.
c) Torsional loading shall apply to all 8 load patterns using the figures shown.
d) Design pressures are for strength design, multiply by 0.6 for ASD.
e) Torsional Design Exceptions: One story bldg. with $h \leq 30$ ft,
Two stories or less framed with light frame construction,
Two stories or less with flexible diaphragms.

Subject	Wind Loads	Customer	Brian Machado	Location	Malbone Rd Freetown, Ma	Job No.	2025D181
Engr.	Engineer Name	ENGINEERING COMPANY INC.				Rev.	-
Date	6/2/2025	Street Address City, CA 99999 ph. (800) 000-0000 www.website.com				Page	2




This report may not be copied, reproduced or distributed without the written consent of Engineering Company Inc.

Copyright © 2025

5. Wind Load Calculations

1.) Lateral Loads - Transverse Direction:



- a) (-) signs signify wind lateral forces acting opposite to the direction of the arrows shown.
b) Strength design values multiplied by 0.6 to obtain ASD values.

Wind Base Shear (ASD)						
Load Case A: Transverse Direction						
Load Case	Walls (lbs)	Roof (lbs)	Roof Overhangs (lbs)	Total Lateral Load (lbs)	R ₁ (lbs)	R ₂ (lbs)
Positive Internal Pressure	7303	-1631	-357	5315	2740	2575
Negative Internal Pressure	7303	-1631	-357	5315	2740	2575
Roof Pressure = 0	7303	0	0	7303	3796	3507
Min. Pressures (8 psf, 16 psf)	5069	2323	179	7571	3786	3786

- a) Bottom half of wall neglected in tributary area calculations.
b) Strength design values multiplied by 0.6 to obtain ASD values.


Subject	Customer	Location	Job No.
Wind Loads	Brian Machado	Malbone Rd Freetown, Ma	2025D181
Engr.	ENGINEERING COMPANY INC.		Rev.
Engineer Name	Street Address City, CA 99999		-
Date	6/2/2025		Page
	ph. (800) 000-0000 www.website.com		3



This report may not be copied, reproduced or distributed without the written consent of Engineering Company Inc.

Copyright © 2025

2.) Lateral Loads - Longitudinal Direction:



- a) (-) signs signify wind lateral forces acting opposite to the direction of the arrows shown.
b) Strength design values multiplied by 0.6 to obtain ASD values.
c) Where the length of building (L) exceeds 4X the mean roof height (h), wind drag forces should additionally be considered.

Wind Base Shear (ASD)						
Load Case B: Longitudinal Direction						
Load Case	Walls (lbs)	Gable Ends (lbs)	Roof (lbs)	Total Lateral Load (lbs)	R _A (lbs)	R _B (lbs)
Positive Internal Pressure	3568	1588	0	5155	2637	2519
Negative Internal Pressure	3568	1588	0	5155	2637	2519
Roof Pressure = 0	3568	1588	0	5155	2637	2519
Min. Pressures (8 psf, 16 psf)	3379	1549	0	4928	2464	2464

- a) Bottom half of wall neglected in tributary area calculations.
b) Strength design values multiplied by 0.6 to obtain ASD values.


Subject	Wind Loads	Customer	Brian Machado	Location	Malbone Rd Freetown, Ma	Job No.	2025D181
Engr.	Engineer Name	ENGINEERING COMPANY INC.				Rev.	-
Date	6/2/2025	Street Address City, CA 99999 ph. (800) 000-0000 www.website.com				Page	4



This report may not be copied, reproduced or distributed without the written consent of Engineering Company Inc.

Copyright © 2025

3.) Roof Truss Reactions:



- a) Strength design values multiplied by 0.6 to obtain ASD values.
b) Windward loads may be positive or negative depending on pitch of roof.

Roof Truss/Rafter Reactions (ASD)					
w/ Positive Internal Pressure					
Load Case	Horizontal Load (lbs)	Gross Uplift (lbs)	Net Uplift (lbs)	U ₁ (lbs)	U ₂ (lbs)
Transverse Int. Zone	109	2001	130	160	-30
Transverse End Zone	185	2765	894	602	292
Longitudinal Int. Zone	139	1834	-36	91	-127
Longitudinal End Zone	235	2540	669	519	150

- a) Gross Uplift calculations do not include any counteracting roof dead loads.
b) Net Uplift calculations include counteracting roof dead loads multiplied by 0.6 per load case (7) ASCE 7-10.
c) Strength design values multiplied by 0.6 to obtain ASD values for wind loads.
d) Loads based on truss spacing calculated at 48" o/c.
e) Negative values for horizontal load indicate load acting in windward direction (transverse load cases).
f) Negative values for uplift indicate net downward force (zero uplift).

*Disclaimer: The calculations produced herein are for initial design and estimating purposes only. The calculations and drawings presented do not constitute a fully engineered design. All of the potential load cases required to fully design an actual structure may not be provided by this calculator. For the design of an actual structure, a registered and licensed professional should be consulted as per IRC 2012 Sec. R802.10.2 and designed according to the minimum requirements of ASCE 7-10. The wind load calculations provided by this online tool are for educational and illustrative purposes only. Medeek Design assumes no liability or loss for any designs presented and does not guarantee fitness for use.

Subject	Wind Loads	Customer	Brian Machado	Location	Malbone Rd Freetown, Ma	Job No.	2025D181
Engr.	Engineer Name	ENGINEERING COMPANY INC.				Rev.	-
Date	6/2/2025	Street Address City, CA 99999 ph. (800) 000-0000 www.website.com				Page	5



This report may not be copied, reproduced or distributed without the written consent of Engineering Company Inc.

Copyright © 2025