



Wind Load Report

1. Site & Building Data

Roof Type: Gable
Wind Speed (ult): 115 mph
Exposure Category: C
Enclosure Class: Open
Building Width (W): 10 ft.
Building Length (L): 18 ft.
Eave Height (h_e): 8 ft.
Foundation Height (h_f): 0 ft.
Roof Pitch: 1 / 12
Eave Overhang (OH_e): 1 ft.
Gable Overhang (OH_g): 1 ft.

2. Parameters & Coefficients

Topographic Factor (K_{zt}): 1.0
Directionality Factor (K_d): .85
Roof Angle (θ): 4.76 deg.
Mean Roof Height (h): 8.21 ft.
Ridge Height (h_r): 8.42 ft.
Pos. Internal Pressure (+GCpi): +0.00
Neg. Internal Pressure (-GCpi): -0.00
Velocity Pressure Exp. Coeff. (K_h): 0.85 @ $z=h$
Velocity Pressure (q_h): 24.43 psf
End Zone Width (a): 3.00 ft.
Zone 2/2E Dist.: 5.00 ft.

3. Design Assumptions and Notes

Code Standard: ASCE 7-10
Geometry: Regular-Shaped Bldg.
Height Class: Low-Rise Building
Notes:

4. Design Loads

Top Chord Dead Load: 5 psf
Bottom Chord Dead Load: 10 psf
Truss/Rafter Spacing: 24 in. o/c

4. Design Wind Pressures: MWFRS Envelope Procedure

Load Case A: Transverse Direction			
Surface	GCpf	Design Pressure (psf)	
		(w/ +GCpi)	(w/ -GCpi)
1	0.40	9.77	
2	-0.69	-16.86	
3	-0.37	-9.04	
4	-0.29	-7.08	
1E	0.61	14.90	
2E	-1.07	-26.14	
3E	-0.53	-12.95	
4E	-0.43	-10.50	
2OH	-0.69	-16.86	
2EOH	-1.07	-26.14	
3OH	-0.37	-9.04	
3EOH	-0.53	-12.95	
2OH+W	-0.69/-0.7	-33.96	
2EOH+W	-1.07/-0.7	-43.24	



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
b) External Pressure Coefficients linearly interpolated from Fig. 28.4-1 ASCE 7-10.
c) Design building for all wind directions, 4 load patterns per load case.
d) Total horizontal shear shall not be less than that by neglecting roof wind forces.
e) Min. wind load for enclosed or partially enclosed bldg.: 16 psf wall, 8 psf roof.
f) Design pressures are for strength design, multiply by 0.6 for ASD.

Subject Wind Loads	Customer	Location	Job No. 2025D239
Engr. Engineer	NJA Engineering 941 New Road, Amherst NY 14228 ph. (716) 572-1140		Rev. -
Date 8/21/2025			Page 1



This report may not be
copied, reproduced or
distributed without the
written consent of NJA
Engineering

Copyright © 2025

Load Case B: Longitudinal Direction

Surface	GCpf	Design Pressure (psf)	
		(w/ +GCpi)	(w/ -GCpi)
1	-0.45	-10.99	
2	-0.69	-16.86	
3	-0.37	-9.04	
4	-0.45	-10.99	
5	0.40	9.77	
6	-0.29	-7.08	
1E	-0.48	-11.73	
2E	-1.07	-26.14	
3E	-0.53	-12.95	
4E	-0.48	-11.73	
5E	0.61	14.90	
6E	-0.43	-10.50	
2OH	-0.69	-16.86	
2EOH	-1.07	-26.14	
3OH	-0.37	-9.04	
3EOH	-0.53	-12.95	
2EOH+W	-1.07/-0.7	-43.24	
3EOH+W	-0.53/-0.7	-30.05	



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
b) External Pressure Coefficients linearly interpolated from Fig. 28.4-1 ASCE 7-10.
c) Design building for all wind directions, 4 load patterns per load case.
d) Total horizontal shear shall not be less than that by neglecting roof wind forces.
e) Min. wind load for enclosed or partially enclosed bldg.: 16 psf wall, 8 psf roof.
f) Design pressures are for strength design, multiply by 0.6 for ASD.

Torsional Load Cases

Surface	Load Case	GCpf	Design Pressure (psf)	
			(w/ +GCpi)	(w/ -GCpi)
1T	A	-	2.44	
2T	A	-	-4.21	
3T	A	-	-2.26	
4T	A	-	-1.77	
5T	B	-	2.44	
6T	B	-	-1.77	



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
b) Pressures designated with a "T" are 25% of full design wind pressures.
c) Torsional loading shall apply to all 8 load patterns using the figures shown.
d) Design pressures are for strength design, multiply by 0.6 for ASD.
e) Torsional Design Exceptions: One story bldg. with $h \leq 30$ ft,
Two stories or less framed with light frame construction,
Two stories or less with flexible diaphragms.

Subject	Wind Loads	Customer	Location	Job No.	2025D239	
Engr.	Engineer	NJA Engineering 941 New Road, Amherst NY 14228 ph. (716) 572-1140 STRUCTURAL ENGINEERS COMPANY LOGO This report may not be copied, reproduced or distributed without the written consent of NJA Engineering			Rev.	-
Date	8/21/2025				Page	2




This report may not be
copied, reproduced or
distributed without the
written consent of NJA
Engineering

Copyright © 2025

5. Wind Load Calculations

1.) Lateral Loads - Transverse Direction:




- a) (-) signs signify wind lateral forces acting opposite to the direction of the arrows shown.
b) Strength design values multiplied by 0.6 to obtain ASD values.

Wind Base Shear (ASD)						
Load Case A: Transverse Direction						
Load Case	Walls (lbs)	Roof (lbs)	Roof Overhangs (lbs)	Total Lateral Load (lbs)	R ₁ (lbs)	R ₂ (lbs)
Positive Internal Pressure	851	-43	-32	776	425	351
Negative Internal Pressure	851	-43	-32	776	425	351
Roof Pressure = 0	851	0	0	851	467	385
Min. Pressures (8 psf, 16 psf)	691	36	12	739	370	370

- a) Bottom half of wall neglected in tributary area calculations.
b) Strength design values multiplied by 0.6 to obtain ASD values.

Subject	Wind Loads	Customer	Location	Job No.	2025D239
Engr.	Engineer	NJA Engineering 941 New Road, Amherst NY 14228 ph. (716) 572-1140			Rev.
Date	8/21/2025				Page
				 This report may not be copied, reproduced or distributed without the written consent of NJA Engineering Copyright © 2025	3

2.) Lateral Loads - Longitudinal Direction:



- a) (-) signs signify wind lateral forces acting opposite to the direction of the arrows shown.
b) Strength design values multiplied by 0.6 to obtain ASD values.
c) Where the length of building (L) exceeds 4X the mean roof height (h), wind drag forces should additionally be considered.

Wind Base Shear (ASD)						
Load Case B: Longitudinal Direction						
Load Case	Walls (lbs)	Gable Ends (lbs)	Roof (lbs)	Total Lateral Load (lbs)	R _A (lbs)	R _B (lbs)
Positive Internal Pressure	466	23	0	489	267	222
Negative Internal Pressure	466	23	0	489	267	222
Roof Pressure = 0	466	23	0	489	267	222
Min. Pressures (8 psf, 16 psf)	384	20	0	404	202	202

- a) Bottom half of wall neglected in tributary area calculations.
b) Strength design values multiplied by 0.6 to obtain ASD values.


Subject	Customer	Location	Job No.
Wind Loads			2025D239
Engr.	NJA Engineering 941 New Road, Amherst NY 14228 ph. (716) 572-1140		Rev.
Date			-
8/21/2025			Page
			4



This report may not be copied, reproduced or distributed without the written consent of NJA Engineering

Copyright © 2025

3.) Roof Truss Reactions:



- a) Strength design values multiplied by 0.6 to obtain ASD values.
b) Windward loads may be positive or negative depending on pitch of roof.

Roof Truss/Rafter Reactions (ASD)					
w/ Positive Internal Pressure					
Load Case	Horizontal Load (lbs)	Gross Uplift (lbs)	Net Uplift (lbs)	U_1 (lbs)	U_2 (lbs)
Transverse Int. Zone	6	207	15	36	-21
Transverse End Zone	10	302	110	95	15
Longitudinal Int. Zone	5	186	-6	14	-20
Longitudinal End Zone	8	281	89	73	16

- a) Gross Uplift calculations do not include any counteracting roof dead loads.
b) Net Uplift calculations include counteracting roof dead loads multiplied by 0.6 per load case (7) ASCE 7-10.
c) Strength design values multiplied by 0.6 to obtain ASD values for wind loads.
d) Loads based on truss spacing calculated at 24" o/c.
e) Negative values for horizontal load indicate load acting in windward direction (transverse load cases).
f) Negative values for uplift indicate net downward force (zero uplift).

*Disclaimer: The calculations produced herein are for initial design and estimating purposes only. The calculations and drawings presented do not constitute a fully engineered design. All of the potential load cases required to fully design an actual structure may not be provided by this calculator. For the design of an actual structure, a registered and licensed professional should be consulted as per IRC 2012 Sec. R802.10.2 and designed according to the minimum requirements of ASCE 7-10. The wind load calculations provided by this online tool are for educational and illustrative purposes only. Medeck Design assumes no liability or loss for any designs presented and does not guarantee fitness for use.

Subject	Wind Loads	Customer	Location	Job No.	2025D239
Engr.	Engineer	NJA Engineering 941 New Road, Amherst NY 14228 ph. (716) 572-1140			Rev.
Date	8/21/2025				Page
				 This report may not be copied, reproduced or distributed without the written consent of NJA Engineering Copyright © 2025	5