



Wind Load Report

1. Site & Building Data

Roof Type: Gable
Wind Speed (ult): 115 mph
Exposure Category: C
Enclosure Class: Enclosed
Building Width (W): 32 ft.
Building Length (L): 60 ft.
Eave Height (h_e): 12 ft.
Foundation Height (h_f): 0 ft.
Roof Pitch: 6 /12
Eave Overhang (OH_e): 2 ft.
Gable Overhang (OH_g): 1 ft.

2. Parameters & Coefficients

Topographic Factor (K_{zt}): 1.0
Directionality Factor (K_d): .85
Roof Angle (θ): 26.57 deg.
Mean Roof Height (h): 16.00 ft.
Ridge Height (h_r): 20.00 ft.
Pos. Internal Pressure (+GCpi): +0.18
Neg. Internal Pressure (-GCpi): -0.18
Velocity Pressure Exp. Coeff. (K_h): 0.86 @ $z=h$
Velocity Pressure (q_h): 24.76 psf
End Zone Width (a): 3.00 ft.
Zone 2/2E Dist.: 16.00 ft.

3. Design Assumptions and Notes

Code Standard: ASCE 7-10
Geometry: Regular-Shaped Bldg.
Height Class: Low-Rise Building
Notes:

4. Design Loads

Top Chord Dead Load: 7 psf
Bottom Chord Dead Load: 10 psf
Truss/Rafter Spacing: 48 in. o/c

4. Design Wind Pressures: MWFRS Envelope Procedure

Load Case A: Transverse Direction			
Surface	GCpf	Design Pressure (psf)	
		(w/ +GCpi)	(w/ -GCpi)
1	0.55	9.15	18.07
2	-0.10	-6.91	2.00
3	-0.45	-15.53	-6.62
4	-0.39	-14.13	-5.22
1E	0.73	13.56	22.48
2E	-0.19	-9.17	-0.25
3E	-0.58	-18.94	-10.03
4E	-0.53	-17.70	-8.79
2OH	-0.10	-2.46	
2EOH	-0.19	-4.71	
3OH	-0.45	-11.07	
3EOH	-0.58	-14.49	
2OH+W	-0.10/-0.7	-19.56	
2EOH+W	-0.19/-0.7	-21.81	



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
b) External Pressure Coefficients linearly interpolated from Fig. 28.4-1 ASCE 7-10.
c) Design building for all wind directions, 4 load patterns per load case.
d) Total horizontal shear shall not be less than that by neglecting roof wind forces.
e) Min. wind load for enclosed or partially enclosed bldg.: 16 psf wall, 8 psf roof.
f) Design pressures are for strength design, multiply by 0.6 for ASD.


Subject Wind Loads	Customer	Location	Job No. 2025D284
Engr. Engineer Name	ENGINEERING COMPANY INC.		Rev. -
Date 10/15/2025	Street Address City, CA 99999 ph. (800) 000-0000 www.website.com		Page 1

This report may not be copied, reproduced or distributed without the written consent of Engineering Company Inc.

Copyright © 2025

Load Case B: Longitudinal Direction


Surface	GCpf	Design Pressure (psf)	
		(w/ +GCpi)	(w/ -GCpi)
1	-0.45	-15.60	-6.69
2	-0.69	-21.54	-12.63
3	-0.37	-13.62	-4.70
4	-0.45	-15.60	-6.69
5	0.40	5.45	14.36
6	-0.29	-11.64	-2.72
1E	-0.48	-16.34	-7.43
2E	-1.07	-30.95	-22.04
3E	-0.53	-17.58	-8.67
4E	-0.48	-16.34	-7.43
5E	0.61	10.65	19.56
6E	-0.43	-15.11	-6.19
2OH	-0.69	-17.09	
2EOH	-1.07	-26.50	
3OH	-0.37	-9.16	
3EOH	-0.53	-13.12	
2EOH+W	-1.07/-0.7	-43.83	
3EOH+W	-0.53/-0.7	-30.46	



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
b) External Pressure Coefficients linearly interpolated from Fig. 28.4-1 ASCE 7-10.
c) Design building for all wind directions, 4 load patterns per load case.
d) Total horizontal shear shall not be less than that by neglecting roof wind forces.
e) Min. wind load for enclosed or partially enclosed bldg.: 16 psf wall, 8 psf roof.
f) Design pressures are for strength design, multiply by 0.6 for ASD.

Torsional Load Cases

Surface	Load Case	GCpf	Design Pressure (psf)	
			(w/ +GCpi)	(w/ -GCpi)
1T	A	-	2.29	4.52
2T	A	-	-1.73	0.50
3T	A	-	-3.88	-1.65
4T	A	-	-3.53	-1.30
5T	B	-	1.36	3.59
6T	B	-	-2.91	-0.68



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
b) Pressures designated with a "T" are 25% of full design wind pressures.
c) Torsional loading shall apply to all 8 load patterns using the figures shown.
d) Design pressures are for strength design, multiply by 0.6 for ASD.
e) Torsional Design Exceptions: One story bldg. with $h \leq 30$ ft,
Two stories or less framed with light frame construction,
Two stories or less with flexible diaphragms.


Subject	Customer	Location	Job No.
Wind Loads			2025D284
Engr.	ENGINEERING COMPANY INC.		Rev.
Engineer Name	Street Address City, CA 99999		-
Date	ph. (800) 000-0000 www.website.com		Page
10/15/2025			2



This report may not be copied, reproduced or distributed without the written consent of Engineering Company Inc.

5. Wind Load Calculations

1.) Lateral Loads - Transverse Direction:



- a) (-) signs signify wind lateral forces acting opposite to the direction of the arrows shown.
b) Strength design values multiplied by 0.6 to obtain ASD values.


Wind Base Shear (ASD)						
Load Case A: Transverse Direction						
Load Case	Walls (lbs)	Roof (lbs)	Roof Overhangs (lbs)	Total Lateral Load (lbs)	R ₁ (lbs)	R ₂ (lbs)
Positive Internal Pressure	5202	2515	-222	7495	3845	3650
Negative Internal Pressure	5202	2515	-222	7495	3845	3650
Roof Pressure = 0	5202	0	0	5202	2679	2523
Min. Pressures (8 psf, 16 psf)	3456	2304	374	6134	3067	3067

- a) Bottom half of wall neglected in tributary area calculations.
b) Strength design values multiplied by 0.6 to obtain ASD values.

Subject	Customer	Location	Job No.
Wind Loads			2025D284
Engr.	ENGINEERING COMPANY INC. Street Address City, CA 99999 ph. (800) 000-0000 www.website.com		Rev.
Engineer Name			-
Date	10/15/2025		Page
			3

Copyright © 2025

2.) Lateral Loads - Longitudinal Direction:



- a) (-) signs signify wind lateral forces acting opposite to the direction of the arrows shown.
b) Strength design values multiplied by 0.6 to obtain ASD values.
c) Where the length of building (L) exceeds 4X the mean roof height (h), wind drag forces should additionally be considered.

Wind Base Shear (ASD)						
Load Case B: Longitudinal Direction						
Load Case	Walls (lbs)	Gable Ends (lbs)	Roof (lbs)	Total Lateral Load (lbs)	R _A (lbs)	R _B (lbs)
Positive Internal Pressure	2062	1324	0	3386	1740	1645
Negative Internal Pressure	2062	1324	0	3386	1740	1645
Roof Pressure = 0	2062	1324	0	3386	1740	1645
Min. Pressures (8 psf, 16 psf)	1843	1229	0	3072	1536	1536

- a) Bottom half of wall neglected in tributary area calculations.
b) Strength design values multiplied by 0.6 to obtain ASD values.


Subject	Customer	Location	Job No.
Wind Loads			2025D284
Engr.	ENGINEERING COMPANY INC. Street Address City, CA 99999 ph. (800) 000-0000 www.website.com		Rev.
Date			Page
10/15/2025			4



This report may not be copied, reproduced or distributed without the written consent of Engineering Company Inc.

Copyright © 2025

3.) Roof Truss Reactions:



- a) Strength design values multiplied by 0.6 to obtain ASD values.
b) Windward loads may be positive or negative depending on pitch of roof.

Roof Truss/Rafter Reactions (ASD)					
w/ Positive Internal Pressure					
Load Case	Horizontal Load (lbs)	Gross Uplift (lbs)	Net Uplift (lbs)	U ₁ (lbs)	U ₂ (lbs)
Transverse Int. Zone	-145	1009	-435	-279	-157
Transverse End Zone	-170	1254	-190	-170	-20
Longitudinal Int. Zone	171	1476	32	112	-80
Longitudinal End Zone	289	2054	610	467	142

- a) Gross Uplift calculations do not include any counteracting roof dead loads.
b) Net Uplift calculations include counteracting roof dead loads multiplied by 0.6 per load case (7) ASCE 7-10.
c) Strength design values multiplied by 0.6 to obtain ASD values for wind loads.
d) Loads based on truss spacing calculated at 48" o/c.
e) Negative values for horizontal load indicate load acting in windward direction (transverse load cases).
f) Negative values for uplift indicate net downward force (zero uplift).

*Disclaimer: The calculations produced herein are for initial design and estimating purposes only. The calculations and drawings presented do not constitute a fully engineered design. All of the potential load cases required to fully design an actual structure may not be provided by this calculator. For the design of an actual structure, a registered and licensed professional should be consulted as per IRC 2012 Sec. R802.10.2 and designed according to the minimum requirements of ASCE 7-10. The wind load calculations provided by this online tool are for educational and illustrative purposes only. Medeek Design assumes no liability or loss for any designs presented and does not guarantee fitness for use.

Subject	Wind Loads	Customer	Location	Job No.	2025D284	
Engr.	Engineer Name	ENGINEERING COMPANY INC. Street Address City, CA 99999 ph. (800) 000-0000 www.website.com  This report may not be copied, reproduced or distributed without the written consent of Engineering Company Inc. Copyright © 2025			Rev.	-
Date	10/15/2025				Page	5