



Wind Load Report

1. Site & Building Data

Roof Type: Gable
Wind Speed (ult): 120 mph
Exposure Category: C
Enclosure Class: Enclosed
Building Width (W): 45 ft.
Building Length (L): 60 ft.
Eave Height (h_e): 12 ft.
Foundation Height (h_f): 0 ft.
Roof Pitch: 4 /12
Eave Overhang (OH_e): 1 ft.
Gable Overhang (OH_g): 0 ft.

2. Parameters & Coefficients

Topographic Factor (K_{zt}): 1.0
Directionality Factor (K_d): .85
Roof Angle (θ): 18.43 deg.
Mean Roof Height (h): 15.75 ft.
Ridge Height (h_r): 19.50 ft.
Pos. Internal Pressure (+GCpi): +0.18
Neg. Internal Pressure (-GCpi): -0.18
Velocity Pressure Exp. Coeff. (K_h): 0.86 @ $z=h$
Velocity Pressure (q_h): 26.87 psf
End Zone Width (a): 3.00 ft.
Zone 2/2E Dist.: 22.50 ft.

3. Design Assumptions and Notes

Code Standard: ASCE 7-10
Geometry: Regular-Shaped Bldg.
Height Class: Low-Rise Building
Notes:

4. Design Loads

Top Chord Dead Load: 7 psf
Bottom Chord Dead Load: 10 psf
Truss/Rafter Spacing: 120 in. o/c

4. Design Wind Pressures: MWFRS Envelope Procedure

Load Case A: Transverse Direction			
Surface	GCpf	Design Pressure (psf)	
		(w/ +GCpi)	(w/ -GCpi)
1	0.52	9.04	18.72
2	-0.69	-23.38	-13.71
3	-0.47	-17.43	-7.75
4	-0.42	-16.00	-6.33
1E	0.78	16.13	25.80
2E	-1.07	-33.59	-23.92
3E	-0.67	-22.93	-13.26
4E	-0.62	-21.45	-11.77
2OH	-0.69	-18.54	
2EOH	-1.07	-28.76	
3OH	-0.47	-12.59	
3EOH	-0.67	-18.09	
2OH+W	-0.69/-0.7	-37.16	
2EOH+W	-1.07/-0.7	-47.37	



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
b) External Pressure Coefficients linearly interpolated from Fig. 28.4-1 ASCE 7-10.
c) Design building for all wind directions, 4 load patterns per load case.
d) Total horizontal shear shall not be less than that by neglecting roof wind forces.
e) Min. wind load for enclosed or partially enclosed bldg.: 16 psf wall, 8 psf roof.
f) Design pressures are for strength design, multiply by 0.6 for ASD.

Subject	Wind Loads	Customer		Location		Job No.	Oatley
Engr.	Engineer	Company Name 123 Street City, State 12345 ph. (888) 777-5555 www.website.com				Rev.	-
Date	11/6/2025					Page	1


STRUCTURAL ENGINEERS
COMPANY LOGO

This report may not be copied, reproduced or distributed without the written consent of Company Name

Copyright © 2025

Load Case B: Longitudinal Direction


Surface	GCpf	Design Pressure (psf)	
		(w/ +GCpi)	(w/ -GCpi)
1	-0.45	-16.93	-7.26
2	-0.69	-23.38	-13.71
3	-0.37	-14.78	-5.11
4	-0.45	-16.93	-7.26
5	0.40	5.91	15.59
6	-0.29	-12.63	-2.96
1E	-0.48	-17.74	-8.06
2E	-1.07	-33.59	-23.92
3E	-0.53	-19.08	-9.41
4E	-0.48	-17.74	-8.06
5E	0.61	11.56	21.23
6E	-0.43	-16.39	-6.72
2OH	-0.69	-18.54	
2EOH	-1.07	-28.76	
3OH	-0.37	-9.94	
3EOH	-0.53	-14.24	
2EOH+W	-1.07/-0.7	-47.57	
3EOH+W	-0.53/-0.7	-33.05	



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
b) External Pressure Coefficients linearly interpolated from Fig. 28.4-1 ASCE 7-10.
c) Design building for all wind directions, 4 load patterns per load case.
d) Total horizontal shear shall not be less than that by neglecting roof wind forces.
e) Min. wind load for enclosed or partially enclosed bldg.: 16 psf wall, 8 psf roof.
f) Design pressures are for strength design, multiply by 0.6 for ASD.

Torsional Load Cases

Surface	Load Case	GCpf	Design Pressure (psf)	
			(w/ +GCpi)	(w/ -GCpi)
1T	A	-	2.26	4.68
2T	A	-	-5.85	-3.43
3T	A	-	-4.36	-1.94
4T	A	-	-4.00	-1.58
5T	B	-	1.48	3.90
6T	B	-	-3.16	-0.74



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
b) Pressures designated with a "T" are 25% of full design wind pressures.
c) Torsional loading shall apply to all 8 load patterns using the figures shown.
d) Design pressures are for strength design, multiply by 0.6 for ASD.
e) Torsional Design Exceptions: One story bldg. with $h \leq 30$ ft,
Two stories or less framed with light frame construction,
Two stories or less with flexible diaphragms.


Subject	Wind Loads	Customer		Location		Job No.	Oatley
Engr.	Engineer	Company Name 123 Street City, State 12345 ph. (888) 777-5555 www.website.com				Rev.	-
Date	11/6/2025					Page	2



This report may not be
copied, reproduced or
distributed without the
written consent of
Company Name

5. Wind Load Calculations

1.) Lateral Loads - Transverse Direction:



- a) (-) signs signify wind lateral forces acting opposite to the direction of the arrows shown.
b) Strength design values multiplied by 0.6 to obtain ASD values.

Wind Base Shear (ASD)						
Load Case A: Transverse Direction						
Load Case	Walls (lbs)	Roof (lbs)	Roof Overhangs (lbs)	Total Lateral Load (lbs)	R ₁ (lbs)	R ₂ (lbs)
Positive Internal Pressure	5680	-1734	-301	3645	1885	1760
Negative Internal Pressure	5680	-1734	-301	3645	1885	1760
Roof Pressure = 0	5680	0	0	5680	2962	2718
Min. Pressures (8 psf, 16 psf)	3456	2160	96	5712	2856	2856

- a) Bottom half of wall neglected in tributary area calculations.
b) Strength design values multiplied by 0.6 to obtain ASD values.


Subject	Customer	Location	Job No.
Wind Loads			Oatley
Engr.	Company Name 123 Street City, State 12345 ph. (888) 777-5555 www.website.com		Rev.
Date			-
11/6/2025			Page
			3



This report may not be
copied, reproduced or
distributed without the
written consent of
Company Name

Copyright © 2025

2.) Lateral Loads - Longitudinal Direction:




- a) (-) signs signify wind lateral forces acting opposite to the direction of the arrows shown.
b) Strength design values multiplied by 0.6 to obtain ASD values.
c) Where the length of building (L) exceeds 4X the mean roof height (h), wind drag forces should additionally be considered.

Wind Base Shear (ASD)						
Load Case B: Longitudinal Direction						
Load Case	Walls (lbs)	Gable Ends (lbs)	Roof (lbs)	Total Lateral Load (lbs)	R _A (lbs)	R _B (lbs)
Positive Internal Pressure	3106	1886	0	4991	2547	2444
Negative Internal Pressure	3106	1886	0	4991	2547	2444
Roof Pressure = 0	3106	1886	0	4991	2547	2444
Min. Pressures (8 psf, 16 psf)	2592	1620	0	4212	2106	2106

- a) Bottom half of wall neglected in tributary area calculations.
b) Strength design values multiplied by 0.6 to obtain ASD values.

Subject	Wind Loads	Customer	Location	Job No.	Oatley	
Engr.	Engineer	Company Name 123 Street City, State 12345 ph. (888) 777-5555 www.website.com STRUCTURAL ENGINEERS COMPANY LOGO This report may not be copied, reproduced or distributed without the written consent of Company Name Copyright © 2025			Rev.	-
Date	11/6/2025				Page	4

3.) Roof Truss Reactions:



- a) Strength design values multiplied by 0.6 to obtain ASD values.
b) Windward loads may be positive or negative depending on pitch of roof.

Roof Truss/Rafter Reactions (ASD)					
w/ Positive Internal Pressure					
Load Case	Horizontal Load (lbs)	Gross Uplift (lbs)	Net Uplift (lbs)	U_1 (lbs)	U_2 (lbs)
Transverse Int. Zone	317	5808	1027	790	237
Transverse End Zone	538	8024	3243	2071	1172
Longitudinal Int. Zone	404	5323	542	588	-46
Longitudinal End Zone	682	7369	2588	1828	760

- a) Gross Uplift calculations do not include any counteracting roof dead loads.
b) Net Uplift calculations include counteracting roof dead loads multiplied by 0.6 per load case (7) ASCE 7-10.
c) Strength design values multiplied by 0.6 to obtain ASD values for wind loads.
d) Loads based on truss spacing calculated at 120" o/c.
e) Negative values for horizontal load indicate load acting in windward direction (transverse load cases).
f) Negative values for uplift indicate net downward force (zero uplift).

*Disclaimer: The calculations produced herein are for initial design and estimating purposes only. The calculations and drawings presented do not constitute a fully engineered design. All of the potential load cases required to fully design an actual structure may not be provided by this calculator. For the design of an actual structure, a registered and licensed professional should be consulted as per IRC 2012 Sec. R802.10.2 and designed according to the minimum requirements of ASCE 7-10. The wind load calculations provided by this online tool are for educational and illustrative purposes only. Medeek Design assumes no liability or loss for any designs presented and does not guarantee fitness for use.

Subject	Wind Loads	Customer	Location	Job No.	Oatley	
Engr.	Engineer	Company Name 123 Street City, State 12345 ph. (888) 777-5555 www.website.com			Rev.	-
Date	11/6/2025				Page	5

STRUCTURAL ENGINEERS

COMPANY LOGO

This report may not be copied, reproduced or distributed without the written consent of Company Name

Copyright © 2025



This report may not be copied, reproduced or distributed without the written consent of Company Name

Copyright © 2025