



# Wind Load Report

## 1. Site & Building Data

Roof Type: Gable  
 Wind Speed (ult): 116 mph  
 Exposure Category: D  
 Enclosure Class: Enclosed  
 Building Width (W): 42 ft.  
 Building Length (L): 41 ft.  
 Eave Height (h<sub>e</sub>): 12 ft.  
 Foundation Height (h<sub>f</sub>): 3 ft.  
 Roof Pitch: 12 /12  
 Eave Overhang (OH<sub>e</sub>): .5 ft.  
 Gable Overhang (OH<sub>g</sub>): .5 ft.

## 2. Parameters & Coefficients

Topographic Factor (K<sub>zt</sub>): 1.0  
 Directionality Factor (K<sub>d</sub>): .85  
 Roof Angle (θ): 45.00 deg.  
 Mean Roof Height (h): 22.50 ft.  
 Ridge Height (h<sub>r</sub>): 33.00 ft.  
 Pos. Internal Pressure (+GC<sub>pi</sub>): +0.18  
 Neg. Internal Pressure (-GC<sub>pi</sub>): -0.18  
 Velocity Pressure Exp. Coeff. (K<sub>h</sub>): 1.11 @ z=h  
 Velocity Pressure (q<sub>h</sub>): 32.37 psf  
 End Zone Width (a): 3.00 ft.  
 Zone 2/2E Dist.: 21.00 ft.

## 3. Design Assumptions and Notes


Code Standard: ASCE 7-10  
 Geometry: Regular-Shaped Bldg.  
 Height Class: Low-Rise Building  
 Notes:

## 4. Design Loads

Top Chord Dead Load: 7 psf  
 Bottom Chord Dead Load: 10 psf  
 Truss/Rafter Spacing: 19.2 in. o/c

## 4. Design Wind Pressures: MWFRS Envelope Procedure

Load Case A: Transverse Direction			
Surface	GC <sub>pf</sub>	Design Pressure (psf)	
		(w/ +GC <sub>pi</sub> )	(w/ -GC <sub>pi</sub> )
1	0.56	12.30	23.95
2	0.21	0.97	12.62
3	-0.43	-19.75	-8.09
4	-0.37	-17.80	-6.15
1E	0.69	16.51	28.16
2E	0.27	2.91	14.57
3E	-0.53	-22.98	-11.33
4E	-0.48	-21.36	-9.71
2OH	0.21	6.80	
2EOH	0.27	8.74	
3OH	-0.43	-13.92	
3EOH	-0.53	-17.16	
2OH+W	0.21/-0.7	-14.32	
2EOH+W	0.27/-0.7	-12.38	



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
- b) External Pressure Coefficients linearly interpolated from Fig. 28.4-1 ASCE 7-10.
- c) Design building for all wind directions, 4 load patterns per load case.
- d) Total horizontal shear shall not be less than that by neglecting roof wind forces.
- e) Min. wind load for enclosed or partially enclosed bldg.: 16 psf wall, 8 psf roof.
- f) Design pressures are for strength design, multiply by 0.6 for ASD.


Subject <b>Wind Loads</b>	Customer	Location	Job No. <b>2026D38</b>
Engr. <b>Engineer</b>	<b>Company Name</b> 123 Street City, State 12345 ph. (888) 777-5555 www.website.com		Rev. -
Date <b>3/14/2026</b>			Page <b>1</b>



This report may not be copied, reproduced or distributed without the written consent of Company Name

### Load Case B: Longitudinal Direction


Surface	GCpf	Design Pressure (psf)	
		(w/ +GCpi)	(w/ -GCpi)
1	-0.45	-20.39	-8.74
2	-0.69	-28.16	-16.51
3	-0.37	-17.80	-6.15
4	-0.45	-20.39	-8.74
5	0.40	7.12	18.77
6	-0.29	-15.21	-3.56
1E	-0.48	-21.36	-9.71
2E	-1.07	-40.46	-28.81
3E	-0.53	-22.98	-11.33
4E	-0.48	-21.36	-9.71
5E	0.61	13.92	25.57
6E	-0.43	-19.75	-8.09
2OH	-0.69		-22.33
2EOH	-1.07		-34.64
3OH	-0.37		-11.98
3EOH	-0.53		-17.16
2EOH+W	-1.07/-0.7		-57.29
3EOH+W	-0.53/-0.7		-39.81



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
- b) External Pressure Coefficients linearly interpolated from Fig. 28.4-1 ASCE 7-10.
- c) Design building for all wind directions, 4 load patterns per load case.
- d) Total horizontal shear shall not be less than that by neglecting roof wind forces.
- e) Min. wind load for enclosed or partially enclosed bldg.: 16 psf wall, 8 psf roof.
- f) Design pressures are for strength design, multiply by 0.6 for ASD.

### Torsional Load Cases

Surface	Load Case	GCpf	Design Pressure (psf)	
			(w/ +GCpi)	(w/ -GCpi)
1T	A	-	3.08	5.99
2T	A	-	0.24	3.16
3T	A	-	-4.94	-2.02
4T	A	-	-4.45	-1.54
5T	B	-	1.78	4.69
6T	B	-	-3.80	-0.89




- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
- b) Pressures designated with a "T" are 25% of full design wind pressures.
- c) Torsional loading shall apply to all 8 load patterns using the figures shown.
- d) Design pressures are for strength design, multiply by 0.6 for ASD.
- e) Torsional Design Exceptions: One story bldg. with  $h \leq 30$  ft.  
Two stories or less framed with light frame construction,  
Two stories or less with flexible diaphragms.

Subject <b>Wind Loads</b>	Customer	Location	Job No. <b>2026D38</b>
Engr. <b>Engineer</b>	<b>Company Name</b> 123 Street City, State 12345 ph. (888) 777-5555 www.website.com		Rev. -
Date <b>3/14/2026</b>			 This report may not be copied, reproduced or distributed without the written consent of Company Name Copyright © 2026

# 5. Wind Load Calculations

## 1.) Lateral Loads - Transverse Direction:




- a) (-) signs signify wind lateral forces acting opposite to the direction of the arrows shown.
- b) Strength design values multiplied by 0.6 to obtain ASD values.

Wind Base Shear (ASD)						
Load Case A: Transverse Direction						
Load Case	Walls (lbs)	Roof (lbs)	Roof Overhangs (lbs)	Total Lateral Load (lbs)	R <sub>1</sub> (lbs)	R <sub>2</sub> (lbs)
Positive Internal Pressure	3458	11094	299	14851	7667	7184
Negative Internal Pressure	3458	11094	299	14851	7667	7184
Roof Pressure = 0	3458	0	0	3458	1783	1675
Min. Pressures (8 psf, 16 psf)	1771	4133	202	6106	3053	3053

- a) Bottom half of wall neglected in tributary area calculations.
- b) Strength design values multiplied by 0.6 to obtain ASD values.

Subject <b>Wind Loads</b>	Customer	Location	Job No. <b>2026D38</b>
Engr. <b>Engineer</b>	<b>Company Name</b> 123 Street City, State 12345 ph. (888) 777-5555 www.website.com		Rev. -
Date <b>3/14/2026</b>			
This report may not be copied, reproduced or distributed without the written consent of Company Name Copyright © 2026			

2.) Lateral Loads - Longitudinal Direction:




- a) (-) signs signify wind lateral forces acting opposite to the direction of the arrows shown.
- b) Strength design values multiplied by 0.6 to obtain ASD values.
- c) Where the length of building (L) exceeds 4X the mean roof height (h), wind drag forces should additionally be considered.

Wind Base Shear (ASD)						
Load Case B: Longitudinal Direction						
Load Case	Walls (lbs)	Gable Ends (lbs)	Roof (lbs)	Total Lateral Load (lbs)	R <sub>A</sub> (lbs)	R <sub>B</sub> (lbs)
Positive Internal Pressure	2625	5940	0	8565	4339	4226
Negative Internal Pressure	2625	5940	0	8565	4339	4226
Roof Pressure = 0	2625	5940	0	8565	4339	4226
Min. Pressures (8 psf, 16 psf)	1814	4234	0	6048	3024	3024

- a) Bottom half of wall neglected in tributary area calculations.
- b) Strength design values multiplied by 0.6 to obtain ASD values.

Subject <b>Wind Loads</b>	Customer	Location	Job No. <b>2026D38</b>
Engr. <b>Engineer</b>	<b>Company Name</b> 123 Street City, State 12345 ph. (888) 777-5555 www.website.com		Rev. -
Date <b>3/14/2026</b>			
This report may not be copied, reproduced or distributed without the written consent of Company Name Copyright © 2026			

3.) Roof Truss Reactions:



- a) Strength design values multiplied by 0.6 to obtain ASD values.
- b) Windward loads may be positive or negative depending on pitch of roof.

Roof Truss/Rafter Reactions (ASD)					
w/ Positive Internal Pressure					
Load Case	Horizontal Load (lbs)	Gross Uplift (lbs)	Net Uplift (lbs)	U <sub>1</sub> (lbs)	U <sub>2</sub> (lbs)
Transverse Int. Zone	-417	392	-420	-314	-106
Transverse End Zone	-524	419	-393	-328	-65
Longitudinal Int. Zone	214	943	131	120	11
Longitudinal End Zone	361	1304	492	338	154

- a) Gross Uplift calculations do not include any counteracting roof dead loads.
- b) Net Uplift calculations include counteracting roof dead loads multiplied by 0.6 per load case (7) ASCE 7-10.
- c) Strength design values multiplied by 0.6 to obtain ASD values for wind loads.
- d) Loads based on truss spacing calculated at 19.2" o/c.
- e) Negative values for horizontal load indicate load acting in windward direction (transverse load cases).
- f) Negative values for uplift indicate net downward force (zero uplift).

\*Disclaimer: The calculations produced herein are for initial design and estimating purposes only. The calculations and drawings presented do not constitute a fully engineered design. All of the potential load cases required to fully design an actual structure may not be provided by this calculator. For the design of an actual structure, a registered and licensed professional should be consulted as per IRC 2012 Sec. R802.10.2 and designed according to the minimum requirements of ASCE 7-10. The wind load calculations provided by this online tool are for educational and illustrative purposes only. Medeek Design assumes no liability or loss for any designs presented and does not guarantee fitness for use.

Subject <b>Wind Loads</b>	Customer	Location	Job No. <b>2026D38</b>
Engr. <b>Engineer</b>	<b>Company Name</b> 123 Street City, State 12345 ph. (888) 777-5555 www.website.com		Rev. -
Date <b>3/14/2026</b>			 This report may not be copied, reproduced or distributed without the written consent of Company Name Copyright © 2026