



Wind Load Report - CAMPUS CORNER

1. Site & Building Data

Roof Type: Gable
 Wind Speed (ult): 100 mph
 Exposure Category: B
 Enclosure Class: Enclosed
 Building Width (W): 25.5 ft.
 Building Length (L): 65.5 ft.
 Eave Height (h_e): 19.5 ft.
 Foundation Height (h_f): 0 ft.
 Roof Pitch: 8 /12
 Eave Overhang (OH_e): 1.0 ft.
 Gable Overhang (OH_g): 1 ft.

2. Parameters & Coefficients

Topographic Factor (K_{zt}): 1.0
 Directionality Factor (K_d): .85
 Roof Angle (θ): 33.69 deg.
 Mean Roof Height (h): 23.75 ft.
 Ridge Height (h_r): 28.00 ft.
 Pos. Internal Pressure (+GC_{pi}): +0.18
 Neg. Internal Pressure (-GC_{pi}): -0.18
 Velocity Pressure Exp. Coeff. (K_h): 0.70 @ z=h
 Velocity Pressure (q_h): 15.24 psf
 End Zone Width (a): 3.00 ft.
 Zone 2/2E Dist.: 12.75 ft.

3. Design Assumptions and Notes


Code Standard: ASCE 7-10
 Geometry: Regular-Shaped Bldg.
 Height Class: Low-Rise Building
 Notes: WIND LOAD CALCS

4. Design Loads


Top Chord Dead Load: 8 psf
 Bottom Chord Dead Load: 10 psf
 Truss/Rafter Spacing: 24 in. o/c

4. Design Wind Pressures: MWFRS Envelope Procedure

Load Case A: Transverse Direction			
Surface	GC _{pf}	Design Pressure (psf)	
		(w/ +GC _{pi})	(w/ -GC _{pi})
1	0.56	5.79	11.28
2	0.21	0.46	5.95
3	-0.43	-9.30	-3.81
4	-0.37	-8.38	-2.90
1E	0.69	7.77	13.26
2E	0.27	1.37	6.86
3E	-0.53	-10.82	-5.34
4E	-0.48	-10.06	-4.57
2OH	0.21	3.20	
2EOH	0.27	4.12	
3OH	-0.43	-6.56	
3EOH	-0.53	-8.08	
2OH+W	0.21/-0.7	-7.47	
2EOH+W	0.27/-0.7	-6.56	



- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
- b) External Pressure Coefficients linearly interpolated from Fig. 28.4-1 ASCE 7-10.
- c) Design building for all wind directions, 4 load patterns per load case.
- d) Total horizontal shear shall not be less than that by neglecting roof wind forces.
- e) Min. wind load for enclosed or partially enclosed bldg.: 16 psf wall, 8 psf roof.
- f) Design pressures are for strength design, multiply by 0.6 for ASD.

Subject	Customer	Location	Job No.
Wind Loads	TROY MARTINEZ	1501 Chrisway Drive	26 006
Engr.	Company Name		Rev.
Date	123 Street City, State 12345 ph. (888) 777-5555 www.website.com		-
4/26/2026			Page
	<small>This report may not be copied, reproduced or distributed without the written consent of Company Name</small>		1
	Copyright © 2026		

Load Case B: Longitudinal Direction


Surface	GCpf	Design Pressure (psf)	
		(w/ +GCpi)	(w/ -GCpi)
1	-0.45	-9.60	-4.12
2	-0.69	-13.26	-7.77
3	-0.37	-8.38	-2.90
4	-0.45	-9.60	-4.12
5	0.40	3.35	8.84
6	-0.29	-7.17	-1.68
1E	-0.48	-10.06	-4.57
2E	-1.07	-19.06	-13.57
3E	-0.53	-10.82	-5.34
4E	-0.48	-10.06	-4.57
5E	0.61	6.56	12.04
6E	-0.43	-9.30	-3.81
2OH	-0.69	-10.52	
2EOH	-1.07	-16.31	
3OH	-0.37	-5.64	
3EOH	-0.53	-8.08	
2EOH+W	-1.07/-0.7	-26.98	
3EOH+W	-0.53/-0.7	-18.75	




- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
- b) External Pressure Coefficients linearly interpolated from Fig. 28.4-1 ASCE 7-10.
- c) Design building for all wind directions, 4 load patterns per load case.
- d) Total horizontal shear shall not be less than that by neglecting roof wind forces.
- e) Min. wind load for enclosed or partially enclosed bldg.: 16 psf wall, 8 psf roof.
- f) Design pressures are for strength design, multiply by 0.6 for ASD.

Torsional Load Cases

Surface	Load Case	GCpf	Design Pressure (psf)	
			(w/ +GCpi)	(w/ -GCpi)
1T	A	-	1.45	2.82
2T	A	-	0.11	1.49
3T	A	-	-2.32	-0.95
4T	A	-	-2.10	-0.72
5T	B	-	0.84	2.21
6T	B	-	-1.79	-0.42




- a) (+) and (-) signs signify wind pressures acting toward & away from surfaces.
- b) Pressures designated with a "T" are 25% of full design wind pressures.
- c) Torsional loading shall apply to all 8 load patterns using the figures shown.
- d) Design pressures are for strength design, multiply by 0.6 for ASD.
- e) Torsional Design Exceptions: One story bldg. with $h \leq 30$ ft.
Two stories or less framed with light frame construction,
Two stories or less with flexible diaphragms.

Subject	Customer	Location	Job No.
Wind Loads	TROY MARTINEZ	1501 Chrisway Drive	26 006
Engr.	Engineer	Company Name	Rev.
Date	4/26/2026	123 Street City, State 12345 ph. (888) 777-5555 www.website.com	-
			Page
<small>This report may not be copied, reproduced or distributed without the written consent of Company Name</small>			2
<small>Copyright © 2026</small>			

5. Wind Load Calculations


1.) Lateral Loads - Transverse Direction:



- a) (-) signs signify wind lateral forces acting opposite to the direction of the arrows shown.
- b) Strength design values multiplied by 0.6 to obtain ASD values.


Wind Base Shear (ASD)						
Load Case A: Transverse Direction						
Load Case	Walls (lbs)	Roof (lbs)	Roof Overhangs (lbs)	Total Lateral Load (lbs)	R ₁ (lbs)	R ₂ (lbs)
Positive Internal Pressure	5561	3334	94	8989	4596	4393
Negative Internal Pressure	5561	3334	94	8989	4596	4393
Roof Pressure = 0	5561	0	0	5561	2839	2722
Min. Pressures (8 psf, 16 psf)	6131	2672	298	9101	4550	4550

- a) Bottom half of wall neglected in tributary area calculations.
- b) Strength design values multiplied by 0.6 to obtain ASD values.

Subject	Wind Loads	Customer	TROY MARTINEZ	Location	1501 Chrisway Drive	Job No.	26 006	
Engr.	Engineer	Company Name 123 Street City, State 12345 ph. (888) 777-5555 www.website.com					Rev.	-
Date	4/26/2026						Page	3

This report may not be copied, reproduced or distributed without the written consent of Company Name

2.) Lateral Loads - Longitudinal Direction:



- a) (-) signs signify wind lateral forces acting opposite to the direction of the arrows shown.
- b) Strength design values multiplied by 0.6 to obtain ASD values.
- c) Where the length of building (L) exceeds 4X the mean roof height (h), wind drag forces should additionally be considered.


Wind Base Shear (ASD)						
Load Case B: Longitudinal Direction						
Load Case	Walls (lbs)	Gable Ends (lbs)	Roof (lbs)	Total Lateral Load (lbs)	R _A (lbs)	R _B (lbs)
Positive Internal Pressure	1663	694	0	2356	1224	1133
Negative Internal Pressure	1663	694	0	2356	1224	1133
Roof Pressure = 0	1663	694	0	2356	1224	1133
Min. Pressures (8 psf, 16 psf)	2387	1040	0	3427	1714	1714

- a) Bottom half of wall neglected in tributary area calculations.
- b) Strength design values multiplied by 0.6 to obtain ASD values.

Subject	Wind Loads	Customer	TROY MARTINEZ	Location	1501 Chrisway Drive	Job No.	26 006	
Engr.	Engineer	Company Name 123 Street City, State 12345 ph. (888) 777-5555 www.website.com					Rev.	-
Date	4/26/2026						Page	4

This report may not be copied, reproduced or distributed without the written consent of Company Name

3.) Roof Truss Reactions:



- a) Strength design values multiplied by 0.6 to obtain ASD values.
- b) Windward loads may be positive or negative depending on pitch of roof.

Roof Truss/Rafter Reactions (ASD)					
w/ Positive Internal Pressure					
Load Case	Horizontal Load (lbs)	Gross Uplift (lbs)	Net Uplift (lbs)	U ₁ (lbs)	U ₂ (lbs)
Transverse Int. Zone	-99	152	-471	-272	-199
Transverse End Zone	-126	162	-461	-278	-183
Longitudinal Int. Zone	54	351	-273	-115	-158
Longitudinal End Zone	91	486	-137	-32	-105

- a) Gross Uplift calculations do not include any counteracting roof dead loads.
- b) Net Uplift calculations include counteracting roof dead loads multiplied by 0.6 per load case (7) ASCE 7-10.
- c) Strength design values multiplied by 0.6 to obtain ASD values for wind loads.
- d) Loads based on truss spacing calculated at 24" o/c.
- e) Negative values for horizontal load indicate load acting in windward direction (transverse load cases).
- f) Negative values for uplift indicate net downward force (zero uplift).

*Disclaimer: The calculations produced herein are for initial design and estimating purposes only. The calculations and drawings presented do not constitute a fully engineered design. All of the potential load cases required to fully design an actual structure may not be provided by this calculator. For the design of an actual structure, a registered and licensed professional should be consulted as per IRC 2012 Sec. R802.10.2 and designed according to the minimum requirements of ASCE 7-10. The wind load calculations provided by this online tool are for educational and illustrative purposes only. Medeek Design assumes no liability or loss for any designs presented and does not guarantee fitness for use.

Subject	Wind Loads	Customer	TROY MARTINEZ	Location	1501 Chrisway Drive	Job No.	26 006	
Engr.	Engineer	Company Name 123 Street City, State 12345 ph. (888) 777-5555 www.website.com					Rev.	-
Date	4/26/2026						Page	5